

February 24, 1997

Mr. Kevin P. Donovan, Chairman
Boiling Water Reactor Owners' Group
Centerior Energy
Perry Power Plant
MC A210
P. O. Box 97
Perry, OH 44081

SUBJECT: BWR OWNERS' GROUP TOPICAL REPORT, NEDC-32160P, "CALIBRATION
INTERVAL EXTENSION," DATED DECEMBER 1992 (TAC NO. M85776)

Dear Mr. Donovan:

By letter dated June 13, 1996, the staff issued a status report on its review of the BWR Owners' Group (BWROG) topical report NEDC-32160P, "Calibration Interval Extension." The staff's review concluded that the extended surveillance intervals proposed in NEDC-32160P were inadequately justified by the topical report evaluations and by the additional data and analyses provided in the BWROG's responses to the staff's requests for additional information.

During management meetings between the NRC and the BWROG held on July 10 and October 23, 1996, the BWROG discussed the status of the topical report and stated that it would arrange a meeting with the staff to discuss the open items described in the staff's status report. To date, the BWROG has not arranged a meeting with the staff, nor has it provided an indication of a time frame for addressing the open issues. This lack of activity leads the staff to conclude that the topical report is no longer being actively pursued and we intend to terminate our review of NEDC-32160P unless we hear from you within 30 days.

If you have any questions concerning this matter, please contact the project manager, Jim Wilson, at (301) 415-1108.

Sincerely,
Original Signed By:
David B. Matthews, Chief
Generic Issues and Environmental
Projects Branch
Office of Nuclear Reactor Regulation

Project No. 691

cc: see attached list

DISTRIBUTION:

Central File	PGEb r/f	OGC	BBoger	JGaniere	JMauck
PUBLIC	ACRS	TMartin	JWermiel	CDoutt	MChiramal
Document Name: TR32160P					

OFC	PGEb <i>sw</i>	SC:PGEb <i>sw</i>	C:HICB	C:PGEb <i>sw</i>
NAME	JWilson:sw	RArchitzel	JWermiel	DMatthews
DATE	2/20/97	2/21/97	2/20/97	2/24/97

OFFICIAL RECORD COPY

9702260360 970224
PDR PROJ
691 PDR

97-37
NRC FILE CENTER COPY

PROJ

DF0310
PROJ 691



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 24, 1997

Mr. Kevin P. Donovan, Chairman
Boiling Water Reactor Owners' Group
Centerior Energy
Perry Power Plant
MC A210
P. O. Box 97
Perry, OH 44081

SUBJECT: BWR OWNERS' GROUP TOPICAL REPORT, NEDC-32160P, "CALIBRATION
INTERVAL EXTENSION," DATED DECEMBER 1992 (TAC NO. M85776)

Dear Mr. Donovan:

By letter dated June 13, 1996, the staff issued a status report on its review of the BWR Owners' Group (BWROG) topical report NEDC-32160P, "Calibration Interval Extension." The staff's review concluded that the extended surveillance intervals proposed in NEDC-32160P were inadequately justified by the topical report evaluations and by the additional data and analyses provided in the BWROG's responses to the staff's requests for additional information.

During management meetings between the NRC and the BWROG held on July 10 and October 23, 1996, the BWROG discussed the status of the topical report and stated that it would arrange a meeting with the staff to discuss the open items described in the staff's status report. To date, the BWROG has not arranged a meeting with the staff, nor has it provided an indication of a time frame for addressing the open issues. This lack of activity leads the staff to conclude that the topical report is no longer being actively pursued and we intend to terminate our review of NEDC-32160P unless we hear from you within 30 days.

If you have any questions concerning this matter, please contact the project manager, Jim Wilson, at (301) 415-1108.

Sincerely,

A handwritten signature in cursive script, reading "D B Matthews".

David B. Matthews, Chief
Generic Issues and Environmental
Projects Branch
Office of Nuclear Reactor Regulation

Project No. 691

cc: see attached list

Project No. 691
Boiling Water Reactor Owners Group

cc: C. D. Terry
Vice President, Nuclear Engineering
Niagara Mohawk Power Corporation
Nine Mile Point-2
PO Box 63
Lycoming, NY 13093

D. B. Feters
PECO Energy
Nuclear Group Headquarters
MC 62C-3
965 Chesterbrook Blvd.
Wayne, PA 19087

L. A. England
Entergy Operations Inc.
PO Box 31995
Jackson, MS 39286

K. K. Sedney
GE Nuclear Energy
175 Curtner Ave, M/C 182
San Jose, CA 95125

T. J. Rausch
Commonwealth Edison Company
Nuclear Fuel Services
1400 Opus Place, 4th Floor ETWIII
Downers Grove, IL 60515