

Log # TXX-4545
File # 10010
909.5

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

WILLIAM G. COUNCIL
EXECUTIVE VICE PRESIDENT

September 4, 1985

Director of Nuclear Reactor Regulation
Attention: Mr. Vincent S. Noonan, Director
Comanche Peak Project
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
OPERATOR ACTION TO RESTORE UPS ROOM
VENTILATION DURING A POSTULATED
CONTROL ROOM/CABLE SPREADING ROOM FIRE

Dear Mr. Noonan:

Texas Utilities letter TXX-4528 dated August 6, 1985 stated that for a Control Room/Cable Spreading Room Fire, concurrent with a loss of offsite power, operator action to restore UPS room ventilation is required in less than ten minutes.

We have reviewed the qualification of the safe shutdown equipment contained in the UPS room and have determined that the equipment can operate for greater than ten minutes without ventilation.

Should you have any questions in this matter, please contact this office.

Very truly yours,

W. G. Council
W. G. Council

BSD/grr

8509100095 850904
PDR ADOCK 05000445
F PDR