

PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101



February 21, 1997

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk


SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
1996 Steam Generator Tube Inspection Results Report

REFERENCE: (a) Calvert Cliffs Units 1 and 2 Technical Specifications 4.4.5.5.b

Reference (a) requires that we report, on an annual basis, the results of the steam generator tube inservice inspection conducted in the past year. This report includes the number and extent of tubes examined, imperfections noted, and the identity of tubes plugged. Attached please find the report of steam generator tube examinations conducted on the Unit 1 steam generators in April 1996. The Unit 1 steam generator tube inspection results required 340 total tubes to be plugged in No. 11 Steam Generator and 500 total tubes to be plugged in No. 12 Steam Generator. The number of circumferential flaws detected were 58 in No. 11 Steam Generator and 38 in No. 12 Steam Generator. No similar inspections were conducted on the Unit 2 steam generators in 1996.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,


for
P. E. Katz

Plant General Manager

9702270273 970221
PDR ADOCK 05000317
G PDR

PEK/RCG/bjd

Attachment

IEO1/1



cc: A. W. Dromerick, NRC
H. J. Miller, NRC
Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC

(Without Attachment)

D. A. Brune, Esquire
J. E. Silberg, Esquire
Director, Project Directorate I-1, NRC