



Northeast
Utilities System

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791

November 27, 1996

Docket No. 50-423
B16023

Re: 10CFR 50.73(a)(2)(i)(B)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 96-042-00
Submitted Pursuant to 10CFR 50.73(a)(2)(i)

This letter forwards Licensee Event Report 96-042-00, documenting a condition that was determined at Millstone Unit No. 3 on October 28, 1996. This LER is submitted pursuant to 10CFR 50.73(a)(2)(i)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. James M. Peschel at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



M. H. Brothers
Unit Director, Millstone Unit No. 3

030022

9612030319 961127
PDR ADOCK 05000423
S PDR

IE22%

Attachment: 1) NNECO's commitments in response to LER 96-042-00
2) LER 96-042-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response
(LER 96-042-00)

November 1996

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Any other actions discussed in the submittal represent intended or planned actions by NNECO. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16023-01	Response time testing of the Containment Fuel Drop Instrument channels will be successfully completed.	Prior to returning the Containment Purge & Vent valves to service
B16023-02	Procedure DC 10, "Incorporation and Implementation of License Amendments" will be revised to clarify the requirements and responsibilities for implementation of license amendments.	March 31, 1997
B16023-03	Licensing personnel and appropriate line personnel will be trained on the requirements and responsibilities associated with developing and processing Technical Specification change requests	March 31, 1997