



**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

February 19, 1997

Docket No. 50-245
B16171

Re: 10CFR50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 95-033-00, documenting events that occurred at Millstone Nuclear Power Station, Unit No. 1 on June 23, 1995 and November 25, 1995. This LER is submitted pursuant to 10CFR50.73(a)(2)(ii).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16171-1 During Refueling Outage 15, the S1 Turbine Building Secondary Closed Cooling Water and Service Water relays were removed from within the S2 train isolation box in Control Room Panel 906. The change documentation did not specify that the S1 and S2 wiring must be separated by three feet or a barrier be provided. Therefore, the S1 and S2 wiring will be checked to ensure that it meets the requisite separation requirement prior to startup for operating Cycle 16.
- B16171-2 NNECO commits that the S2 train diesel powered Service Water Pump control cable entering S1 Bus 14E Cubicle 10 will be removed or a suitable barrier provided prior to startup for operating Cycle 16.
- B16171-3 NNECO commits that the Updated Final Safety Analysis Report will be updated to include applicable physical wiring separation criteria applicable to Millstone Unit No. 1. This will be completed prior to startup for operating Cycle 16.
- B16171-4 NNECO commits that the under the Configuration Management Program/50.54(f) effort, NNECO will perform a review of the physical separation of wiring at Millstone Unit No. 1 prior to startup for operating Cycle 16.

9702280023 970219
PDR ADOCK 05000245
S PDR

JE221

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in dark ink, consisting of several loops and a long horizontal stroke at the end, positioned above a solid horizontal line.

P. D. Hinnenkamp
Director, Unit Operations

Attachment: LER 95-033-00

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1