

```

NNNNNNNNNNNNNNNN
N   BOILING   N
N   WATER     N
N   REACTORS  N
NNNNNNNNNNNNNNNN

```

FACILITY

and FEB 1985-

8509100470 850630
PDR ADOCK 05000155
R PDR



NUCLEAR OPERATIONS DEPARTMENT **Unit Shutdowns and Power Reductions**

| | | | | | |
|---------------------------|-------------------------|------------------------------|----------------------|-------------------------|----------------------------------|
| Report Month June 1985 | Docket Number 50-155 | Unit Big Rock Point Plant | Date July 5, 1985 | Completed by JSDugan | Telephone (616)547-6537 X 180 |
|---------------------------|-------------------------|------------------------------|----------------------|-------------------------|----------------------------------|

| Number | Date | Type ¹ | Duration (Hours) | Reason ² | Method of Shutting Down ³ Reactor | Licensee Event Report Number | System Code ⁴ | Component Code ⁵ | Cause and Corrective Action To Prevent Recurrence |
|---|------|-------------------|---------------------|---------------------|---|---------------------------------|-----------------------------|--------------------------------|---|
| <div>←</div> <div>NONE</div> <div>→</div> | | | | | | | | | |

¹F = Forced
S = Scheduled

²Reason:
A = Equipment Failure (Explain)
B = Maintenance of Test
C = Refueling
D = Regulatory Restriction
E = Operator Training and License Examination
F = Administrative
G = Operational Error (Explain)
H = Other (Explain)

³Method:
1 = Manual
2 = Manual Scram
3 = Automatic Scram
4 = Other (Explain)

⁴Exhibit G = Instructions for
Preparation of Data Entry Sheets
for Licensee Event Report (LER)
File (NUREG-0161)

⁵Exhibit I = Same Source

| | | |
|----|--------|-------|
| 1 | 202.37 | 62.00 |
| 2 | 197.17 | 60.50 |
| 3 | 196.71 | 60.11 |
| 4 | 195.17 | 59.78 |
| 5 | 193.79 | 59.50 |
| 6 | 191.46 | 59.20 |
| 7 | 192.21 | 58.87 |
| 8 | 187.87 | 58.67 |
| 9 | 188.42 | 58.27 |
| 10 | 187.71 | 59.05 |
| 11 | 187.79 | 57.77 |
| 12 | 184.54 | 57.47 |
| 13 | 187.71 | 57.19 |
| 14 | 184.46 | 56.90 |
| 15 | 184.17 | 56.58 |
| 16 | 182.71 | 56.38 |
| 17 | 181.92 | 56.08 |
| 18 | 181.42 | 55.75 |
| 19 | 180.33 | 55.53 |
| 20 | 183.17 | 55.41 |
| 21 | 177.54 | 55.58 |
| 22 | 180.29 | 55.44 |
| 23 | 178.83 | 55.07 |
| 24 | 178.79 | 54.85 |
| 25 | 178.21 | 54.60 |
| 26 | 177.29 | 54.39 |
| 27 | 152.67 | 45.72 |
| 28 | 179.75 | 55.05 |
| 29 | 173.25 | 53.17 |
| 30 | 172.62 | 53.01 |

Refueling Information Request

1. Facility name: Big Rock Point Plant
2. Scheduled date for next refueling shutdown: August 1985
3. Scheduled date for restart following shutdown: October 1985
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes

If yes, explain: Addition of "Appendix R" commitments and 11 Reload.

If no, has the reload fuel design and core configuration been reviewed by Plant Safety Review Committee to determine whether any unreviewed safety questions as associated with the core reload (Reference 10 CFR, Section 50.59)?

If no review has taken place, when is it scheduled?

5. Scheduled date(s) for submittal of proposed licensing action and supporting information:
6. Important licensing considerations associated with refueling, eg, new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design new operating procedures:
7. Number of fuel assemblies in: core 84; spent fuel storage pool 172.
8. Present licensed spent fuel storage capacity: 441

Size of any increase in licensed storage capacity that has been requested or is planned (in number of fuel assemblies):
9. Projected date of last refueling that can be discharged to spent fuel pool assuming the present license capacity: 1993



Consumers
Power
Company

Big Rock Point Nuclear Plant, Box 591, Route 3, Charlevoix, MI 49720

5p-155
D P Hoffman
Plant Superintendent

July 5, 1985

Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Enclosed please find the statistical data for the Big Rock Point Nuclear Plant covering the period of June 1 through June 30, 1985.

Sincerely,

D P Hoffman
Plant Superintendent

DPH:11b

Enclosures

cc: DEVanFarowe, Department of Public Health
RCallen, Michigan Public Service Commission
Michigan Department of Labor
INPO Records Center
Resident NRC Inspector, Site
Document Control, BRP, 740*22*35*10
RBDeWitt, P24-117B
DJVandeWalle, P24-115
WGFogg, P24-610
File

IE24
1/1