

Georgia Power Company
Post Office Box 439
Baxley, Georgia 31513
Telephone 912 367-7781
912 537-9444



Edwin I. Hatch Nuclear Plant

July 30, 1985
LR-MGR-132-0785

PLANT E. I. HATCH
Correction of Monthly Operating Report for June 1985


Director
Office of Management and Program Analysis
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Sir:

In the June 1985 Monthly Operating Report for Hatch Unit One, Docket 50-321, it was incorrectly reported that on June 27, 1985 the unit was manually scrammed because of the loss of both A&B 4160V busses. However, further investigation revealed that an automatic scram signal was received approximately one half second prior to the reactor operator actuating the manual scram.

Please note this change in the Narrative Report and in the Unit Shutdowns and Power Reductions Report.

If you have any questions please contact me at (912) 367-7851.



H. C. Nix
General Manager

WV EDW GHR
HCN/CTJ/GAG/EZW/JHR/bb

xc: T. V. Greene
File

8509100499 850730
PDR ADOCK 05000321
R PDR

*IE24
1/0*