

REVISED  
7/18/85

DOCKET NO. 50 - 352

DATE JUNE 14, 1985

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

W.M. ALDEN  
ENGINEER-IN-CHARGE  
NUCLEAR SECTION  
GENERATION DIVISION-NUCLEAR  
TELEPHONE (215) 841-5022

## OPERATING STATUS

1. UNIT NAME: LIMERICK UNIT 1
2. REPORTING PERIOD: MAY, 1985
3. LICENSED THERMAL POWER (MWT): 165
4. NAMEPLATE RATING (GROSS MWE): 1092
5. DESIGN ELECTRICAL RATING (NET MWE): 1055
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): -
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): -
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
10. REASONS FOR RESTRICTIONS, IF ANY:

NOTES: UNIT 1 IS IN STARTUP TESTING.  
FACILITY OPERATING LICENSE  
NPF-27, ISSUED 10/26/84, RE-  
STRICTS POWER LEVELS NOT TO  
EXCEED 5% OF THE RATED POWER.

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	0	0	0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0	1,413.8	1,451.5
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	0.0	25.3	25.3
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	0	131,922	131,922
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0	310	310
18. NET ELECTRICAL ENERGY GENERATED (MWH)	* -7,226	* -9,400	* -9,400
19. UNIT SERVICE FACTOR	0.0	0.7	0.6
20. UNIT AVAILABILITY FACTOR	0.0	0.7	0.6
21. UNIT CAPACITY FACTOR (USING MDC NET)	0.0	0.0	0.0
22. UNIT CAPACITY FACTOR (USING DER NET)	0.0	0.0	0.0
23. UNIT FORCED OUTAGE RATE	0.0	0.0	0.0
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): UNIT #1 IN SHUTDOWN MODE. UNIT PENDING FULL POWER LICENSE.			

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION):	FORECAST	ACHIEVED
INITIAL CRITICALITY	12/19/84	12/22/84
INITIAL ELECTRICITY	MID APRIL 85	4/13/85
COMMERCIAL OPERATION	4TH QTR 85	

\* - NEGATIVE VALUE REPORTED FOR CONSISTENCY WITH FEDERAL ENERGY REGULATORY COMMISSION REPORTS.

850911014 850718  
PDR ADOCK 05006352  
PDR