



Consumers  
Power  
Company

David J VandeWalle  
Director of  
Nuclear Licensing

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-1636

September 3, 1985

Director,  
Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 - BIG ROCK POINT PLANT -  
SUPPLEMENTAL TECHNICAL SPECIFICATION CHANGE REQUEST - CONTROL ROD DRIVE  
PERFORMANCE

Consumers Power Company submitted a proposed technical specification change to eliminate the minimum control rod withdrawal rate limit by letter dated November 1, 1974. Consumers Power Company contends that the November 1, 1974 submittal as supplemented by our July 1, 1975 letter provide sufficient justification for deletion of the 23 second minimum withdrawal time. This submittal is a synopsis of previous correspondence and an addenda to address any editorial changes that may have occurred since 1974. Accordingly, revised technical specification pages are enclosed which supersede those in our previous submittal. Additionally, an updated evaluation showing Big Rock Points compliance with more recent review criteria is attached.

Pursuant to 10CFR170.12(c), a check in the amount of \$150 is attached.

David J VandeWalle  
Director, Nuclear Licensing

CC Administrator, Region III, USNRC  
NRC Resident Inspector - Big Rock Point

Attachment

8509110183 850903  
PDR ADOCK 05000155  
P PDR

CC0885-0005B-NL02

Rec'd w/ check \$150.00  
#488241

A001  
/38