

ADMINISTRATIVE CONTROLS

INDEPENDENT SAFETY ENGINEERING GROUP (ISEG) (Continued)

RESPONSIBILITIES

6.2.3.3 The ISEG shall be responsible for maintaining surveillance of unit activities to provide independent verification* that these activities are performed correctly and that human errors are reduced as much as practical.

AUTHORITY

6.2.3.4 The ISEG shall make detailed recommendations for revised procedures, equipment modifications, maintenance activities, operations activities or other means of improving unit safety to the Senior Vice President, Nuclear.

6.2.4 SHIFT TECHNICAL ADVISOR

6.2.4.1 The Shift Technical Advisor shall provide technical support to the Shift Superintendent in the areas of thermal hydraulics, reactor engineering and plant analysis with regard to safe operation of the unit.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions and the supplemental requirements specified in Section A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, except for the Chemistry/Radiation Control Superintendent who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975; the Shift Technical Advisor who shall meet or exceed the qualifications referred to in Section 2.2.1.b of Enclosure I of the October 30, 1979 NRC letter to all operating nuclear power plants; and those members of the Independent Safety Engineering Group used for meeting the minimum complement specified in Section 6.2.3.2, each of whom shall have a Bachelor of Science degree or be registered as a Professional Engineer and shall have at least two years experience in their field, at least one year of which experience shall be in the nuclear field.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Training Superintendent, shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and Appendix "A" of 10 CFR Part 55 and the supplemental requirements specified in Sections A and C of Enclosure 1 of the March 28, 1980 NRC letter[#] to all licensees, and shall include familiarization with relevant industry operational experience.

6.5 REVIEW AND AUDIT

6.5.1 PLANT SAFETY REVIEW COMMITTEE (PSRC)

FUNCTION

6.5.1.1 The PSRC shall function to advise the GGNS General Manager on all matters related to nuclear safety.

* Not responsible for sign-off function.

[#] Except that the experience and other training information provided in a letter to the NRC dated July 29, 1985 are acceptable for the individuals listed in that letter.