

Docket Nos.: 50-440
and 50-441

SEP 10 1985

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Compliance with TMI Action Plan Item III.D.1.1, "Primary Coolant
Outside Containment" -- Perry Nuclear Power Plant (Units 1 and 2)

The staff has reviewed your letter dated May 29, 1985, which details CEI's proposed resolution of TMI Action Plan Item III.D.1.1 and finds that the emergency service water system, the scram discharge volume and the emergency closed cooling system should be added to the Perry Leakage Surveillance and Preventative Maintenance Program. In addition, the Leakage Surveillance and Preventative Maintenance Program should address inspection of heat exchangers such as the RHR heat exchanger, fuel pool heat exchangers, HPCS room cooler, etc., and components served by the aforementioned systems which could be potential sources of leakage. Additional justification for excluding the reactor water cleanup (RWCU) system should be provided since the Postaccident Sampling System will sample 3 points of the RWCU system.

This letter has been discussed with your staff and a commitment received for a prompt response in view of your current fuel load dated scheduled for Perry Unit 1.

Sincerely,

ORIGINAL SIGNED BY:

L. N. Okhan

R. J. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

DISTRIBUTION:

Docket File	JStefano	GWillis
NRC PDR	JStefano	JHayes
LPDR	AJ (16)	
NSIC	Jordan	
PRC System	JPartlow	
LB#1 R/F	BGrimes	
MRushbrook	WGammill	

LB#1:DL
JStefano:kab
9/10/85

LB#1:DL
BJYoungblood
9/10/85

8509130007 850910
PDR ADOCK 05000440
PDR

SEP 10 1985

Mr. Murray R. Edelman
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Units 1 and 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047