

**Northeast  
Utilities System**

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791

February 28, 1997

Docket No. 50-245  
B16213

Re: 10CFR50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-004-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on January 27, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(ii).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.


- B16213-1 NNECO commits that a radiological assessment will be performed by March 21, 1997, to determine the impact on off-site dose calculations based on the additional leakage from the penetration X-24. Based on the results, an engineering evaluation will be performed on containment isolation valve 1-RC-206 to determine the corrective actions required to assure that the offsite dose remains within allowable limits. The results of the radiological assessment and any required corrective actions will be provided in a supplement to this report by April 30, 1997.
- B16213-2 NNECO commits that the required corrective actions will be completed prior to primary containment being required for operating Cycle 16.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

040092

9703040377 970228  
PDR ADDCK 05000245  
S PDR

  
P. D. Hinnenkamp  
Director, Unit Operations

Attachment: LER 97-004-00

cc: Dr. W. D. Travers, Director, Special Projects  
H. J. Miller, Region I Administrator  
S. Dembek, NRC Project Manager, Millstone Unit No. 1  
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1



11  
1022