

September 6, 1985

Docket No. 50-302

DISTRIBUTION

Mr. Walter S. Wilgus
Vice President, Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Licensing
& Fuel Management
P. O. Box 14042; M.A.C. H-3
St. Petersburg, Florida 33733

Docket File
NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan
BGrimes
JPartlow
ACRS-10

RIngram
HSilver
BMozafari
Gray File
EBrach
HOrnstein
WPaulson
GEdison
RRamirez

Dear Mr. Wilgus:

By letter dated June 17, 1985, you submitted the DCRDR Summary Report (SR) for Crystal River Unit 3 (CR-3) as required by Supplement 1 to NUREG-0737. Based on our review of that document, we have identified shortcomings in the following areas:

1. outlining proposed control room changes
2. proposed schedules for making changes
3. providing acceptable justification for human engineering discrepancies with safety significance to be left uncorrected or partially corrected.

Our specific concerns and the information needed to complete our review of the CR-3 DCRDR are identified in the enclosed evaluation prepared by our contractor Science Applications International Inc. (SAIC). We agree with the technical evaluations, conclusions, and recommendations contained in that evaluation.

Because of the number of concerns we have with your DCRDR SR, and the complexity of some of these concerns, we propose to meet with you to discuss the SR. Please arrange such a meeting with the NRC Project Manager to take place as soon as possible, but no later than 60 days after receipt of this report.

At this meeting, you should be prepared to discuss our concerns, present the requested information, and make any necessary commitments toward completing the DCRDR.

8509160116 850906
PDR ADOCK 05000302
P PDR

Mr. Wilgus

-2-

This request for additional information affects fewer than ten respondents; therefore, OMB clearance is not required under P. L. 96-511.


Sincerely,


*ORIGINAL SIGNED BY
JOHN F. STOLZ*

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
As Stated

cc w/enclosure:
See next page


ORB#4:DL
HSilver;cr
9/5/85


ORB#4:DL
JStolz
9/5/85

Mr. W. S. Wilgus
Florida Power Corporation

Crystal River Unit No. 3 Nuclear
Generating Plant

cc:

Mr. R. W. Neiser
Senior Vice President
and General Counsel
Florida Power Corporation
P. O. Box 14042
St Petersburg, Florida 33733

Bureau of Intergovernmental Relations
660 Apalachee Parkway
Tallahassee, Florida 32304

Mr. Wilbur Langely, Chairman
Board of County Commissioners
Citrus County
Inverness, Florida 36250

Nuclear Plant Manager
Florida Power Corporation
P. O. Box 219
Crystal River, Florida 32629

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector
U.S. Nuclear Regulatory Commission
Route #3, Box 717
Crystal River, Florida 32629

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. Ulray Clark, Administrator
Radiological Health Services
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304