



ATOMIC POWER COMPANY •

EDISON DRIVE
AUGUSTA, MAINE 04336
(207) 623-3521

September 6, 1985
MN-85-160

Proposed Change # 120

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

References: (a) License No. DPR-36 (Docket No. 50-309)

Subject: Proposed Change to Maine Yankee Technical Specifications - Turbine
Driven Auxiliary Feedwater Pump

Gentlemen:

The enclosed proposed Technical Specification change requires that the turbine driven auxiliary feedwater pump be operable during plant operation. The turbine driven auxiliary feedwater pump is not required to protect the plant from postulated design basis accidents but it is capable of providing feedwater during certain nondesign basis, low probability events.

The specific change is as follows:

Replace pages 3.8-2 and 3.8-3 of the Maine Yankee Technical Specifications with the enclosed pages 3.8-2, 3.8-3 and 3.8-4.

This proposed change adds a restriction to the Technical Specifications. The change does not increase the probability or consequences of an accident previously analyzed. It does not involve the possibility of a new accident and it does not decrease margin to safety. Therefore, the change does not involve a significant hazards consideration.

This proposed change has been reviewed by the Plant Operation Review Committee and the Nuclear Safety Audit and Review Committee.

8509160259 850906
PDR ADDCK 05000309
P PDR

A001
1/1
Rec'd w/Chen 8/150.00
1798

United States Nuclear Regulatory Commission
Attention: Document Control Desk

Page Two
MN-85-160

A State of Maine representative is being notified of this requested change to the Technical Specifications by a copy of this letter.

A fee of one hundred and fifty dollars is enclosed.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

John B. Randazza
John B. Randazza
Executive Vice President

JBR/bjp

Enclosure:

cc: Mr. Edward J. Butcher, Jr.
Dr. Thomas E. Murley
Mr. Cornelius F. Holden
Mr. Clough Toppan

STATE OF MAINE)
)ss
COUNTY OF LINCOLN)

Then personally appeared before me, John B. Randazza, who being duly sworn did state that he is Executive Vice President of Maine Yankee Atomic Power Company, that he is duly authorized to execute and file the foregoing request in the name and on behalf of Maine Yankee Atomic Power Company, and that the statements therein are true to the best of his knowledge and belief.

Brenda F. Castonguay
Notary Public

BRENDA F. CASTONGUAY
NOTARY PUBLIC, MAINE
MY COMMISSION EXPIRES APRIL 21, 1990