



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SACRAMENTO MUNICIPAL UTILITY DISTRICT

DOCKET NO. 50-312

RANCHO SECO NUCLEAR GENERATING STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 75  
License No. DPR-54

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Sacramento Municipal Utility District (the licensee) dated October 29, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-54 is hereby amended to read as follows:


8509170382 850909  
PDR ADOCK 05000312  
P PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 75, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: September 9, 1985

ATTACHMENT TO LICENSE AMENDMENT NO.75

FACILITY OPERATING LICENSE NO. DPR-54

DOCKET NO. 50-312

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages as indicated. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

4-62  
6-12f

Insert

4-62  
6-12f

PANCHO SECO UNIT 1  
TECHNICAL SPECIFICATIONS

Surveillance Standards

- a. Once per 31 days by visual inspection of the station to assure all equipment is available at the station.
- b. Once per 18 months inspect and replace all gaskets in the couplings that are degraded, and remove the hose for inspection and re-racking.
- c. Once per three (3) years, partially open hose station valves to verify valve operability and no valve blockage.
- d. Once per three (3) years by removing and replacing all hose with new hose that meets or exceeds NFPA guidelines or recommendations.

4.18.6 Fire Barrier Penetrations

4.18.6.1 Each of the fire barrier penetrations specified in Section 3.14.6.1 shall be verified to be functional:

- a. At least once per 18 months by a visual inspection.
- b. Prior to returning a fire barrier penetration to functional status following repairs or maintenance by performance of a visual inspection of the affected fire barrier penetration(s).

RANCHO SECO UNIT 1  
TECHNICAL SPECIFICATIONS

Administrative Controls

Special Reports

6.9.5 Special reports shall be submitted to the Regional Administrator Region V Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification:

- A. A one-time only, "Narrative Summary of Operating Experience" will be submitted to cover the transition period (calendar year 1977).
- B. A Reactor Building structural integrity report shall be submitted within ninety (90) days of completion of each of the following tests covered by Technical Specification 4.4.2 (the integrated leak rate test is covered in Technical Specification 4.4.1.1).
  - 1. Annual Inspection
  - 2. Tendon Stress Surveillance
  - 3. End Anchorage Concrete Surveillance
  - 4. Liner Plate Surveillance
- C. Inservice Inspection Program
- D. Reserved for Proposed Amendment No. 43
- E. Status of Inoperable Fire Protection Equipment
- F. Inoperable Emergency Control Room/TSC Ventilation Room Filter System
- G. Radioactive Liquid Effluent Dose 30 days (3.17.2)
- H. Noble Gas Limits 30 days (3.18.2)
- I. Radioiodine and Particulates 30 days (3.18.3)
- J. Gaseous Radwaste Treatment 30 days (3.19)
- K. Radiological Monitoring Program 30 days (3.22)
- L. Monitoring Point Substitutions 30 days (3.22)
- M. Deleted
- N. Fuel Cycle Dose 30 days (3.25)
- O. Deleted