



John C. Brons
Senior Vice President
Nuclear Generation

June 18, 1985
JPN-85-50

U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Thomas E. Murley
Regional Administrator

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
NRC Bulletin 80-25
Operating Problems with Target Rock Safety Relief
Valves

- References: 1. PASNY letter, R. J. Pasternak to
B. H. Grier, dated March 19, 1981
(JAFP-81-0258).
2. NUREG/CR-3794, "Closeout of IE Bulletin 80-25:
Operating Problems with Target Rock Safety-
Relief Valves at Boiling Water Reactors," dated
January, 1985.

Dear Sir:

As a result of several malfunctions of Target Rock safety relief valves, IE Bulletin 80-25 was issued for action to all operating Boiling Water Reactor facilities. In Reference 1 the New York Power Authority responded to the Bulletin, and committed to modify the pneumatic supply system which actuates the safety relief valves. Upon evaluation of utility responses and Nuclear Regulatory Commission inspection reports, Reference 2 was issued. This document identified the Authority's commitment to modify the pneumatic supply as an open item. However, this modification, which provides additional over pressure protection and high and low pressure alarms, was completed during the 1981 refueling and maintenance outage.


We consider that the completion of this modification closes Bulletin 80-25 for the FitzPatrick plant.

8508260082 850618
PDR ADOCK 05000333
G PDR

IE 11/10

If you have any questions, please contact Mr. J. A. Gray, Jr.
of my staff.

Very truly yours,

A handwritten signature in cursive script, appearing to read "John C. Brons", with a small "for" written below it.

John C. Brons
Senior Vice President
Nuclear Generation

cc: Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, N.Y. 13093

Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing, USNRC
Washington, D.C. 20555