

Distribution: 4/7  
 Docket No. 50-320  
 NRC PDR  
 Local PDR  
 DCS  
 TMI HQ R/F  
 TMI Site R/F  
 BJSnyder  
 WDTTravers  
 TCPoindexter  
 MTMasnik  
 RAWeller  
 PGrant  
 RCook  
 CCowgill  
 LChandler, ELD  
 IE (3)  
 LSchneider  
 TBarnhart (4)  
 ACRS (16)  
 OPA  
 SECY  
 Eisenhut/Denton  
 RHartfield, MPA  
 M-town Office

July 8, 1985

Docket No. 50-320

Mr. F. R. Standerfer  
 Vice President/Director  
 Three Mile Island Unit 2  
 GPU Nuclear Corporation  
 P.O. Box 480  
 Middletown, PA 17057

Dear Mr. Standerfer:

Subject: Three Mile Island Nuclear Station, Unit 2  
 Operating License No. DPR-73  
 Docket No. 50-320  
 Amendment of Order for Containment  
 Isolation Valves

On October 31, 1984, you forwarded a letter to the NRC which stated that TMI-2 has certain containment penetration valve configurations that do not satisfy the requirements in the Proposed Technical Specifications, Section 1.7 issued in our July 17, 1984 Amendment of Order. In addition, the staff has learned that these same valve configurations do not meet the staff's Approval of Alternate Design for 10 CFR 50, Appendix A, Criteria 55 and 56, dated July 17, 1984. These penetrations, none the less, had been found acceptable by the staff at the time of initial licensing of TMI-2.

The NRC has therefore issued the enclosed Amendment of Order and attached safety evaluation which discusses the acceptability of your penetration valve configurations.

Since the February 11, 1980 Order imposing the PTS is currently pending before the Atomic Safety and Licensing Board, the staff will be advising the Licensing Board of this Amendment of Order through a Notice of Issuance of Amendment of Order and a Motion to Conform the Proposed Technical Specifications in Accordance Therewith.

8508270392 850708  
 PDR ADOCK 05000320  
 P PDR

*WD Paton concurrence  
 5-29-85 subject to  
 changes in attached  
 note to Tom Poinind stey  
 change 7/8/85  
 06/13/85*

\*See previous concurrence

OFFICE	TMIP0:NRR	SL:TMIP0:NRR	PD:TMIP0:NRR	ELD	DD:NRR	D:NRR	
SURNAME	TCPoindexter	bg* RAWeller*	BJSnyder*	LChandler*	DBEisenhut	RDenton	
DATE	4/11/85	4/15/85	4/16/85	5/10/85	6/1/85	7/8/85	

Mr. F. R. Standerfer

-2-

A Federal Register Notice for the subject issuance is enclosed. Copies of the related Safety Evaluation and a revised page for the PTS are also enclosed.

Sincerely,

Original signed by

B. J. Snyder

Bernard J. Snyder, Program Director  
Three Mile Island Program Office  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment of Order
2. Safety Evaluation
3. Proposed Technical Specification  
Page Changes
4. Federal Register Notices

cc: T. F. Demmitt  
R. E. Rogan  
S. Levin  
R. L. Freerman  
J. J. Byrne  
A. W. Miller  
Service Distribution List  
(see attached)

OFFICE							
SURNAME							
DATE							

Distribution:

Docket No. 50-320

Mr. F. R. Standerfer  
Vice President/Director  
Three Mile Island Unit 2  
GPU Nuclear Corporation  
P.O. Box 480  
Middletown, PA 17057

Dear Mr. Standerfer:

Subject: Three Mile Island Nuclear Station, Unit 2  
Operating License No. DPR-73  
Docket No. 50-320  
Amendment of Order For Containment  
Isolation Valves

On October 31, 1984, you forwarded a letter to the NRC which stated that TMI-2 has certain containment penetration valve configurations that do not satisfy the requirements in the Proposed Technical Specifications, Section 1.7 issued in our July 17, 1984 Amendment of Order. In addition, the staff has learned that these same valve configurations do not meet the staff's Approval of Alternate Design for 10 CFR 50, Appendix A, Criteria 55 and 56, dated July 17, 1984.

The NRC has issued the enclosed Amendment of Order and attached safety evaluation which discusses the acceptability of your penetration valve configurations.

Since the February 11, 1980 Order imposing the PTS is currently pending before the Atomic Safety and Licensing Board, the staff will be advising the Licensing Board of this Amendment of Order through a Notice of Issuance of Amendment of Order and a Motion to Conform the Proposed Technical Specifications in Accordance Therewith.

\*See Previous Concurrence

OFFICE	TMIPD:NRR	SL:TMIPD:NRR	PD:TMIPD:NRR	ELD:Patton	DD:NRR	D:NRR	
SURNAME	JCPaindexter	bg*RAWeller*	BJSnyder*	Chandler	EGEisenhut	HRDenton	
DATE	4/11/85	4/15/85	4/16/85	5/10/85	4/ /85	4/ /85	

*subject to deletion  
of Env. Agreement  
5/15/85*

Docket No. 50-320

Mr. F. R. Standerfer  
 Vice President/Director  
 Three Mile Island Unit 2  
 GPU Nuclear Corporation  
 P.O. Box 480  
 Middletown, PA 17057

Dear Mr. Standerfer:

Subject: Three Mile Island Nuclear Station, Unit 2  
 Operating License No. DPR-73  
 Docket No. 50-320  
 Amendment of Order for Containment  
 Isolation Valves

On October 31, 1984, you forwarded a letter to the NRC which stated that TH1-2 has certain containment penetration valve configurations that do not satisfy the requirements in the Proposed Technical Specifications, Section 1.7 issued in our July 17, 1984 Amendment of Order. In addition, the staff has learned that these same valve configurations do not meet the staff's Approval of Alternate Design for 10 CFR 50, Appendix A, Criteria 55 and 56, dated July 17, 1984.

Therefore, after reviewing the above documents and pursuant to the provisions of 10 CFR 2.204, the NRC has issued the enclosed Amendment of Order and attached safety evaluation which discusses the acceptability of your penetration valve configurations. You may demand a hearing with respect to all or any part of the Amendment within 20 days from the date of this letter. Otherwise, this Amendment of Order becomes effective at the end of the 20 day period.

Since the February 11, 1980 Order imposing the PTS is currently pending before the Atomic Safety and Licensing Board, the staff will be advising the Licensing Board of this Amendment of Order through a Notice of Issuance of Amendment of Order and a Motion to Conform the Proposed Technical Specifications in Accordance Therewith.

OFFICE	TMIPQ:NRR	SL:TMIPQ:NRR	PD:TMIPQ:NRR	ELD	DD:NRR	D:NRR
SURNAME	TCPO:Indexter	bg:Raweller	BJSnyder	LChandler	DGEisenhut	HRDenton
DATE	4/11/85	4/15/85	4/16/85	4/ /85	4/ /85	4/ /85

Mr. F. R. Standerfer

-2-

A Federal Register Notice for the subject issuance is enclosed. Copies of the related Safety Evaluation and a revised page for the PTS are also enclosed.

Sincerely,

Bernard J. Snyder, Program Director  
Three Mile Island Program Office  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment of Order
2. Safety Evaluation
3. Proposed Technical Specification  
Page Changes
4. Notice of Environmental Assessment  
and Finding of No Significant Impact
5. Federal Register Notices

cc: T. F. Demmitt  
R. E. Rogan  
S. Levin  
R. L. Freeman  
J. J. Byrne  
A. W. Miller

OFFICE							
SURNAME							
DATE							

# TMI-2 SERVICE LIST

Dr. Thomas Murley  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

John F. Wolfe, Esq., Chairman,  
Administrative Judge  
3409 Shepherd St.  
Chevy Chase, MD. 20015

Dr. Oscar H. Paris  
Administrative Judge  
Atomic Safety and Licensing  
Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dr. Frederick H. Shon  
Administrative Judge  
Atomic Safety and Licensing  
Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Karin W. Carter  
Assistant Attorney General  
505 Executive House  
P.O. Box 2357  
Harrisburg, PA 17120

Dr. Judith H. Johnsrud  
Environmental Coalition on  
Nuclear Power  
433 Orlando Ave.  
State College, PA 16801

George F. Trowbridge, Esq.  
Shaw, Pittman, Potts and  
Trowbridge  
1800 M. St., NW.  
Washington, D.C. 20036

Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Atomic Safety and Licensing Appeal Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Secretary  
U.S. Nuclear Regulatory Commission  
ATTN: Chief, Docketing & Service Branch  
Washington, D.C. 20555

Mr. Larry Hochendoner  
Dauphin County Commissioner  
P.O. Box 1295  
Harrisburg, PA 17108-1295

John E. Minnich, Chairperson,  
Dauphin County Board of Commissioners  
Dauphin County Courthouse  
Front and Market Streets  
Harrisburg, PA 17101

Dauphin County Office of Emergency  
Preparedness  
Court House, Room 7  
Front & Market Streets  
Harrisburg, PA 17101

U.S. Environmental Protection Agency  
Region III Office  
ATTN: EIS Coordinator  
Curtis Building (Sixth Floor)  
6th & Walnut Streets  
Philadelphia, PA 19106

Thomas M. Gerusky, Director  
Bureau of Radiation Protection  
Department of Environmental Resources  
P.O. Box 2063  
Harrisburg, PA 17120

Dan Kennedy  
Office of Environmental Planning  
Department of Environmental Resources  
P.O. Box 2063  
Harrisburg, PA 17120

Willis Bixby, Site Manager  
U.S. Department of Energy  
P.O. Box 88  
Middletown, PA 17057-0311

David J. McGoff  
Division of Three Mile Island Programs  
NE-23  
U.S. Department of Energy  
Washington, D.C. 20545

William Lochstet  
104 Davey Laboratory  
Pennsylvania State University  
University Park, PA 16802

Randy Myers, Editorial  
The Patriot  
812 Market St.  
Harrisburg, PA 17105

Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 220  
7910 Woodmont Ave.  
Bethesda, MD. 20814

Michael Churchill, Esq.  
PILCOP  
1315 Walnut St., Suite 1632  
Philadelphia, PA 19107

Linda W. Little  
5000 Hermitage DR.  
Raleigh, NC 27612

Marvin I. Lewis  
6504 Bradford Terrace  
Philadelphia, PA 19149

Jane Lee  
183 Valley Rd.  
Etters, PA 17319

J.B. Liberman, Esquire  
Berlack, Isaacs, Liberman  
26 Broadway  
New York, NY 10004

Walter W. Cohen, Consumer Advocate  
Department of Justice  
Strawberry Square, 14th Floor  
Harrisburg, PA 17127

Edward O. Swartz  
Board of Supervisors  
Londonderry Township  
RFD #1 Geyers Church Rd.  
Middletown, PA 17057

Robert L. Knupp, Esquire  
Assistant Solicitor  
Knupp and Andrews  
P.O. Box P  
407 N. Front St.  
Harrisburg, PA 17108

John Levin, Esquire  
Pennsylvania Public Utilities Comm.  
P.O. Box 3265  
Harrisburg, PA 17120

Honorable Mark Cohen  
512 E-E Main Capital Building  
Harrisburg, PA 17120

Mr. Edwin Kintner  
Executive Vice President  
General Public Utilities Nuclear Corp.  
100 Interpace Parkway  
Parsippany, NJ 07054

Ad Crable  
Lancaster New Era  
8 West King Street  
Lancaster, PA 17602