



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT TEXAS 77704

AREA CODE 409 838-6631

August 26, 1985
RBG-21861
File Code: G9.5,
G9.20.8

Mr. Harold R. Denton, Director
Office of Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station-Unit 1
Docket No. 50-458

This response provides the status of Gulf States Utilities Company's justification for interim operation (JIO) on Rosemount, Inc. pressure transmitters (Model No. 1152PXX22T0280PB). The environmental qualification of the pressure transmitters (previously submitted under 10CFR50.49(i)) has been successfully completed. The attached table is an update reflecting the qualification of the transmitters. Your office will be informed as the remaining JIC's for environmental qualification have been completed.

Sincerely,

J.E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/WJR/RGK/ko

8508280213 850826
PDR ADOCK 05000458
A PDR

Adas

ATTACHMENT

RBS
ENVIRONMENTAL QUALIFICATION
SUMMARY LISTING OF
JUSTIFICATIONS FOR INTERIM OPERATION (JIO)

<u>SRN No.</u>	<u>Rev. No.</u>	<u>Description</u>	<u>Schedule Completion</u>	<u>Required Shutdown</u>
211161-6	0	Cable Repair Kits	September 1985	N/A
211161-8	1	Raychem Heat-Shrink	September 1985	N/A
211161-10	1	Heat Tracing	November 1985	N/A
225220-1	0	Standby Gas Treatment	September 1985	N/A
241242-1	1	Rockbestos Cable	November 1985	N/A
242533-1	0	Load Centers	November 1985	N/A
242562-1	0	Motor Control Centers	November 1985	N/A
247250-1	1	Digital Radiation Monitoring	October 1985	N/A
247433-1	4	Flow Detecting Elements	August 1985	N/A
247497-1	1	Electrohydraulic Actuators	November 1985	N/A
CO1	0	Rosemount Transmitters	Completed (1)	No
247491-3	0	Air Operated Valves	November 1985	No

Notes:

N/A - No new equipment is required to be installed to replace existing equipment (Not Applicable).

(1) - Qualification is complete. The qualification reports have been reviewed for the RBS specific application and were found acceptable. The qualification documentation is available for review.