



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 27, 1985

Docket No. 99900900/85-02

Westinghouse Electric Corporation
Nuclear Technology Division
ATTN: Mr. J. L. Gallagher
General Manager
Post Office Box 355
Pittsburgh, Pennsylvania 15230-0355

Gentlemen:

This refers to the inspection conducted by Mr. S. D. Alexander of this office on September 16-17, 1985, of your facility at Forest Hills, Pennsylvania and to the discussions of our findings with Mr. John Martin and other members of your staff at the conclusion of the inspection.

The purpose of this inspection was to observe high energy line break testing on a 600 HP pump motor and to review the status of your actions in response to our concerns raised in the previous inspection. Areas examined during the inspection and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During this inspection, we found the testing observed to be in compliance with the test plan and procedures and with regulatory requirements. Deviations noted and anomalies observed were documented and justified, and the test article appeared to function within test requirements during the period observed.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public-Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Gary G. Zech, Chief
Vendor Program Branch
Division of Quality Assurance, Vendor,
and Technical Training Center Programs
Office of Inspection and Enforcement

8512020359 851127
PDR GA999 EMVWEST
99900900 PDR

Enclosures:
See next page

IED9
1/1

November 27, 1985

Westinghouse Electric
Corporation

- 2 -

Enclosures:

1. Appendix A-Inspection Report 99900900/85-02
2. Appendix B-Inspection Data Sheets (6 pages)

November 27, 1985

Westinghouse Electric
Corporation

- 2 -

Enclosures:

1. Appendix A-Inspection Report 99900900/85-02
2. Appendix B-Inspection Data Sheets (6 pages)

DISTRIBUTION:

DMB:IE:09

VPB Reading

DQAVT Reading

RVollmer

JTCollins


JStone


GHolahan, NRR/ORAB


UPotapovs


SAlexander

Region I


VPB:DQAVT
SAlexander
11/25/85


SC/VPB:DQAVT
UPotapovs
11/25/85


BC/VPB:DQAVT
GGZech
11/26/85


DIR:DQAVT
BGrimes
11/26/85