

December 23, 1985

Docket No.: 50-423

Mr. J. F. Opeka
Senior Vice President
Nuclear Engineering and Operations
Northern Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

Subject: Millstone Nuclear Power Station, Unit No. 3 Technical Specifications

On November 25, 1985, the Commission issued Facility Operating License NPF-44 together with Technical Specifications (NUREG-1161) and an Environmental Protection Plan for the Millstone Nuclear Power Station Unit 3. Page 3/4 3-59 of NUREG-1161 contained an error. Please replace this page with the page enclosed.

We regret any inconvenience this may have caused you.

Sincerely,

ORIGINAL SIGNED BY

Vincent Noonan, Director
PWR Project Directorate No. 5
Division of PWR Licensing-A

Enclosure:
TS Page 3/4 3-59

cc: See next page

Handwritten: CMT 12/23/85
VNoonan/yt
12/23/85
PAD5
MRushbrook
12/23/85

Handwritten: DIR:PAD5
VNoonan
12/23/85

8601210535 851223
PDR ADOCK 05000423
P PDR

Mr. J. F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit No. 3

cc:
Gerald Garfield, Esq.
Day, Berry & Howard
City Place
Hartford, Connecticut 06103-3499

Ms. Jane Spector
Federal Energy Regulatory Commission
825 N. Capitol Street, NE
Room 8608C
Washington, D.C. 20426

Mr. Maurice R. Scully, Executive
Director
Connecticut Municipal Electric
Energy Cooperative
268 Thomas Road
Groton, Connecticut 06340

Mr. Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06115

Robert W. Bishop, Esq.
Corporate Secretary
Northeast Utilities
Post Office Box 270
Hartford, Connecticut 06141

Mr. T. Rebelowski
Senior Resident Inspector Office
U. S. Nuclear Regulatory Commission
Millstone III
P. O. Box 615
Waterford, Connecticut 06385

Mr. Michael L. Jones, Manager
Project Management Department
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Regional Administrator
U. S. NRC, Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Karl Abraham
Public Affairs Office, Region I
U. S. Nuclear Regulatory Commission,
King of Prussia, Pennsylvania 19406

INSTRUMENTATION

ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.6 The accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With the number of OPERABLE accident monitoring instrumentation channels except the containment area high range radiation monitor, less than the Total Number of Channels shown in Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 7 days, or be in at least HOT STANDBY within the next 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- b. With the number of OPERABLE accident monitoring instrumentation channels except the containment area-high range radiation monitor, less than the Minimum Channels OPERABLE requirements of Table 3.3-10, restore the inoperable channel(s) to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- c. With the number of OPERABLE channels for the containment area-high range radiation monitor less than required by either the total or the Minimum Channels OPERABLE requirements, initiate an alternate method of monitoring the appropriate parameter(s), within 72 hours, and either restore the inoperable channel(s) to OPERABLE status within 7 days or prepare and submit a Special Report to the Commission, pursuant to Specification 6.9.2, within 14 days that provides actions taken, cause of the inoperability, and the plans and schedule for restoring the channels to OPERABLE status.
- d. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.6 Each accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION at the frequencies shown in Table 4.3-7.

Correction Letter dated
December 23, 1985

DISTRIBUTION

Docket File 50-423

NRC PDR
Local PDR
PAD5 Reading
HThompson
VNoonan
MRushbrook
VNerses
BDoolittle
Attorney, ELD
LHarmon
EJordan
BGrimes
JPartlow
TBarnhart (4)
WJones
VBenaroya
ACRS (10)
OPA
LFMB
FRosa