



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, P.O. Box 15830, Sacramento, CA 95813; (916) 452-3211
RJR 85-565 AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

November 27, 1985

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTN HUGH L THOMPSON JR
DIVISION OF LICENSING
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
RANCHO SECO NUCLEAR GENERATING STATION
UNIT NO. 1
GENERIC LETTER 81-21, NATURAL CIRCULATION COOLDOWN

By letter dated September 19, 1985 (RJR 85-343, Mr. R. J. Rodriguez to Mr. H. L. Thompson), the District provided its response to Generic Letter 81-21. The submittal included a topical report on the GPU Nuclear approach for natural circulation cooldown and Rancho Seco specific notes.

The attached addendum to the Rancho Seco notes on Topical Report 017 addresses two sections of the report which were inadvertently omitted in the September 19, 1985 submittal.

If you have any questions, please contact Robert Little at (916) 732-6021.

William K. Latham

WILLIAM K. LATHAM
ACTING GENERAL MANAGER

Attachment

8512030285 851127
PDR ADOCK 05000312
P PDR

A052
11

ADDENDUM TO

RANCHO SECO NOTES ON TOPICAL REPORT 017

5.0 OPERATIONAL GUIDELINES

This section of Topical Report 017 is valid for Rancho Seco.

6.0 CONCLUSIONS

This section of Topical Report 017 is valid for Rancho Seco with the exception that the Rancho Seco DHR cut in conditions are 250 psig and 280°F. To prevent coolant flashing in the RV head during RCS cooldowns, the head will be required to be cooled for at least 24 and 7 hours respectively.