



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, P.O. Box 15830, Sacramento, CA 95813; (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RJR 85-554

November 25, 1985

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTN: HUGH L. THOMPSON, JR., DIRECTOR
DIVISION OF LICENSING
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555

DOCKET NO. 50-312
LICENSE NO. DPR-54
PROPOSED AMENDMENT 122, REVISION 2

In accordance with 10 CFR 50.59, the Sacramento Municipal Utility District hereby proposes to amend its Operating License DPR-54 for Rancho Seco Nuclear Generating Station No. 1. Per the requirements of 10 CFR 50.92, this Proposed Amendment 122, Revision 2, has been evaluated by a No Significant Hazards consideration in Attachment I.

This proposal addresses minor editorial changes to Revision 1 of Proposed Amendment No. 122.

Attachment II to this submittal is a description of the proposed changes for Amendment No. 122, Revision 2. Pursuant to 10 CFR 50.91 (a) of the regulation, we have provided a copy of this letter, the proposed change in Technical Specifications, and our analyses of significant hazards considerations to Joseph Ward, the designated representative of the State of California.

8512030488 851125
PDR ADDCK 05000312
P PDR

A001
11

November 25, 1985

Since this is a revision to Proposed Amendment No. 122, no additional license fees are required.

If you have any questions concerning this proposal, please contact Mr. Ron W. Colombo at Rancho Seco Nuclear Generating Station.

William K. Latham


WILLIAM K. LATHAM
ACTING GENERAL MANAGER

Enclosures 3

Subscribed and sworn to before me
this 25th day of November, 1985

Patricia K. Geisler

Notary Public



Attachment I

Safety Analysis

Rancho Seco Technical Specifications have recently undergone many changes in the steam generator area. Amendment No. 66 added surveillance requirements for certain special interest steam generator tubes and visual inspections of the internal auxiliary feedwater flow distributor, attachment welds and thermal sleeves. Amendment No. 76 revised Technical Specifications governing the inservice inspection of steam generator tubes to reflect OTSG operational experience. Proposed Amendment No. 122 has further revised OTSG Technical Specifications by creating 100% inspection requirements for specific limited areas which are distinguished by unique operating conditions and/or physical construction. The proposed addition of these two tables (Tables 4.17-3 and 4.17-4) has necessitated that OTSG Auxiliary Feedwater Header Surveillance Requirements that were added as Table 4.17-3 in Amendment No. 66 be moved to Table 4.17-5. The other proposed change contained in this submittal refers to steam generator tubing inservice inspection results that fall into category C-3. 10 CFR 50.72 requires a four-hour report whenever a principal safety barrier has been found seriously degraded. Category C-3 is considered to be such a condition. This statement has been added to Section 4.17 to make this requirement more visible.

No Significant Hazards Considerations

This revision to Proposed Amendment No. 122 contains minor changes that are editorial in nature. One change entails moving OTSG Auxiliary Feedwater Header Surveillance requirements to another table. The other change calls out specific requirements of 10 CFR 50.72 in Section 4.17 of Technical Specifications. Therefore, operation of Rancho Seco in accordance with this Proposed Amendment:

- 1) does not involve a significant increase in the probability or consequences of an accident previously evaluated,
- 2) does not create the possibility of a new or different kind of accident from any accident previously evaluated, and
- 3) does not involve a significant reduction in a margin of safety.

Therefore, significant safety hazards are not associated with this Proposed Amendment.

Attachment II

Description of Proposed Changes

- 1) Page ix, List of Tables, Table 4.17-5; OTSG Auxiliary Feedwater Header Surveillance Requirements have been moved from Table 4.17-3.
- 2) Page 4-55, Specification 4.17-5c; Category C-3 steam generator inspection results require notification of the Commission within 4 hours and shall be reported pursuant to Specification 6.9.5P.
- 3) Page 4-55a, Fourth Paragraph of the Bases; Category C-3 steam generator inspection reporting requirements have been revised.
- 4) Page 4.-57, Table 4.17-2A; Category C-3 steam generator inspection reporting requirements have been revised.
- 5) Page 4.57a, Table 4.17-2B; Category C-3 steam generator inspection reporting requirements have been revised.
- 6) Pages 4.57g and 4-57h, Table 4.17-5; OTSG Auxiliary Feedwater Header Surveillance information was formerly contained in Table 4.17-3.