

DISTRIBUTION:

DN 50-320
NRC PDR
Local PDR
DCS
TMI HQ r/f
TMI Site r/f
BJSnyder
WDTravers
MTMasnik
RAWeller
PGrant
RCook
CCowgill
LChandler
IE (3)
ACRS
M-Town Office
Service List

September 12, 1985
NRC/TMI 85-071

Docket No. 50-320

GPU Nuclear Corporation
ATTN: Mr. F. R. Standerfer
Vice President/Director, TMI-2
P. O. Box 480
Middletown, PA 17057

Dear Sir:

Subject: General Project Design Criteria (GPDC)

Reference: Letter from F. R. Standerfer to B. J. Snyder, 4410-85-L-0159,
dated August 2, 1985

The referenced letter with attached GPDC addresses NRC comments in our letter of December 11, 1984. We believe that the clarification in the current revision (revision 6) of the GPDC has essentially resolved the NRC comments in our previous letter.

We find your definition in section 2.5 acceptable for identifying safety related systems. We agree that safety related systems should be designed to remain functional through the events listed in sections 3.2.4 and 3.2.5. It is currently implied but should be explicitly stated that they are also required to remain functional through environmental conditions generated by or occurring during an accident.


Sincerely,

ORIGINAL SIGNED BY:
William D. Travers

William D. Travers
Deputy Program Director
TMI Program Office

cc: T. F. Demmitt
R. E. Rogan
S. Levin
W. H. Linton
J. J. Byrne
A. W. Miller
Service Distribution List
(see attached)

8509180500 850912
PDR ADOCK 05000320
P PDR

OFFICE	TMIPD		TMIPD				
SURNAME	LHThonus:wa	PGrant	WDTravers				
DATE	9/12/85	9/12/85	9/12/85				