



Carolina Power & Light Company

15 JAN 27 P 3: 05
P. O. Box 165, New Hill, North Carolina 27562
January 17, 1986

FILE: SH N-2/18
Item 224

MQAH 86-18

Dr. J. N. Grace
US Nuclear Regulatory Commission
Region II
Suite 2900
101 Marietta Sreet, NW
Atlanta, Georgia 30323

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400
RAYCHEM HEAT SHRINKABLE TUBING

Dear Dr. Grace:


This is to confirm the January 17, 1986 telephone conversation between Mr. N. J. Chiangi (CP&L) and Mr. V. Brownlee. Mr. Brownlee was informed that the December 20, 1985 potentially reportable item, pertaining to the use of Raychem heat shrinkable tubing in applications exceeding manufacturer's recommendations, has been evaluated and is considered not to be reportable per the provisions of 10CFR50.55(e).

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. G. Maxwell
Mr. J. M. Taylor


N. J. Chiangi - Manager
Quality Assurance/Quality Control
Harris Plant

8602030262 B60117
PDR ADOCK 05000400
S PDR

10
1827