



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

NOV 21 1985

Docket No. 50-354

Mr. R. L. Mittl, General Manager  
Nuclear Assurance and Regulation  
Public Service Electric & Gas Company  
P.O. Box 570, T22A  
Newark, New Jersey 07101

Dear Mr. Mittl:

SUBJECT: REPLACEMENT SERVICE WATER SPRAY WATER PUMPS

We have completed our review of the Public Service Electric and Gas Company (PSE&G) request dated October 10, 1985 with respect to a replacement Service Water Spray Water Pump for Hope Creek.

The Service Water Spray Water Pump was originally procured from Haywood Tyler and was constructed to Section III, Class 3, of the ASME Boiler and Pressure Vessel Code including an "N" stamp. The replacement Service Water Spray Water Pump will also be procured from Haywood Tyler and constructed to Section III, Class 3, of the Code but without the "N" Stamp as their ASME Code Authorization and N-Type Stamp was revoked due to relocation of the plant. In order to have the "N" Stamp reinstated, Haywood Tyler is scheduled to be resurveyed in February 1986 by an Authorized Inspection Agency (AIA). If the results of the AIA resurvey are satisfactory, Haywood Tyler may again construct these pumps in accordance with the Code including the "N" Stamp.


The replacement Service Water Spray Water Pump would be procured to meet all the requirements of Section III, Class 3, of the ASME Code including all appropriate quality assurance requirements, with the exception of the "N" Stamp. The quality assurance requirements will be in compliance with 10CFR Part 50, Appendix B. In addition, PSE&G will perform an appropriate vendor survey and provide an ASME type certification document certifying compliance with all other related Section III requirements.

We find that the replacement Service Water Spray Water Pump without the "N" Stamp is acceptable provided the AIA resurvey of the Haywood Tyler facility is acceptable and the ASME Code Authorization and "N" Stamp is reinstated. This approval is also contingent on the PSE&G commitment to provide an ASME type certification document certifying compliance with all other related Section III requirements. In all other respects, the replacement Service Water Spray Water Pump shall be in conformance with Section III, Class 3, of the ASME Boiler and Pressure Vessel Code.

8512040185 851121  
PDR ADOCK 05000354  
A PDR

Please keep us informed with respect to the results of the AIA resurvey of the Haywood Tyler facility. In the event the ASME Code Authorization and "N" Stamp are not reinstated, we will require further discussion with PSE&G to determine the adequacy of the replacement Service Water Spray Water Pumps.

Sincerely,

A handwritten signature in cursive script that reads "Walter R. Butler".

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

Please keep us informed with respect to the results of the AIA resurvey of the Haywood Tyler facility. In the event the ASME Code Authorization and "N" Stamp are not reinstated, we will require further discussion with PSE&G to determine the adequacy of the replacement Service Water Spray Water Pumps.

Sincerely,

Original Signed by

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

DISTRIBUTION

Docket File  
NRC PDR  
PRC System  
Local PDR  
NSIC  
LB#2 Reading  
Ehlyton  
DWagner  
Dewey, OELD  
ACRS (16)  
JPartlow  
BGrimes  
EJordan  
RKirkwood

*lw*  
LB#2/DL/PM  
DWagner:lb  
11/21/85

*WB*  
LB#2/DL/BC  
WButler  
11/29/85

Please keep us informed with respect to the results of the AIA resurvey of the Haywood Tyler facility. In the event the ASME Code Authorization and "N" Stamp are not reinstated, we will require further discussion with PSE&C to determine the adequacy of the replacement Service Water Spray Water Pumps.

Sincerely,

Original Signed by

Walter R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

DISTRIBUTION

Docket File  
NRC PDR  
PRC System  
Local PDR  
NSIC  
LB#2 Reading  
EHylton  
DWagner  
Dewey, OELD  
ACRS (16)  
JPartlow  
BGrimes  
EJordan  
RKirkwood

LB#2/DL/PM  
DWagner:lb  
11/21/85

LB#2/DL/BC  
WButler  
11/29/85

WB

Mr. R. L. Mittl  
Public Service Electric & Gas Co.

Hope Creek Generating Station

cc:

Gregory Minor  
Richard Hubbard  
Dale Bridenbaugh  
MHB Technical Associates  
1723 Hamilton Avenue, Suite K  
San Jose, California 95125

Susan C. Remis  
Division of Public Interest Advocacy  
New Jersey State Department of  
the Public Advocate  
Richard J. Hughes Justice Complex  
CN-850  
Trenton, New Jersey 08625

Troy B. Conner, Jr. Esquire  
Conner & Wetterhahn  
1747 Pennsylvania Avenue N.W.  
Washington, D.C. 20006

Office of Legal Counsel  
Department of Natural Resources  
and Environmental Control  
89 Kings Highway  
P.O. Box 1401  
Dover, Delaware 19903

Richard Fryling, Jr., Esquire  
Associate General Solicitor  
Public Service Electric & Gas Company  
P. O. Box 570 TSE  
Newark, New Jersey 07101

Mr. K. W. Burrowes, Project Engineer  
Bechtel Power Corporation  
50 Beale Street  
P. O. Box 3965  
San Francisco, California 94119

Resident Inspector  
U.S.N.R.C.  
P. O. Box 241  
Hancocks Bridge, New Jersey 08038

Mr. J. M. Ashley  
Senior Licensing Engineer  
c/o Public Service Electric & Gas Co.  
Bethesda Office Center, Suit 550  
4520 East-West Highway  
Bethesda, Maryland 20814

Richard F. Engel  
Deputy Attorney General  
Division of Law  
Environmental Protection Section  
Richard J. Hughes Justice Complex  
CN-112P  
Trenton, New Jersey 08625

Mr. A. E. Giardino  
Manager - Quality Assurance E&C  
Public Service Electric & Gas Co.  
P. O. Box A  
Hancocks Bridge, New Jersey 08038

Mr. Robert J. Touhey,  
Acting Director  
DNREC - Division of  
Environmental Control  
89 Kings Highway  
P. O. Box 1401  
Dover, Delaware 19903

Mr. Anthony J. Pietrofitta  
General Manager  
Power Production Engineering  
Atlantic Electric  
1199 Black Horse Pike  
Pleasantville, New Jersey 08232

Mr. R. S. Salvesen  
General Manager-Hope Creek Operation  
Public Service Electric & Gas Co.  
P.O. Box A  
Hancocks Bridge, New Jersey 08038

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Public Service Electric & Gas Co. - 2 -

Hope Creek Generating Station

cc:

Mr. B. A. Preston  
Public Service Electric & Gas Co.  
Hope Creek Site MC12Y  
Licensing Trailer 12L1  
Foot of Button wood Road  
Hancock's Bridge, New Jersey 08038

Ms. Rebecca Green  
New Jersey Bureau of Radiation  
Protection  
380 Scotch Road  
Trenton, New Jersey 08628