



Wayne D. Romberg
Assistant Vice President
and Manager, Technical

Fermi 2
1400 North Dixie Hwy
Newport, Michigan 48166
(313) 586-1844



10CFR50.73

April 3, 1997
NRC-97-0040

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Reference: Fermi 2
Docket No. 50-341
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 97-004

Pursuant to 10CFR50.73(a)(2)(ii)(B), Detroit Edison is submitting the enclosed LER No. 97-004 regarding the calibration of the Primary Containment oxygen monitor. If the monitor is calibrated while the Primary Containment is in a de-inerted environment, the monitor cannot be considered operable after the Primary Containment is inerted.

The following commitment is being made in this LER:

The oxygen sensor calibration procedures and channel checks will be revised prior to startup from the current outage based on the trouble shooting and data-gathering results to ensure proper calibration of the oxygen sensor.

If you have any questions, please contact Mari Jaworsky, Compliance Engineer, at (313) 586-1427.

9704090045 970403
PDR ADOCK 05000341
S PDR

Sincerely,

Wayne D. Romberg

1/1
Terz

cc: A. B. Beach
G. A. Harris
M. J. Jordan
A. J. Kugler
M. V. Yudaszy, Jr.
Region III

