

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

January 14, 1986

RECEIVED
JAN 17 1986
TELEPHONE
(415) 368-6241

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - December 1985
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated December 12, 1985

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in December 1985.

Fire doors found inoperable during the December routine surveillances are identified in the Attachment and include 8 latching mechanism failures and 7 closure mechanism failures. No doors were found blocked open in December. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. We are continuing previously reported corrective actions to upgrade door latches and closure mechanisms.

8602040273 860114
PDR ADOCK 05000361
S PDR

IE-01


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in January 1986 will be submitted by February 18, 1986.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in dark ink, appearing to read "H. E. Morgan", with a long horizontal flourish extending to the right.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF DECEMBER 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 8, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-301	10/24/85	---
AR-401	11/20/85	12/16/85
FH3-103	11/24/85	12/07/85
AC-416	11/28/85	---
FH3-304	12/07/85	12/12/85
AC-339	12/07/85	12/19/85
AC-114	12/09/85	---
AC-417	12/10/85	12/12/85

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF DECEMBER 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 7, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-417	12/06/85	12/12/85
FH3-304	12/10/85	12/12/85
AR-502	12/12/85	---
FH3-304	12/14/85	12/19/85
AC-442	12/26/85	---
FH3-304	12/26/85	12/27/85
AC-459	12/28/85	---

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF DECEMBER 1985
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

III. Doors Blocked Open:

Number of doors blocked open - None