

922

RELATED CORRESPONDENCE



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 30, 1986



Dr. Robert M. Lazo, Chairman
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. Richard F. Cole
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. Emmeth A. Luebke
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

In the Matter of
FLORIDA POWER AND LIGHT COMPANY
(Turkey Point Plant, Unit Nos. 3 and 4)
Docket Nos. 50-250, 50-251 OLA-2
SFP Expansion

Dear Administrative Judges:

In a letter dated December 26, 1985 regarding its inservice test program, Licensee informed the NRC that the upgrade of the spent fuel pool cooling system, a Licensee commitment noted in the NRC's Safety Evaluation in support of the spent fuel pool expansion amendments, will be completed by the end of the Unit 3 Cycle 11 and Unit 4 Cycle 12 refueling outages. A copy of the letter was distributed to the Board and parties by letter of Licensee Counsel, Steven P. Frantz, dated January 3, 1986. Enclosed is a copy of a letter from Daniel McDonald, NRC, to Licensee, dated January 23, 1986, which states that the schedule for the completion of the upgrade is consistent with Section 2.7 of the November 21, 1984 safety evaluation.

Copies of the enclosed letter are being sent to the parties to this proceeding by means of this letter.

Sincerely,

8602040306 860130
PDR ADOCK 05000250
G PDR

Mitzi A. Young
Mitzi A. Young
Counsel for NRC Staff

Enclosure: As stated

cc w/encl: Joette Lorion
Michael Bauser
Norman Coll

cc w/o encl: Remainder of Service List

DS07



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 23, 1986

Docket Nos. 50-250
and 50-251

Mr. C. O. Woody
Group Vice President
Nuclear Energy Department
Florida Power and Light
Post Office Box 14000
Juno Beach, Florida 33408

Dear Mr. Woody:

Reference: TAC Numbers 60413 and 60414

Subject: Revision to Inservice Test Programs for Pumps and Valves

By letter dated December 26, 1985, you requested relief from the Inservice Test (IST) requirements related to the spent fuel pool (SFP) cooling pumps. However, subsequent to the inclusion of the SFP cooling pumps in the proposed IST program submitted by letter dated October 24, 1985, you have committed to upgrade the Unit 3 and 4 SFP cooling systems as documented in Section 2.7 of the NRC's Safety Evaluation (SE) in support of the SFP expansion dated November 21, 1984.

Section 2.7 of the SE indicates that the upgrade will be completed by the end of the second refueling outage after issuance of the approval for re-racking the SFP's. Your December 26, 1985 letter, indicated the SFP cooling system upgrade will be completed by the end of Cycle 11 Unit 3 and Cycle 12 Unit 4 refueling outages. These outages are the second refueling outages after issuance of approval for the re-racking of the SFP's. Therefore, your request is consistent with Section 2.7 of the NRC's SE in support of the SFP re-rack.


The staff will review your relief request on a schedule consistent with the review of your proposed IST Program for Pumps and Valves as documented in your October 24, 1984 request.

Mr. C. O. Woody

- 2 -

If you have any questions concerning this action of schedule, please contact me.

Sincerely,

A handwritten signature in cursive script, appearing to read "Daniel G. McDonald".

Daniel G. McDonald, Project Manager
PWR Project Directorate #2
Division of PWR Licensing-A
Office of Nuclear Reactor Regulation

cc: See next page

Mr. C. O. Woody
Florida Power and Light Company

Turkey Point Plant

cc:

Harold F. Reis, Esquire
Newman and Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Norman A. Coll, Esquire
Steel, Hector and Davis
4000 Southeast Financial
Center
Miami, Florida 33131-2398

Mr. C. M. Wethy, Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

Mr. M. R. Stierheim
County Manager of Metropolitan
Dade County
Miami, Florida 33130

Resident Inspector
U.S. Nuclear Regulatory Commission
Turkey Point Nuclear Generating Station
Post Office Box 57-1185
Miami, Florida 33257-1185

Mr. Allan Schubert, Manager
Public Health Physicist
Department of Health and
Rehabilitative Services
1323 Winewood Blvd.
Tallahassee, Florida 32301

Intergovernmental Coordination
and Review
Office of Planning & Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Room 2900
101 Marietta Street
Atlanta, Georgia 30323

Martin H. Hodder, Esquire
1131 NE, 86th Street
Miami, Florida 33138

Joette Lorian
7269 SW, 54 Avenue
Miami, Florida 33143

Mr. Chris J. Baker, Plant Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
P.O. Box 029100
Miami, Florida 33102

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304