

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

September 16, 1985

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370
Extension of Allowed Outage Time for VA System

Dear Sir:


Attached are proposed license amendments to facility operating licenses NPF-9 and NPF-17 for McGuire Nuclear Station Units 1 and 2, respectively. The proposed amendments would increase the time allowed to restore an inoperable auxiliary building filtered ventilation exhaust (VA) system train to operable status to 7 days.

Attachment 1 contains the proposed Technical Specification changes. Attachment 2 discusses the Justification and Safety Analysis to support the proposed changes (included in attachment 2 as attachment 2A is a detailed description of the VA system, along with 9 "as built" drawings (enclosed) with appropriate sections of the VA system highlighted). Pursuant to 10 CFR 50.91, Attachment 3 provides an analysis performed in accordance with the standards contained in 10 CFR 50.92 which concludes that the proposed amendments do not involve a significant hazards consideration. The proposed amendments have been reviewed and have been determined to have no adverse safety or environmental impact.

Pursuant to 10 CFR 170.3(y), 170.12(c), and 170.21, Duke Power proposes that this application contains license amendments for McGuire Units 1 and 2 subject to fees based on the full cost of the review (to be calculated using the applicable professional staff rates shown in 10 CFR 170.20) and must be accompanied by an application fee of \$150, with the NRC to bill Duke Power at six-month intervals for all accumulated costs for the application or when review is completed, whichever is earlier. Accordingly, please find enclosed a check in the amount of \$150.00.

Should there be any questions or if additional information is required, please advise.

Very truly yours,



Hal B. Tucker

PBN/VMK/hrp

Attachments/Enclosures

8509190467 850916
PDR ADOCK 05000369
P PDR

Rec'd w/ check \$150.00
#18198925

Mr. Harold R. Denton, Director
September 16, 1985
Page 2


cc: w/attachments only
Mr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Dayne Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P. O. Box 12200
Raleigh, North Carolina 27605

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station


Mr. Harold R. Denton, Director
Septmeber 16, 1985
Page 4

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station License Nos. NPF-9 and NPF-17 and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 16th day of September, 1985.



Notary Public

My Commission Expires:

Sept. 20, 1989

ATTACHMENT 1

Proposed McGuire Unit 1 and 2 Technical Specification Changes