

Public Service
Electric and Gas
Company

Corbin A. McNeill, Jr.
Vice President -
Nuclear

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609 339-4800

January 28, 1986

U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Washington, DC 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Gentlemen:

PUMP AND VALVE TEST PROGRAM
UNIT NO. 2
DOCKET NO. 50-311
SALEM GENERATING STATION

Pursuant to the guidance provided in your letter dated April 12, 1983, we have amended our Pump and Valve In-Service Test (IST) Program to include Fire Protection and Emergency Diesel Generator Auxiliary Systems.

We have also made several changes to the Program based on NRC approved testing requirements of ASME Section XI, 1980 Edition and Addenda through the Winter of 1980. These changes, for which we have previously requested relief for Salem Unit No. 1 from the 1974 Edition and Summer of 1975 Addenda of ASME Section XI, are as follows:

- a. The pump testing interval (subsection IWP) was increased from every thirty (30) days to every ninety (90) days.
- b. The Category "E" valves (subsection IWV) testing requirements were removed from the IST Program.

Attachment 1 is a resubmittal of our IST Program superseding, in its entirety, our last IST Program submittal dated February 2, 1981 and incorporating the above modifications as well as the following general changes:

8602050299 860128
PDR ADOCK 05000311
P PDR

*A-047
1/40*
*Add: Ballard Ltr Encl
1 1*


Mr. Steven A. Varga

-2-

- a. Revised the key testing requirements (Part 2, Item 2).
- b. Added valves due to Plant Modifications.
- c. Added valves identified in our total program review.
- d. Revised the valve location coordinates to correspond to new P&ID revisions.
- e. Added a remote position indicator verification test requirement.
- f. Added valves and changed valve categories in accordance with PSE&G Nuclear Engineering Department Directives.

Should you have any questions, we will be pleased to discuss them with you.

Sincerely,

A handwritten signature in dark ink, appearing to read "Cameron", followed by a long, sweeping horizontal line that extends to the right.

Attachment

C Mr. Samuel J. Collins, Chief
Projects Branch #2, DPRP
Region I

Mr. Donald C. Fischer
Licensing Project Manager

Mr. Thomas J. Kenny
Senior Resident Inspector