

10CFR50.90



PECO NUCLEAR

A Unit of PECO Energy

PECO Energy Company
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

March 31, 1997

Docket Nos. 50-277
50-278

License Nos. DPR-44
DPR-56

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station, Units 2 and 3
License Change Request ECR 96-00627

Dear Sir:

PECO Energy Company hereby submits License Change Request ECR 96-00627 in accordance with 10CFR50.90 requesting changes to Appendix A of the Peach Bottom Facility Operating Licenses. The proposed changes extend the surveillance interval for calibration of Average Power Range Monitor flow bias instrumentation from 18 months to 24 months.

Attachment 1 to this letter describes the proposed changes and provides justification for the changes. Attachment 2 provides marked-up Technical Specifications pages indicating the proposed changes. If you have any questions concerning this matter, please do not hesitate to contact us.

Very truly yours,

G. A. Hunger, Jr.
G. A. Hunger, Jr.,
Director - Licensing

cc: H. J. Miller, Administrator, Region I, USNRC
W. L. Schmidt, Senior Resident Inspector, PBAPS, USNRC
R. R. Janati, Commonwealth of Pennsylvania

090069

9704090312 970331
PDR ADOCK 05000277
P PDR

1/1
ADU1



COMMONWEALTH OF PENNSYLVANIA :
 : SS
COUNTY OF CHESTER :

D. B. Feters, being first duly sworn, deposes and says:

That he is Vice President of PECO Energy, the applicant herein; that he has read the attached License Change Request (ECR 96-00627) for Peach Bottom Atomic Power Station, Unit 2 and Unit 3, Facility Operating Licenses Nos. DPR-44 and DPR-56, and knows the contents thereof; and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.



Vice President

Subscribed and sworn to
before me this 31st day
of March 1997.

Mary Lou Skrocki
Notary Public

