

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: (717) 542-3242

$$\text{IE}^{22} \quad ||$$

Attachment

LER 83-057/01X-1

NPF-14 and proposed Amendment 4 to NPF-22 were submitted on May 4, 1984 to incorporate feedwater bypass leakage testing requirements into the Technical Specifications. Additional engineering analysis has since justified that bypass leakage testing of the feedwater system is not necessary. The proposed Amendments were withdrawn on December 18, 1984 and NRC approval of PP&L's position was obtained on July 31, 1985.



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 28, 1986

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-057/01X-1
ER 100450 FILE 841-23
PLAS-143

Docket No. 50-387
License No. NPF-14

Attached is updated Licensee Event Report 83-057/01X-1. This event was determined reportable per Technical Specification 6.9.1.8h, in that bypass leakage calculations for the feedwater system were found invalid.

T.M. Crimmins, Jr.
Superintendent of Plant-Susquehanna

TNC/pjg

cc: Dr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Mr. R.H. Jacobs
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

1522
1/1