

DMB

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility: D. C. Cook Unit 1

Docket No. 50-315

Licensee Emergency Classification:
 _____ Notification of an Unusual Event
 _____ Alert
 _____ Site Area Emergency
 _____ General Emergency
 XX _____ Not Applicable

Subject: OUTAGE TO REPAIR MISCELLANEOUS PRIMARY SYSTEM LEAKAGE

The licensee has elected to keep Unit 1 shut down following a reactor trip on November 25, 1985, for the purpose of repairing several valve and component leaks in the primary cooling system. The reactor tripped on November 25, 1985, when instrument technicians inadvertently generated high negative flux rate signals during testing on the plant's nuclear instrumentation.

A subsequent examination of the reactor containment identified a number of leaking valves and components, most of which were repaired with plant in Hot Standby status. For the remaining leaks-two leaking safety injection check valves and a gasket flange leak for a reactor coolant pump-the licensee is placing the plant in Cold Shutdown. The outage is expected to last about 10 days. (The licensee did not exceed any Technical Specification leakage limits).

The Resident Inspectors will monitor the licensee's activities.

The State of Michigan will be informed.

Region III (Chicago) was notified of the outage plans by the Resident Inspector at 10:00 a.m., November 27, 1985. This information is current as of that time.

CONTACT:

J. F. Suermann
 J. F. Suermann
 FTS 388-5585

C. W. Hehl
 C. W. Hehl
 FTS 388-5552

N. Chrissotimos
 N. Chrissotimos
 FTS 388-5716

DISTRIBUTION:

H. St.	EDO	NRR	E/W	Willste	Mail: ADM:DMB
Chairman Palladino	PA		IE	NMSS	DOT:Trans on.y
Comm. Zech	ELD		OIA	RES	
Comm. Bernthal			AEOD		
Comm. Roberts					
Comm. Asselstine	SP 1:50	Regional Offices			
ACRS	INPO 2:04	NSAC 1:58			
SECY	RIII Resident Office				
CA	Licensee: 2:45	(Corp. Office - Reactor Lic. Only)			
PDR					

Region III
 Rev. November 1985

8512050179 851127
 PDR I&E
 PNO-III-85-099 PDR

IE34
0/1