



ATOMIC POWER COMPANY •

EDISON DRIVE
AUGUSTA, MAINE 04336
(207) 623-3521

January 30, 1986
MN-86-19

GDW-86-31

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Ashok C. Thadani, Director
PWR Project Directorate #8
Division of Licensing

References: (a) License No. DPR-36 (Docket No. 50-309)
(b) MYAPCo Letter to USNRC dated July 18, 1985 (MN-85-134)
Maine Yankee Offsite Power Supplies

Subject: Results of Offsite Power Supply Tests During the 1985 Refueling Outage

Gentlemen:

In recent telephone discussions, our NRR Project Manager, Pat Sears, requested that we document the completion of commitments made in Reference (b), concerning offsite power supplies. Each of the actions has been completed as described below.

MN-85-134 - Commitment 1:

Maine Yankee will develop a testing procedure by August 30, 1985. Testing will be completed prior to startup after the 1985 refueling outage.

Resolution:

Procedure 1-22-4-1 was prepared and approved by PORC. The test was completed during the outage. Copies of the procedure are available for your review at the plant site along with the test results. In 1985 we found that voltages were acceptable; we plan to conduct this test during each refueling.

MN-85-134 Commitment 2:

[B]y August 30, 1985, Maine Yankee will implement a program for review and updating, as appropriate, our voltage system computer models. The purpose of this program is to periodically verify the adequacy of Maine Yankee's station service power systems.

Resolution:

Maine Yankee satisfied this requirement by performing Plant Engineering Procedure 17-301. Copies are available at the plant site for your review.

8602060053 860130
PDR ADOCK 05000309
P PDR

Acc'd
1/10

United States Nuclear Regulatory Commission
Attention: Mr. Ashok C. Thadani, Director

Page Two
MN-86-19

MN-85-134 Commitment 3:

Maine Yankee will complete the tap setting change during the 1985 refueling.


Resolution:

The tap setting changes were completed during the outage under DR/RO numbers 3998-85 and 4000-85. These completed work packages are also available for review at the plant.

We hope this information enables you to close this matter in your records.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY



G. D. Whittier, Manager
Nuclear Engineering & Licensing

GDW/bjp

cc: Dr. Thomas E. Murley
Mr. Cornelius F. Holden
Mr. Pat Sears