

TABLE 1

U S NUCLEAR REGULATORY COMMISSION
 OFFICE OF INSPECTION AND ENFORCEMENT
 CONFIRMATORY MEASUREMENTS PROGRAM
 FACILITY: POINT BEACH
 FOR THE 3 QUARTER OF 1984

SAMPLE	ISOTOPE	-----NRC-----		----LICENSEE----		---LICENSEE:NRC----		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	G BETA	3.0E-04	1.1E-05	2.9E-04	3.0E-06	9.6E-01	2.7E 01	A
	H-3	9.4E-01	5.0E-03	5.9E-01	0.0E-01	6.3E-01	1.9E 02	D
	SR-89	2.1E-07	3.0E-08	2.0E-07	1.4E-08	9.4E-01	7.0E 00	A
	SR-90	4.7E-07	3.0E-08	3.3E-07	6.5E-08	7.0E-01	1.6E 01	A

T TEST RESULTS:

A=AGREEMENT

D=DISAGREEMENT

*=CRITERIA RELAXED

N=NO COMPARISON

8512050343 851121
 PDR ADOCK 05000266
 G PDR