

ILLINOIS POWER COMPANY



CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

January 31, 1986

Docket No. 50-461

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Director
BWR Project Directorate No. 4
Division of BWR Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Clinton Power Station Unit 1
SER Outstanding Issue #7ii
Seismic and Dynamic Qualification of Equipment

Dear Dr. Butler:

This letter is in response to an unresolved item identified by the NRC Seismic Qualification Review Team (SQRT) during their visit to Clinton Power Station (CPS) during the week of August 27-30, 1985. As requested in Generic Item 5, attached is copy of the December 1985 report entitled "Qualification/Installation Status by Equipment Number."

Please contact us if you have any questions on this matter.

Sincerely yours,

F. A. Spangenberg
F. A. Spangenberg
Manager - Licensing
and Safety

SMK/ckc

Attachment

cc: B. L. Siegel, NRC Clinton Licensing Project Manager
NRC Resident Office
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety

8602070011 860131
PDR ADDCK 05000461
E PDR

ADD:

ENCLOSURE TO

A. Lee 1C4

J. Lombardo 1C4

A048
1/10

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PR	0AE-PR005	Ebrln/	No	No
PR	0AE-PR006	Ebrln/	No	No
AP	0AP05E	Gld-BB/480V Substn	Yes	Yes
AP	0AP06E	Gld-BB/480V Substn	Yes	Yes
AP	0AP24E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP25E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP54EA	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP54EB	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP55EA	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP55EB	Gld-ITE/5600 Series MCC	Yes	Yes
AP	0AP56E	GLD-ITE/5600 Series MCC	Yes	Yes
AP	0AP57E	Gld-ITE/5600 Series MCC	Yes	Yes
VC	0ES-VC533A	GE/Load Drvs	Yes	Yes
VC	0ES-VC533B	GE/Load Drvs	Yes	Yes
VC	0ES-VC534A	GE/Load Drvs	Yes	Yes
VC	0ES-VC534B	GE/Load Drvs	Yes	Yes
VC	0ES-VC535A	GE/Load Drvs	Yes	Yes
VC	0ES-VC535B	GE/Load Drvs	Yes	Yes
VC	0ES-VC535C	GE/Load Drvs	Yes	No
VC	0ES-VC536A	GE/Load Drvs	Yes	Yes
VC	0ES-VC536B	GE/Load Drvs	Yes	Yes
VC	0ES-VC536C	GE/Load Drvs	Yes	No
VC	0ES-VG516A	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ505A	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ505B	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ505C	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ512A	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ512B	GE/Load Drvs	Yes	Yes
VQ	0ES-VQ513A	GE/Load Drvs	Yes	Yes
VC	0EY-VC093	ActPk/Pwr Sp AP9046	Yes	Yes
VC	0EY-VC193	ActPk/Pwr Sp AP9046	Yes	Yes
VG	0FC-VG004	Lv/Cntr 54-8115-8134-8174	Yes	Yes
VG	0FC-VG104	Lv/Cntr 54-8115-8134-8174	Yes	Yes
VG	0FE-VG001	AirMonCorp/AirFlow Statns	Yes	Yes
VG	0FE-VG004	AirMonCorp/AirFlow Statns	Yes	Yes
VG	0FE-VG104	AirMonCorp/AirFlow Statns	Yes	Yes
VR	0FE-VR500	BrndtInd/Air Flw Measurng Stat	Yes	Yes
PR	0FI-PR008A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0FI-PR008B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0FI-PR012A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0FI-PR012B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
VC	0FI-VC072	GE/180 Vert Ind	Yes	Yes
VC	0FI-VC172	GE/180 Vert Ind	Yes	Yes
VG	0FI-VG004	GE/180 Vert Ind	Yes	Yes
VG	0FI-VG104	GE/180 Vert Ind	Yes	Yes
VC	0FIC-VC072	LvCntlr/54-8115-8134-8174	Yes	Yes
VC	0FIC-VC172	LvCntlr/54-8115-8134-8174	Yes	Yes
VC	0FIS-VC008	ITTBtrn/Sw 580-0	Yes	Yes
VC	0FIS-VC108	ITTBtrn/Sw 580-0	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PR	0FS-PR008	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0FS-PR012	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
VC	0FSV-VC614A	AlliedCntrl/Sol 1-HH20313	Yes	Yes
VC	0FSV-VC614B	AlliedCntrl/Sol 1-HH20313	Yes	Yes
VC	0FT-VC072	Vldyn/Flow Xmtr P372D-1-12-93	Yes	Yes
VC	0FT-VC172	Vldyn/Flow Xmtr P372D-1-12-93	Yes	Yes
VG	0FT-VG004	Vldyn/Flow Xmtr P372D-1-12-93	Yes	Yes
VG	0FT-VG104	Vldyn/Flow Xmtr P372D-1-12-93	Yes	Yes
VC	0FY-VC072	Trnsmtn/W-221A-20-243	Yes	Yes
VC	0FY-VC172	Trnsmtn/W-221A-20-243	Yes	Yes
VG	0FY-VG004A	Xmtn/Flw Alrm Rly W221A-20-243	Yes	Yes
VG	0FY-VG004B	Xmtn/Flw Alrm Rly W221A-20-243	Yes	Yes
VG	0FY-VG104A	Xmtn/Flw Alrm Rly W221A-20-243	Yes	Yes
VG	0FY-VG104B	Xmtn/Flw Alrm Rly W221A-20-243	Yes	Yes
VC	0FZ-VC003A	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003B	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003C	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003D	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003E	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003F	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC003G	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC005	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC006	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC011	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC012	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC014	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC016AA	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC016AB	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC016BA	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC016BB	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC017	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC022	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC023	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC024	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC025	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC026	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC068	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC072	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC096	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103A	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103B	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103C	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103D	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103E	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103F	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC103G	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC105	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC106	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC111	ITT/NH-95 Act	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0FZ-VC112	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC114	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC116AA	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC116AB	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC116BA	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC116BB	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC117	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC122	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC123	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC124	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC125	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC126	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC168	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC172	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC196	ITT/NH-95 Act	Yes	Yes
VC	0FZ-VC604A	Carrier/Act 0VC13CA	Yes	Yes
VC	0FZ-VC604B	Carrier/Act 0VC13CB	Yes	Yes
VC	0FZ-VC606A	Carrier/Act 0VC13CA	Yes	Yes
VC	0FZ-VC606B	Carrier/Act 0VC13CB	Yes	Yes
VG	0FZ-VG003A	ITT/NH-95	Yes	Yes
VG	0FZ-VG003B	ITT/NH-95	Yes	Yes
VG	0FZ-VG004	ITT/NH-91	Yes	Yes
VG	0FZ-VG006A	ITT/NH-95	Yes	Yes
VG	0FZ-VG006B	ITT/NH-95	Yes	Yes
VG	0FZ-VG103A	ITT/NH-95	Yes	Yes
VG	0FZ-VG103B	ITT/NH-95	Yes	Yes
VG	0FZ-VG104	ITT/NH-91	Yes	Yes
VG	0FZ-VG106A	ITT/NH-95	Yes	Yes
VG	0FZ-VG106B	ITT/NH-95	Yes	Yes
VL	0FZ-VL011	Cntrmtcs/375 SR Act	Yes	No
VL	0FZ-VL013	Cntrmtcs/375 SR Act	Yes	No
VQ	0FZ-VQ013	ITT/NH-95 Act	Yes	Yes
VQ	0FZ-VQ014	ITT/NH-95 Act	Yes	Yes
VQ	0FZ-VQ016	ITT/NH-95 Act	Yes	Yes
VQ	0FZ-VQ017	ITT/NH-95 Act	Yes	Yes
VQ	0FZ-VQ019	ITT/NH-95 Act	Yes	Yes
VQ	0FZ-VQ020	ITT/NH-95 Act	Yes	Yes
HG	0HG01JA	Rockwell/Pwr & Cntrl Pnl	Yes	Yes
HG	0HG01JB	Rockwell/Pwr & Cntrl Pnl	Yes	Yes
HG	0HG01SA	Rckwl/H2 Recomb	Yes	Yes
HG	0HG01SA(3)	Rama/IH-7905, 4.8 KV Htr	Yes	Yes
HG	0HG01SB	Rckwl/H2 Recomb	Yes	Yes
HG	0HG01SB(3)	Rama/IH-7905, 4.8 KV Htr	Yes	Yes
HG	0HG03CA	Rckwl/DR6 Support Bracket	Yes	Yes
HG	0HG03CA(M)	Rlnc/7HP TETZ-XT 254TCZ	Yes	Yes
HG	0HG03CB	Rckwl/DR6 Support Bracket	Yes	Yes
HG	0HG03CB(M)	Rlnc/7HP TETZ-XT 254TCZ	Yes	Yes
HG	0HG04CA(M)	Rlnc/3HP TETZ-XT 213T	Yes	Yes
HG	0HG04CB(M)	Rlnc/3HP TETZ-XT 213T	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
AP	0HS-AP033	GE/CR2940	Yes	Yes
AP	0HS-AP034	GE/CR2940	Yes	Yes
MC	0HS-MC007	GE/CR2940	Yes	Yes
MC	0HS-MC008	GE/CR2940	Yes	Yes
MC	0HS-MC009	GE/CR2940	Yes	Yes
MC	0HS-MC010	GE/CR2940	Yes	Yes
MC	0HS-MC012	GE/CR2940	Yes	Yes
MC	0HS-MC013	GE/CR2940	Yes	Yes
RA	0HS-RA008	GE/CR2940	Yes	No
RA	0HS-RA009	GE/CR2940	Yes	No
VC	0HS-VC001	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC002	GE/HS SBM	Yes	Yes
VC	0HS-VC003A	GE/CR2940	Yes	Yes
VC	0HS-VC003B	GE/CR2940	Yes	Yes
VC	0HS-VC004A	GE/SBM	Yes	Yes
VC	0HS-VC004B	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC007	GE/SBM	Yes	Yes
VC	0HS-VC009	GE/SBM	Yes	Yes
VC	0HS-VC010	GE/HS SB1	Yes	Yes
VC	0HS-VC013A	GE/CR2940	Yes	Yes
VC	0HS-VC013B	GE/CR2940	Yes	Yes
VC	0HS-VC015A	GE/CR2940	Yes	Yes
VC	0HS-VC015B	GE/CR2940	Yes	Yes
VC	0HS-VC020A	GE/CR2940	Yes	Yes
VC	0HS-VC020B	GE/CR2940	Yes	Yes
VC	0HS-VC06B	GE/CR2940	Yes	Yes
VC	0HS-VC071	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC080A	GE/CR2940	Yes	Yes
VC	0HS-VC080B	GE/CR2940	Yes	Yes
VC	0HS-VC085	GE/CR2940	Yes	Yes
VC	0HS-VC101	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC102	GE/SBM	Yes	Yes
VC	0HS-VC103A	GE/CR2940	Yes	Yes
VC	0HS-VC103B	GE/CR2940	Yes	Yes
VC	0HS-VC104A	GE/SBM	Yes	Yes
VC	0HS-VC104B	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC107	GE/SBM	Yes	Yes
VC	0HS-VC109	GE/SBM	Yes	Yes
VC	0HS-VC110	GE/SB1	Yes	Yes
VC	0HS-VC113A	GE/CR2940	Yes	Yes
VC	0HS-VC113B	GE/CR2940	Yes	Yes
VC	0HS-VC115A	GE/CR2940	Yes	Yes
VC	0HS-VC115B	GE/CR2940	Yes	Yes
VC	0HS-VC119	GE/HS	Yes	Yes
VC	0HS-VC120A	GE/CR2940	Yes	Yes
VC	0HS-VC120B	GE/CR2940	Yes	Yes
VC	0HS-VC16B	GE/CR2940	Yes	Yes
VC	0HS-VC171	ElctrSw/20K Hand Sw	Yes	Yes
VC	0HS-VC180A	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0HS-VC180B	GE/CR2940	Yes	Yes
VC	0HS-VC185	GE/CR2940	Yes	Yes
VC	0HS-VC301	GE/CR2940	Yes	Yes
VC	0HS-VC302	GE/CR2940	Yes	Yes
VC	0HS-VC303	GE/CR2940	Yes	Yes
VC	0HS-VC304	GE/CR2940	Yes	Yes
VC	0HS-VC341	GE/CR2940	Yes	Yes
VC	0HS-VC342	GE/CR2940	Yes	Yes
VC	0HS-VC401	GE/CR2940	Yes	Yes
VC	0HS-VC402	GE/CR2940	Yes	Yes
VC	0HS-VC403	GE/CR2940	Yes	Yes
VC	0HS-VC404	GE/CR2940	Yes	Yes
VC	0HS-VC607A	AlnBrd/Hnd Sw 800H-R2A	Yes	Yes
VC	0HS-VC607B	AlnBrd/Hnd Sw 800H-R2A	Yes	Yes
VC	0HS-VC627A	AlnBrd/Hnd Sw P/N 800H-R2A2	Yes	Yes
VC	0HS-VC627B	AlnBrd/Hnd Sw P/N 800H-R2A2	Yes	Yes
VC	0HS-VC628A	AlnBrd/Hnd Sw P/N 800H-H33A	Yes	Yes
VC	0HS-VC628B	AlnBrd/Hnd Sw P/N 800H-H33A	Yes	Yes
VC	0HS-VC629A	AlnBrd/Hnd Sw P/N 800H-R1A	Yes	Yes
VC	0HS-VC629B	AlnBrd/Hnd Sw P/N 800H-R1A	Yes	Yes
VG	0HS-VG039	GE/CR2940	Yes	Yes
VG	0HS-VG139	GE/CR2940	Yes	Yes
VG	0HS-VG155	GE/SBM	Yes	Yes
VG	0HS-VG157	GE/SMM	Yes	Yes
VG	0HS-VG161	GE/SMB	Yes	Yes
VG	0HS-VG163	GE/SMB	Yes	Yes
VQ	0HS-VQ013	ElctrSw/20K Hand Sw	Yes	Yes
VQ	0HS-VQ016	ElctrSw/20K Hand Sw	Yes	Yes
VQ	0HS-VQ019	ElctrSw/20K Hand Sw	Yes	Yes
VQ	0HS-VQ022	GE/CR2940	Yes	Yes
IP	0IP54EB	PwrCnvProd/15KVA AD Ln Rgltr	Yes	Yes
IP	0IP55EB	PwrCnvProd/15KVA AD Ln Rgltr	Yes	Yes
VC	0KY-VC001	Agst/7014 PDLL	Yes	Yes
VC	0KY-VC003	Agst/7014 PD	Yes	Yes
VC	0KY-VC004	Agst/7014PD	Yes	No
VC	0KY-VC008	Agst/7014AD	Yes	Yes
VC	0KY-VC017	Agst/7014AD	Yes	Yes
VC	0KY-VC019	Agst/7014PDLL	Yes	Yes
VC	0KY-VC044	Agst/7014PD	Yes	Yes
VC	0KY-VC045	Agst/7014PD	Yes	Yes
VC	0KY-VC046	Agst/7014AD	Yes	Yes
VC	0KY-VC101	Agst/7014PDLL	Yes	Yes
VC	0KY-VC103	Agst/7014AD	Yes	Yes
VC	0KY-VC104	Agst/7014PD	Yes	No
VC	0KY-VC108	Agst/7014AD	Yes	Yes
VC	0KY-VC117	Agst/7014AD	Yes	Yes
VC	0KY-VC119	Agst/7014PDLL	Yes	Yes
VC	0KY-VC144	Agst/7014PD	Yes	Yes
VC	0KY-VC145	Agst/7014PD	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0KY-VC146	Agst/7014AD	Yes	Yes
VC	0KY-VC360	Agst/7014AC	Yes	Yes
VC	0KY-VC361	Agst/7014AC	Yes	Yes
VC	0KY-VC362	Agst/7014AC	Yes	Yes
VG	0KY-VC363	Agst/7014AC	Yes	Yes
VC	0KY-VC623A	Agst/7022AN	Yes	Yes
VC	0KY-VC623B	Agst/7022AN	Yes	Yes
VC	0KY-VC624A	Agst/7012AB	Yes	Yes
VC	0KY-VC624B	Agst/7012AB	Yes	Yes
VC	0KY-VC625A	Agst/324CD4C1G1R1A01X	Yes	Yes
VC	0KY-VC625B	Agst/324CD4C1G1R1A01X	Yes	Yes
VC	0KY-VC626A	Agst/324CDP2FR1A01X	Yes	Yes
VC	0KY-VC626B	Agst/324CDP2FR1A01X	Yes	Yes
VG	0KY-VG036	Agst/7014AD	Yes	Yes
VG	0KY-VG037	Agst/7014AD	Yes	Yes
VG	0KY-VG136	Agst/7014AD	Yes	Yes
VG	0KY-VG137	Agst/7014AD	Yes	Yes
MC	0MC009(A)	Lmt/SMB-000	Yes	Yes
MC	0MC009(V)	AD/4" Gt Vlv	Yes	Yes
MC	0MC010(A)	Lmt/SMB-000	Yes	Yes
MC	0MC010(V)	AD/4" Gt Vlv	Yes	Yes
VC	0MT-VC027	Aminco/Xmtr	Yes	Yes
VC	0MT-VC090	Aminco/Xmtr	Yes	Yes
VC	0MT-VC091	Aminco/Xmtr	Yes	Yes
VC	0MT-VC092	Aminco/Xmtr	Yes	Yes
VC	0MT-VC127	Aminco/Xmtr	Yes	Yes
VC	0MT-VC190	Aminco/Xmtr	Yes	Yes
VC	0MT-VC191	Aminco/Xmtr	Yes	Yes
VC	0MT-VC192	Aminco/Xmtr	Yes	Yes
VC	0PC-VC093	Hnywl/R7335C	Yes	Yes
VC	0PC-VC193	Hnywl/R7335C	Yes	Yes
VC	0PDI-VC021	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC047	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC052	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC058	Dwyer/2000 DP Gage	Yes	Yes
VC	0PDI-VC059	Dwyer/2000 DP Gage	Yes	Yes
VC	0PDI-VC121	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC147	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC152	GE/180 Vert Ind	Yes	Yes
VC	0PDI-VC158	Dwyer/2000 DP Gage	Yes	Yes
VC	0PDI-VC159	Dwyer/2000 DP Gage	Yes	Yes
VG	0PDI-VG001	GE/180 Vert Ind	Yes	Yes
VG	0PDI-VG023	GE/180 Vert Ind	Yes	Yes
VG	0PDI-VG024	GE/180 Vert Ind	Yes	Yes
VG	0PDI-VG101	GE/180 Vert Ind	Yes	Yes
VG	0PDI-VG123	GE/180 Vert Ind	Yes	Yes
VG	0PDI-VG124	GE/180 Vert Ind	Yes	Yes
VC	0PDR-VC053	Westronics/M11E	Yes	Yes
VC	0PDR-VC153	Westronics/M11E	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0PDS-VC031	ITTBrtn/583A-2	Yes	Yes
VC	0PDS-VC044	Solon/7PSIIADPW	Yes	Yes
VC	0PDS-VC045	Solon/7PSIIADPW	Yes	Yes
VC	0PDS-VC046	ITT Barton/581A-2	Yes	Yes
VC	0PDS-VC131	ITTBrtn/583A-2	Yes	Yes
VC	0PDS-VC144	Solon/7PSIIADPW	Yes	Yes
VC	0PDS-VC145	Solon/7PSIIADPW	Yes	Yes
VC	0PDS-VC146	ITTBrtn/581A-2	Yes	Yes
VG	0PDS-VG035	ITTBrtn/583A-2	Yes	Yes
VG	0PDS-VG036	ITTBrtn/583A-2	Yes	Yes
VG	0PDS-VG037	ITTBrtn/581A-2	Yes	Yes
VG	0PDS-VG135	ITTBrtn/583A-2	Yes	Yes
VG	0PDS-VG136	ITTBrtn/583A-2	Yes	Yes
VG	0PDS-VG137	ITTBrtn/581A-2	Yes	Yes
VC	0PDT-VC021A	Vldyn/Diff Press Xmtr	Yes	Yes
VC	0PDT-VC021B	Vldyn/Diff Press Xmtr	Yes	Yes
VC	0PDT-VC047	Rsmt/1153	Yes	Yes
VC	0PDT-VC052	Rsmt/1153	Yes	Yes
VC	0PDT-VC053	Rsmt/1153	Yes	Yes
VC	0PDT-VC121A	Vldyn/Diff Press Xmtr	Yes	Yes
VC	0PDT-VC121B	Vldyn/Diff Press Xmtr	Yes	Yes
VC	0PDT-VC147	Rsmt/1153	Yes	Yes
VC	0PDT-VC152	Rsmt/1153	Yes	Yes
VC	0PDT-VC153	Rsmt/1153	Yes	Yes
VG	0PDT-VG023	ITTBrtn/765 DP Xmtr	Yes	Yes
VG	0PDT-VG024	ITTBrtn/765 DP Xmtr	Yes	Yes
VG	0PDT-VG123	ITTBrtn/765 DP Xmtr	Yes	Yes
VG	0PDT-VG124	ITTBrtn/765 DP Xmtr	Yes	Yes
VC	0PDY-VC021	Roca/SC1320 Current Rly	Yes	Yes
VC	0PDY-VC047	Xmtn/W-221A-20-243	Yes	Yes
VC	0PDY-VC052	Xmtn/W-221A-20-243	Yes	Yes
VC	0PDY-VC053	Xmtn/W-221A-20-243	Yes	Yes
VC	0PDY-VC121	Rochester Ins/SC1320	Yes	Yes
VC	0PDY-VC147	Xmtn/W-221A-20-243	Yes	Yes
VC	0PDY-VC152	Xmtn/W-221A-20-243	Yes	Yes
VC	0PDY-VC153	Xmtn/W-221A-20-243	Yes	Yes
VG	0PDY-VG023	Xmtn/W-221A-20-243	Yes	Yes
VG	0PDY-VG024	Xmtn/W-221A-20-243	Yes	Yes
VG	0PDY-VG123	Xmtn/W-221A-20-243	Yes	Yes
VG	0PDY-VG124	Xmtn/W-221A-20-243	Yes	Yes
PR	0PI-PR008A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PI-PR008B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PI-PR012A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PI-PR012B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PL	0PL39JA	MCCPwrs/Stndby Gas Trtmnt A	Yes	Yes
PL	0PL39JB	MCCPwrs/Stndby Gas Trtmnt B	Yes	Yes
PL	0PL43JA	ActPkHywlRsmt/	Yes	Yes
PL	0PL43JB	ActPkHywlRsmt/	Yes	Yes
PL	0PL47JA	MCCPwrs/Cubical Coolers	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PL	0PL47JB	MCCPwrs/Cubical Coolers	Yes	Yes
PL	0PL47JB	Bchanan-ITE-Gld/3581 P-302C	Yes	Yes
PL	0PL58J	MCCPwrs/HVAC Contr Pnl	Yes	Yes
PL	0PL72JA	MCCPwrs/HVAC Contr Pnl	Yes	Yes
PL	0PL72JB	MCCPwrs/HVAC Contr Pnl	Yes	Yes
PR	0PR05S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR06S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR07S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR08S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR09S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR10S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR11S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0PR12S	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
VC	0PR13A	Ebrln/Sample Cplr	Yes	Yes
VC	0PS-VC093	ITTBrtn/DP Sw 580-0	Yes	Yes
VC	0PS-VC193	ITTBrtn/DP Sw 580-0	Yes	Yes
VC	0PS-VC610A	Vel/J6D274	Yes	Yes
VC	0PS-VC610B	Vel/J6D27A	Yes	Yes
VC	0PS-VC613A	Vel/J21KD-7879	Yes	Yes
VC	0PS-VC613B	Vel/J21KD-7871	Yes	Yes
VC	0PS-VC614A	Vel/J21KD-7880	Yes	Yes
VC	0PS-VC614B	Vel/J21KD-7880	Yes	Yes
VC	0PS-VC615A	Vel/AP21-1092	Yes	Yes
VC	0PS-VC615B	Vel/AP21-1092	Yes	Yes
VC	0PS-VC620A	Vel/J27KDBT50	Yes	Yes
VC	0PS-VC620B	Vel/J27KDB550	Yes	Yes
VC	0PT-VC093	Rsmt/1153	Yes	Yes
VC	0PT-VC193	Rsmt/1153	Yes	Yes
RA	0RA026(L)	Namco/EA180	Yes	Yes
RA	0RA026(LS)	Conax/7F20-11005-01	Yes	Yes
RA	0RA026(O)	Asco/2068323U	Yes	Yes
RA	0RA026(OS)	Conax/7F20-11001-02	Yes	Yes
RA	0RA026(V)	Fshr/1" AO G1b V1v	Yes	Yes
RA	0RA027(L)	Namco/EA180	Yes	Yes
RA	0RA027(LS)	Conax/7F20-11005-01	Yes	Yes
RA	0RA027(O)	Asco/2068323U	Yes	Yes
RA	0RA027(OS)	Conax/7F20-11001-02	Yes	Yes
RA	0RA027(V)	Fshr/1" AO G1b V1v	Yes	Yes
RA	0RA028(L)	Namco/EA180	Yes	Yes
RA	0RA028(LS)	Conax/7F20-11005-01	Yes	Yes
RA	0RA028(O)	Asco/2068323U	Yes	Yes
RA	0RA028(OS)	Conax/7F20-11001-02	Yes	Yes
RA	0RA028(V)	Fshr/1" AO G1b V1v	Yes	Yes
RA	0RA029(L)	Namco/EA180	Yes	Yes
RA	0RA029(LS)	Conax/7F20-11005-01	Yes	Yes
RA	0RA029(O)	Asco/2068323U	Yes	Yes
RA	0RA029(OS)	Conax/7F20-11001-02	Yes	Yes
RA	0RA029(V)	Fshr/1" AO G1b V1v	Yes	Yes
PR	0RE-PR008A	Ebrln/10450-806	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PR	0RE-PR008B1	Ebrln/10450-B28	Yes	Yes
PR	0RE-PR008B2	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0RE-PR008C	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0RE-PR012A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0RE-PR012B1	Ebrln/10450-B06	Yes	Yes
PR	0RE-PR012B2	Ebrln/10450-B28	Yes	Yes
PR	0RE-PR012C	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
VC	0RI-VC075	GE/180 Vert Ind	Yes	Yes
VC	0RI-VC076	GE/180 Vert Ind	Yes	Yes
VC	0RI-VC175	GE/180 Vert Ind	Yes	Yes
VC	0RI-VC176	GE/180 Vert Ind	Yes	Yes
PR	0RIX-PR008	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0RIX-PR012	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0RX-PR0012A	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR0012B1	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR0012B2	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR0012C	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR008A	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR008B1	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR008B2	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
PR	0RX-PR008C	Ebrln/Rad Det IB-4A-HT-CC	Yes	No
VC	0SQ-VC605A	Carrier/Guide Vane Close Sw	Yes	Yes
VC	0SQ-VC605B	Carrier/Guide Van Close Sw	Yes	Yes
VC	0TC-VC622A	Carrier/Chiller Instr	Yes	Yes
VC	0TC-VC622B	Carrier/Chiller Instr	Yes	Yes
VC	0TE-VC028	Kidde/Temp Elem	Yes	No
VC	0TE-VC030	Kidde/Temp Elem	Yes	No
VC	0TE-VC033	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC034	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC035	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC036	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC037	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC038	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC039	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC049	Wd/TempElmt 612-1A-C-3-11-0-0	Yes	Yes
VC	0TE-VC057	Wd/TempElmt 612-1A-C-3-11-0-0	Yes	Yes
VC	0TE-VC133	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC134	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC135	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC136	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC137	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC138	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC139	Minco/RTD S8894Z8	Yes	Yes
VC	0TE-VC149	Wd/TempElmt 612-1A-C-3-11-0-0	Yes	Yes
VC	0TE-VC157	Wd/TempElmt 612-1A-C-3-11-0-0	Yes	Yes
VC	0TE-VC617A	RShw/E511-1101	Yes	Yes
VC	0TE-VC617B	RShw/E511-1101	Yes	Yes
VC	0TE-VC617C	RShw/E511-1101	Yes	Yes
VC	0TE-VC617D	RShw/E511-1101	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	QTE-VC618A	RShw/E511-3002	Yes	Yes
VC	QTE-VC618B	RShw/E511-3002	Yes	Yes
VC	QTE-VC619A	RShw/A-294	Yes	Yes
VC	QTE-VC619B	RShw/a-294	Yes	Yes
VC	QTE-VC622A	Spctrl/1990-0123	Yes	Yes
VC	QTE-VC622B	Spctrl/1990-0123	Yes	Yes
VG	QTE-VG021	Wd/ 612-1A-A-C-3-C-11-0-0	Yes	Yes
VG	QTE-VG022	Wd/ 612-1A-A-C-3-C-11-0-0	Yes	Yes
VG	QTE-VG121	Wd/ 612-1A-A-C-3-C-11-0-0	Yes	Yes
VG	QTE-VG122	Wd/ 612-1A-A-C-3-C-11-0-0	Yes	Yes
VC	QTI-VC049	GE/Vert Ind 180	Yes	Yes
VC	QTI-VC057	GE/Vert Ind 180	Yes	Yes
VC	QTI-VC149	GE/Vert Ind 180	Yes	Yes
VC	QTI-VC157	GE/Vert Ind 180	Yes	Yes
VG	QTI-VG021	GE/Vert Ind 180	Yes	Yes
VG	QTI-VG022	GE/Vert Ind 180	Yes	Yes
VG	QTI-VG121	GE/Vert Ind 180	Yes	Yes
VG	QTI-VG122	GE/Vert Ind 180	Yes	Yes
VC	QTIC-VC033	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC034	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC035	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC038	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC039	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC133	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC134	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC135	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC138	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIC-VC139	Lv/TmpCnt54-838-8139-8134-8174	Yes	Yes
VC	QTIS-VG161	Untd/802PE-7BS Temp Ind Sw	Yes	Yes
VC	QTIY-VC036	Lv/Tmp Rly 48-8115-8174-843	Yes	Yes
VC	QTIY-VC037	Lv/Tmp Rly 48-8115-8174-843	Yes	Yes
VC	QTIY-VC136	Lv/Tmp Rly 48-8115-8174-843	Yes	Yes
VC	QTIY-VC137	Lv/Tmp Rly 48-8115-8174-843	Yes	Yes
VC	QTS-VC019A	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC019B	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC065A	Thermodisc/Autotherm Cutout	Yes	Yes
VC	QTS-VC065B	Thermodisc/Autotherm Cutout	Yes	Yes
VC	QTS-VC094	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC119A	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC119B	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC165A	Thermodisc/Autotherm Cutout	Yes	Yes
VC	QTS-VC165B	Thermodisc/Autotherm Cutout	Yes	Yes
VC	QTS-VC194	United/Temp Sw F302D-5CS	Yes	Yes
VC	QTS-VC601A	Fnwl/67121-0	Yes	Yes
VC	QTS-VC601B	Fnwl/67121-0	Yes	Yes
VC	QTS-VC603A	Fnwl/80016-4	Yes	Yes
VC	QTS-VC603B	Fnwl/80016-4	Yes	Yes
VC	QTS-VC608A	Fnwl/85P1122	Yes	Yes
VC	QTS-VC608B	Fnwl/85P1122	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	QTS-VC609A	Ethrm/F300-6BS	Yes	Yes
VC	QTS-VC609B	Ethrm/F300-6BS	Yes	Yes
VC	QTS-VC610A	Ethrm/PNF7-84	Yes	Yes
VC	QTS-VC610B	Ethrm/PNF7-84	Yes	Yes
VC	QTS-VC611A	Ethrm/F302-6DS	Yes	Yes
VC	QTS-VC611B	Ethrm/F302-6DS	Yes	Yes
VC	QTS-VC616A	GE/1-733A4-76AP-P4	Yes	Yes
VC	QTS-VC616B	GE/1-733A4-76AP-P4	Yes	Yes
VC	QTS-VC617A	RShw/MP12-1037	Yes	Yes
VC	QTS-VC617B	RShw/MP12-1037	Yes	Yes
VC	QTS-VC618A	RShw/MP11-1028	Yes	Yes
VC	QTS-VC618B	RShw/MP11-1028	Yes	Yes
VC	QTS-VC619A	RShw/MP11-1028	Yes	Yes
VC	QTS-VC619B	RShw/MP11-1028	Yes	Yes
VG	QTS-VG010A	Thermodysc/Autotherm Cutout	Yes	Yes
VG	QTS-VG010B	Thermodysc/Autotherm Cutout	Yes	Yes
VG	QTS-VG110A	Thermodysc/Autotherm Cutout	Yes	Yes
VG	QTS-VG110B	Thermodysc/Autotherm Cutout	Yes	Yes
VC	QTSV-VC094	Asco/2068323U	Yes	Yes
VC	QTSV-VC194	Asco/2068323U	Yes	Yes
VG	QTT-VC049	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VC057	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VC149	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VC157	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VG021	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VG022	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VG121	Wd/Temp Trans 4000R	Yes	Yes
VG	QTT-VG122	Wd/Temp Trans 4000R	Yes	Yes
VC	QTTTC-VC036	Love/Temp Xmtr Ctrl (54)	Yes	Yes
VC	QTTTC-VC037	Love/Temp Xmtr Ctrl (54)	Yes	Yes
VC	QTTTC-VC136	Love/Temp Xmtr Ctrl (54)	Yes	Yes
VC	QTTTC-VC137	Love/Temp Xmtr Ctrl (54)	Yes	Yes
VC	QTTZ-VC033	ITT/NH-91	Yes	Yes
VC	QTTZ-VC034	ITT/NH-91	Yes	Yes
VC	QTTZ-VC035	ITT/NH-91	Yes	Yes
VC	QTTZ-VC036	ITT/NH-91	Yes	Yes
VC	QTTZ-VC037	ITT/NH-91	Yes	Yes
VC	QTTZ-VC038	ITT/NH-91	Yes	Yes
VC	QTTZ-VC039	ITT/NH-91	Yes	Yes
VC	QTTZ-VC133	ITT/NH-91	Yes	Yes
VC	QTTZ-VC134	ITT/NH-91	Yes	Yes
VC	QTTZ-VC135	ITT/NH-91	Yes	Yes
VC	QTTZ-VC136	ITT/NH-91	Yes	Yes
VC	QTTZ-VC137	ITT/NH-91	Yes	Yes
VC	QTTZ-VC138	ITT/NH-91	Yes	Yes
VC	QTTZ-VC139	ITT/NH-91	Yes	Yes
VC	QUAY-VC533A	Agst/GPIC750	Yes	Yes
VC	QUAY-VC533B	Agst/GPIC750	Yes	Yes
VC	QUAY-VC533C	Agst/GPIC750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
VC	0UAY-VC533D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC533E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC533F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC533G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC533H	Agst/GPIC750	Yes	Yes
VG	0UAY-VC533J	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534A	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534B	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534C	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534H	Agst/GPIC750	Yes	Yes
VC	0UAY-VC534J	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535A	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535B	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535C	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535H	Agst/GPIC750	Yes	Yes
VC	0UAY-VC535J	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536A	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536B	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536C	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536H	Agst/GPIC750	Yes	Yes
VC	0UAY-VC536J	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544A	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544B	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544C	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC544H	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545A	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545B	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545C	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545D	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545E	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545F	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545G	Agst/GPIC750	Yes	Yes
VC	0UAY-VC545H	Agst/GPIC750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
VG	0UAY-VG506A	Agst/GPIC750	Yes	Yes
VG	0UAY-VG506D	Agst/GPI750	Yes	Yes
VG	0UAY-VG506E	Agst/GPI750	Yes	Yes
VG	0UAY-VG506F	Agst/GPIC750	Yes	Yes
VG	0UAY-VG506G	Agst/GPIC750	Yes	Yes
VC	0UAY-VG506H	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508A	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508D	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508E	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508F	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508G	Agst/GPIC750	Yes	Yes
VG	0UAY-VG508H	Agst/GPIC750	Yes	Yes
VG	0UAY-VG515A	Agst/7014AE	Yes	Yes
VG	0UAY-VG515B	Agst/7014AE	Yes	Yes
VG	0UAY-VG515C	Agst/7014AE	Yes	Yes
VG	0UAY-VG515D	Agst/7014AE	Yes	Yes
VG	0UAY-VG516A	Agst/7014AE	Yes	Yes
VG	0UAY-VG516B	Agst/7014AE	Yes	Yes
VG	0UAY-VG516C	Agst/7014AE	Yes	Yes
VG	0UAY-VG516D	Agst/7014AE	Yes	Yes
VG	0UAY-VG516E	Agst/7014AE	Yes	Yes
AP	0UO-AP501A	GE/Opt Isol	Yes	Yes
AP	0UO-AP501B	GE/Opt Isol	Yes	Yes
AP	0UO-AP501C	GE/Opt Isol	Yes	Yes
AP	0UO-AP501D	GE/Opt Isol	Yes	Yes
AP	0UO-AP501E	GE/Opt Isol	Yes	Yes
AP	0UO-AP501F	GE/Opt Isol	Yes	Yes
AP	0UO-AP503A	GE/Opt Isol	Yes	Yes
AP	0UO-AP503B	GE/Opt Isol	Yes	Yes
AP	0UO-AP503C	GE/Opt Isol	Yes	Yes
AP	0UO-AP503D	GE/Opt Isol	Yes	Yes
AP	0UO-AP503E	GE/Opt Isol	Yes	Yes
AP	0UO-CA501A	GE/Opt Isol	Yes	Yes
VC	0UO-VC501A	GE/Opt Isol	Yes	Yes
VC	0UO-VC501B	GE/Opt Isol	Yes	Yes
VC	0UO-VC501C	GE/Opt Isol	Yes	Yes
VC	0UO-VC501D	GE/Opt Isol	Yes	Yes
VC	0UO-VC501E	GE/Opt Isol	Yes	Yes
VC	0UO-VC501F	GE/Opt Isol	Yes	Yes
VC	0UO-VC502A	GE/Opt Isol	Yes	Yes
VC	0UO-VC502B	GE/Opt Isol	Yes	Yes
VC	0UO-VC502C	GE/Opt Isol	Yes	Yes
VC	0UO-VC502D	GE/Opt Isol	Yes	Yes
VC	0UO-VC502E	GE/Opt Isol	Yes	Yes
VC	0UO-VC502F	GE/Opt Isol	Yes	Yes
VC	0UO-VC503A	GE/Opt Isol	Yes	Yes
VC	0UO-VC503B	GE/Opt Isol	Yes	Yes
VC	0UO-VC503C	GE/Opt Isol	Yes	Yes
VC	0UO-VC503D	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
VC	0U0-VC503E	GE/Opt Isol	Yes	Yes
VC	0U0-VC503F	GE/Opt Isol	Yes	Yes
VC	0U0-VC504A	GE/Opt Isol	Yes	Yes
VC	0U0-VC504B	GE/Opt Isol	Yes	Yes
VC	0U0-VC504C	GE/Opt Isol	Yes	Yes
VC	0U0-VC504D	GE/Opt Isol	Yes	Yes
VC	0U0-VC504E	GE/Opt Isol	Yes	Yes
VC	0U0-VC504F	GE/Opt Isol	Yes	Yes
VC	0U0-VC505A	GE/Opt Isol	Yes	Yes
VC	0U0-VC505B	GE/Opt Isol	Yes	Yes
VC	0U0-VC505C	GE/Opt Isol	Yes	Yes
VC	0U0-VC505D	GE/Opt Isol	Yes	Yes
VC	0U0-VC505E	GE/Opt Isol	Yes	Yes
VC	0U0-VC505F	GE/Opt Isol	Yes	Yes
VC	0U0-VC506A	GE/Opt Isol	Yes	Yes
VC	0U0-VC506B	GE/Opt Isol	Yes	Yes
VC	0U0-VC506C	GE/Opt Isol	Yes	Yes
VC	0U0-VC506D	GE/Opt Isol	Yes	Yes
VC	0U0-VC506E	GE/Opt Isol	Yes	Yes
VC	0U0-VC506F	GE/Opt Isol	Yes	Yes
VC	0U0-VC507A	GE/Opt Isol	Yes	Yes
VC	0U0-VC507B	GE/Opt Isol	Yes	Yes
VC	0U0-VC507C	GE/Opt Isol	Yes	Yes
VC	0U0-VC507D	GE/Opt Isol	Yes	Yes
VC	0U0-VC508A	GE/Opt Isol	Yes	Yes
VC	0U0-VC508B	GE/Opt Isol	Yes	Yes
VC	0U0-VC508C	GE/Opt Isol	Yes	Yes
VC	0U0-VC508D	GE/Opt Isol	Yes	Yes
VC	0U0-VC509A	GE/Opt Isol	Yes	Yes
VC	0U0-VC509B	GE/Opt Isol	Yes	Yes
VC	0U0-VC509C	GE/Opt Isol	Yes	Yes
VC	0U0-VC509D	GE/Opt Isol	Yes	Yes
VC	0U0-VC510A	GE/Opt Isol	Yes	Yes
VC	0U0-VC510B	GE/Opt Isol	Yes	Yes
VC	0U0-VC510C	GE/Opt Isol	Yes	Yes
VC	0U0-VC510D	GE/Opt Isol	Yes	Yes
VC	0U0-VC511A	GE/Opt Isol	Yes	Yes
VC	0U0-VC511B	GE/Opt Isol	Yes	Yes
VC	0U0-VC511C	GE/Opt Isol	Yes	Yes
VC	0U0-VC511D	GE/Opt Isol	Yes	Yes
VC	0U0-VC511E	GE/Opt Isol	Yes	Yes
VC	0U0-VC511F	GE/Opt Isol	Yes	Yes
VC	0U0-VC511G	GE/Opt Isol	Yes	Yes
VC	0U0-VC511H	GE/Opt Isol	Yes	Yes
VC	0U0-VC511I	GE/Opt Isol	Yes	Yes
VC	0U0-VC511J	GE/Opt Isol	Yes	Yes
VC	0U0-VC511K	GE/Opt Isol	Yes	Yes
VC	0U0-VC511L	GE/Opt Isol	Yes	Yes
VC	0U0-VC513A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0U0-VC513B	GE/Opt Isol	Yes	Yes
VC	0U0-VC514A	GE/Opt Isol	Yes	Yes
VC	0U0-VC514B	GE/Opt Isol	Yes	Yes
VC	0U0-VC533A	GE/Opt Isol	Yes	Yes
VC	0U0-VC533B	GE/Opt Isol	Yes	Yes
VC	0U0-VC534A	GE/Opt Isol	Yes	Yes
VC	0U0-VC534B	GE/Opt Isol	No	Yes
VC	0U0-VC535A	GE/Opt Isol	Yes	Yes
VC	0U0-VC535B	GE/Opt Isol	Yes	Yes
VC	0U0-VC535C	GE/Opt Isol	Yes	Yes
VC	0U0-VC535D	GE/Opt Isol	Yes	Yes
VC	0U0-VC536A	GE/Opt Isol	Yes	Yes
VC	0U0-VC536B	GE/Opt Isol	Yes	Yes
VC	0U0-VC536C	GE/Opt Isol	Yes	Yes
VC	0U0-VC536D	GE/Opt Isol	No	Yes
VC	0U0-VC541A	GE/Opt Isol	Yes	Yes
VC	0U0-VC541C	GE/Opt Isol	Yes	Yes
VC	0U0-VC542A	GE/Opt Isol	Yes	Yes
VC	0U0-VC542B	GE/Opt Isol	Yes	Yes
VC	0U0-VC543A	GE/Opt Isol	Yes	Yes
VC	0U0-VC543B	GE/Opt Isol	Yes	Yes
VC	0U0-VC543C	GE/Opt Isol	Yes	Yes
VC	0U0-VC543D	GE/Astat	Yes	Yes
VC	0U0-VC544A	GE/Opt Isol	Yes	Yes
VC	0U0-VC544B	GE/Opt Isol	Yes	Yes
VC	0U0-VC544C	GE/Opt Isol	Yes	Yes
VC	0U0-VC544D	GE/Opt Isol	Yes	Yes
VC	0U0-VC544E	GE/Opt Isol	Yes	Yes
VC	0U0-VC544F	GE/Opt Isol	Yes	Yes
VC	0U0-VC544G	GE/Opt Isol	Yes	Yes
VC	0U0-VC544H	GE/Opt Isol	Yes	Yes
VC	0U0-VC545A	GE/Opt Isol	Yes	Yes
VC	0U0-VC545B	GE/Opt Isol	Yes	Yes
VC	0U0-VC545C	GE/Opt Isol	Yes	Yes
VC	0U0-VC545D	GE/Opt Isol	Yes	Yes
VC	0U0-VC545E	GE/Opt Isol	Yes	Yes
VC	0U0-VC545F	GE/Opt Isol	Yes	Yes
VC	0U0-VC545G	GE/Opt Isol	Yes	Yes
VC	0U0-VC545H	GE/Opt Isol	Yes	Yes
VC	0U0-VC546A	GE/Opt Isol	Yes	Yes
VC	0U0-VC546B	GE/Opt Isol	Yes	Yes
VC	0U0-VC546C	GE/Opt Isol	Yes	Yes
VC	0U0-VC546D	GE/Opt Isol	Yes	Yes
VC	0U0-VC546E	GE/Opt Isol	Yes	Yes
VC	0U0-VC546F	GE/Opt Isol	Yes	Yes
VC	0U0-VC546G	GE/Opt Isol	Yes	Yes
VC	0U0-VC546H	GE/Opt Isol	Yes	Yes
VC	0U0-VC546J	GE/Opt Isol	Yes	Yes
VC	0U0-VC546K	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
VC	0U0-VC547A	GE/Opt Isol	Yes	Yes
VC	0U0-VC547B	GE/Opt Isol	Yes	Yes
VC	0U0-VC547C	GE/Opt Isol	Yes	Yes
VC	0U0-VC547D	GE/Opt Isol	Yes	Yes
VC	0U0-VC547E	GE/Opt Isol	Yes	Yes
VC	0U0-VC547F	GE/Opt Isol	Yes	Yes
VC	0U0-VC547G	GE/Opt Isol	Yes	Yes
VC	0U0-VC547H	GE/Opt Isol	Yes	Yes
VC	0U0-VC547J	GE/Opt Isol	Yes	Yes
VC	0U0-VC547K	GE/Opt Isol	Yes	Yes
VC	0U0-VC549A	GE/Opt Isol	No	Yes
VC	0U0-VC549B	GE/Opt Isol	No	Yes
VC	0U0-VC549C	GE/Opt Isol	No	Yes
VC	0U0-VC549D	GE/Opt Isol	No	Yes
VG	0U0-VG501A	GE/Opt Isol	Yes	Yes
VG	0U0-VG501B	GE/Opt Isol	Yes	Yes
VG	0U0-VG502A	GE/Opt Isol	Yes	Yes
VG	0U0-VG502B	GE/Opt Isol	Yes	Yes
VG	0U0-VG502C	GE/Opt Isol	Yes	No
VG	0U0-VG502D	GE/Opt Isol	Yes	No
VG	0U0-VG503A	GE/Opt Isol	Yes	Yes
VG	0U0-VG503B	GE/Opt Isol	Yes	Yes
VG	0U0-VG503C	GE/Opt Isol	Yes	Yes
VG	0U0-VG503D	GE/Opt Isol	Yes	Yes
VG	0U0-VG503E	GE/Opt Isol	Yes	Yes
VG	0U0-VG503F	GE/Opt Isol	Yes	Yes
VG	0U0-VG504A	GE/Opt Isol	Yes	Yes
VG	0U0-VG504B	GE/Opt Isol	Yes	Yes
VG	0U0-VG504C	GE/Opt Isol	Yes	Yes
VG	0U0-VG504D	GE/Opt Isol	Yes	Yes
VG	0U0-VG504E	GE/Opt Isol	Yes	Yes
VG	0U0-VG504F	GE/Opt Isol	Yes	Yes
VG	0U0-VG505A	GE/Opt Isol	Yes	Yes
VG	0U0-VG505B	GE/Opt Isol	Yes	Yes
VG	0U0-VG505C	GE/Opt Isol	Yes	Yes
VG	0U0-VG505D	GE/Opt Isol	Yes	Yes
VG	0U0-VG505E	GE/Opt Isol	Yes	Yes
VG	0U0-VG505F	GE/Opt Isol	Yes	Yes
VG	0U0-VG507A	GE/Opt Isol	Yes	Yes
VG	0U0-VG507B	GE/Opt Isol	Yes	Yes
VG	0U0-VG507C	GE/Opt Isol	Yes	Yes
VG	0U0-VG507D	GE/Opt Isol	Yes	Yes
VG	0U0-VG507E	GE/Opt Isol	Yes	Yes
VG	0U0-VG507F	GE/Opt Isol	Yes	Yes
VG	0U0-VG509A	GE/Opt Isol	Yes	Yes
VG	0U0-VG509B	GE/Opt Isol	Yes	Yes
VG	0U0-VG510A	GE/Opt Isol	Yes	Yes
VG	0U0-VG510B	GE/Opt Isol	Yes	Yes
VG	0U0-VG513A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	0U0-VG513B	GE/Opt Isol	Yes	Yes
VG	0U0-VG513C	GE/Opt Isol	Yes	Yes
VG	0U0-VG513D	GE/Opt Isol	Yes	Yes
VG	0U0-VG513E	GE/Opt Isol	Yes	Yes
VG	0U0-VG513F	GE/Opt Isol	Yes	Yes
VG	0U0-VG513G	GE/Opt Isol	Yes	Yes
VG	0U0-VG513H	GE/Opt Isol	Yes	Yes
VG	0U0-VG513J	GE/Opt Isol	Yes	Yes
VG	0U0-VG513K	GE/Opt Isol	Yes	Yes
VG	0U0-VG513L	GE/Opt Isol	Yes	Yes
VG	0U0-VG513M	GE/Opt Isol	Yes	Yes
VG	0U0-VG513N	GE/Opt Isol	Yes	Yes
VG	0U0-VG514A	GE/Opt Isol	Yes	Yes
VG	0U0-VG514B	GE/Opt Isol	Yes	Yes
VG	0U0-VG514C	GE/Opt Isol	Yes	Yes
VG	0U0-VG514D	GE/Opt Isol	Yes	Yes
VG	0U0-VG514E	GE/Opt Isol	Yes	Yes
VG	0U0-VG514F	GE/Opt Isol	Yes	Yes
VG	0U0-VG514G	GE/Opt Isol	Yes	Yes
VG	0U0-VG514H	GE/Opt Isol	Yes	Yes
VG	0U0-VG514J	GE/Opt Isol	Yes	Yes
VG	0U0-VG514K	GE/Opt Isol	Yes	Yes
VG	0U0-VG514L	GE/Opt Isol	Yes	Yes
VG	0U0-VG514M	GE/Opt Isol	Yes	Yes
VG	0U0-VG514N	GE/Opt Isol	Yes	Yes
VG	0U0-VG514P	GE/Opt Isol	Yes	Yes
VG	0U0-VG514R	GE/Opt Isol	Yes	Yes
VG	0U0-VG515A	GE/Opt Isol	Yes	Yes
VG	0U0-VG515B	GE/Opt Isol	Yes	Yes
VG	0U0-VG515C	GE/Opt Isol	Yes	Yes
VG	0U0-VG515D	GE/Opt Isol	Yes	Yes
VG	0U0-VG515E	GE/Opt Isol	Yes	Yes
VG	0U0-VG515F	GE/Opt Isol	Yes	Yes
VG	0U0-VG515G	GE/Opt Isol	Yes	Yes
VG	0U0-VG515H	GE/Opt Isol	Yes	Yes
VG	0U0-VG515J	GE/Opt Isol	Yes	Yes
VG	0U0-VG515K	GE/Opt Isol	Yes	Yes
VG	0U0-VG516A	GE/Opt Isol	Yes	Yes
VG	0U0-VG516B	GE/Opt Isol	Yes	Yes
VG	0U0-VG516C	GE/Opt Isol	Yes	Yes
VG	0U0-VG516D	GE/Opt Isol	Yes	Yes
VG	0U0-VG516E	GE/Opt Isol	Yes	Yes
VG	0U0-VG516F	GE/Opt Isol	Yes	Yes
VG	0U0-VG516G	GE/Opt Isol	Yes	Yes
VG	0U0-VG516H	GE/Opt Isol	Yes	Yes
VG	0U0-VG516J	GE/Opt Isol	Yes	Yes
VQ	0U0-VQ504A	GE/Opt Isol	Yes	Yes
VQ	0U0-VQ504B	GE/Opt Isol	Yes	Yes
VQ	0U0-VQ505A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VQ	0UQ-VQ505B	GE/Opt Isol	Yes	No
VQ	0UQ-VQ505C	GE/Opt Isol	Yes	Yes
VQ	0UQ-VQ505D	GE/Opt Isol	Yes	Yes
VQ	0UQ-VQ512A	GE/Opt Isol	Yes	Yes
VQ	0UQ-VQ512B	GE/Opt Isol	Yes	Yes
VQ	0UQ-VQ513D	GE/Opt Isol	Yes	Yes
PR	0UT-PR008A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0UT-PR008B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0UT-PR012A	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
PR	0UT-PR012B	Ebrln/Rad Mon Sys AXM-1	Yes	Yes
VA	0VA01Y	Papco/Parallel Blade Dmpr	Yes	Yes
VA	0VA02YA	Papco/Btrfly Dmpr	Yes	Yes
VA	0VA02YB	Papco/Btrfly Dmpr	Yes	Yes
VA	0VA04Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA05Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA06Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA07Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA08Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA09Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA10Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA11Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA12Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA13Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA14Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA16Y	Ruskin/Fire Dmpr	Yes	Yes
VA	0VA17Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA18Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA19Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA22Y	Balancing Dmpr	Yes	Yes
VA	0VA23Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA24Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA25Y	Papco/LP Backdraft Dmpr	Yes	Yes
VA	0VA26Y	Papco/LP Backdraft Dmpr	Yes	Yes
VA	0VA27Y	Papco/LP Backdraft Dmpr	No	Yes
VA	0VA32Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA33Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA35Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA36Y	Ruskin/Fire Dmpr	Yes	Yes
VA	0VA37Y	Ruskin/Fire Dmpr	Yes	Yes
VA	0VA38Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA42Y	Ruskin/Fire Dmpr	Yes	Yes
VA	0VA45Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA47YA	Papco/Opposed Bld Dmpr	Yes	Yes
VA	0VA47YB	Papco/Opposed Bld Dmpr	Yes	Yes
VA	0VA48Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA49YA	Papco/Parallel Bld Dmpr	Yes	Yes
VA	0VA49YB	Papco/Parallel Bld Dmpr	Yes	Yes
VA	0VA51Y	Papco/Opposed Bld Dmpr	Yes	Yes
VA	0VA52Y	Ruskin/Balancing Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VA	0VA53Y	Papco/LP Backdraft Dmpr	Yes	Yes
VA	0VA57Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA58Y	Papco/Opposed Bld Dmpr	Yes	Yes
VA	0VA59Y	Ruskin/Opposed Bld Dmpr	Yes	Yes
VA	0VA59Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VA60Y	Papco/Parallel Bld Dmpr	Yes	Yes
VA	0VA61Y	Papco/Parallel Bld Dmpr	No	Yes
VA	0VA62Y	Papco/LP Backdraft Dmpr	Yes	Yes
VA	0VA64Y	Papco/Parallel Bld Dmpr	Yes	Yes
VA	0VA77Y	PlmnCnst/FD-100H	Yes	Yes
VA	0VA78Y	PlmnCnst/FD-100H	No	Yes
VA	0VA79Y	PlmnCnst/FD-100H	Yes	Yes
VA	0VA80Y	PlmnCnst/FD-200H	Yes	Yes
VA	0VA81Y	PlmnCnst/FD-100H	Yes	Yes
VA	0VA82Y	PlmnCnst/FD-100V	Yes	Yes
VA	0VA83YA	PlmnCnst/FD-200V	Yes	Yes
VA	0VA83YB	PlmnCnst/FD-400V	Yes	Yes
VA	0VA84Y	PlmnCnst/FD-100V	Yes	Yes
VA	0VA85YA	PlmnCnst/FD-100V	Yes	Yes
VA	0VA85YB	PlmnCnst/FD-200V	Yes	Yes
VA	0VA85YC	PlmnCnst/FD-200V	Yes	Yes
VA	0VA85YD	PlmnCnst/FD-400V	Yes	Yes
VA	0VA86YB	PlmnCnst/FD-100V	Yes	Yes
VA	0VA86YC	PlmnCnst/FD-200V	Yes	Yes
VA	0VA86YD	PlmnCnst/FD-100V	Yes	Yes
VA	0VA87Y	PlmnCnst/FD-100V	Yes	Yes
VC	0VC-12XA	Zack/Silencers	Yes	Yes
VC	0VC-12XB	Zack/Silencers	Yes	Yes
VC	0VC-20XA	Zack/Silencers	Yes	Yes
VC	0VC-20XB	Zack/Silencers	Yes	Yes
VC	0VC-20XC	Zack/Silencers	Yes	Yes
VC	0VC-20XD	Zack/Silencers	Yes	Yes
VC	0VC-20XE	Zack/Silencers	Yes	Yes
VC	0VC-20XF	Zack/Silencers	Yes	Yes
VC	0VC-20XG	Zack/Silencers	Yes	Yes
VC	0VC-20XH	Zack/Silencers	Yes	Yes
VC	0VC-20XJ	Zack/Silencers	Yes	Yes
VC	0VC-20XK	Zack/Silencers	Yes	Yes
VC	0VC-20XL	Zack/Silencers	Yes	Yes
VC	0VC-20XM	Zack/Silencers	Yes	Yes
VC	0VC-20XN	Zack/Silencers	Yes	Yes
VC	0VC-20XP	Zack/Silencers	Yes	Yes
VC	0VC001A	Valcor/Sol Vlv V526-6310-6	Yes	Yes
VC	0VC001B	Valcor/Sol Vlv V526-6310-6	Yes	Yes
VC	0VC001YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC001YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC002A	Valcor/Sol Vlv V526-6310-6	Yes	Yes
VC	0VC002B	Valcor/Sol Vlv V526-6310-6	Yes	Yes
VC	0VC002YA	Papco/Opposed Blade Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0VC002YB	Papco/Opposed Blade Dmpr	Yes	Yes
VC	0VC003A	Valcor/Sol Vlv V525-6220-2	Yes	Yes
VC	0VC003B	Valcor/Sol Vlv V525-6220-2	Yes	Yes
VC	0VC003YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC003YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC004A	AD/6" G1b Vlv	Yes	No
VC	0VC004B	AD/6" G1b Vlv	Yes	No
VC	0VC004YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC004YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC005YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC005YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC006YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC006YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC008YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC008YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC010A(L)	Namco/EA180	Yes	Yes
VC	0VC010A(V)	Fshr/2" AQ G1b Vlv	Yes	Yes
VC	0VC010B(L)	Namco/EA180	No	Yes
VC	0VC010B(V)	Fshr/2" AQ G1b Vlv	Yes	Yes
VC	0VC019YA	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC019YB	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC01MA	Leslie/Strainer Y-Type	Yes	Yes
VC	0VC01MB	Leslie/Strainer Y-Type	Yes	Yes
VC	0VC020YA	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC020YB	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC021YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC021YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC022A(V)	Fshr/1.5" AQ G1b Vlv	Yes	Yes
VC	0VC022B(V)	Fshr/1.5" AQ G1b Vlv	Yes	Yes
VC	0VC022YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC022YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC024YA	Papco/Opposed Blade Dmpr	Yes	Yes
VC	0VC024YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC025A	Dresser/1" SRV	Yes	Yes
VC	0VC025B	Dresser/1" SRV	Yes	Yes
VC	0VC025YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC025YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC027YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC027YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC028YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC028YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC02AA	Nthrm/Stndby Gas Sys Htr	Yes	Yes
VC	0VC02AB	Nthrm/Stndby Gas Sys Htr	Yes	Yes
VC	0VC030YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC030YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC031YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC031YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC032YA	Ruskin/Fire Dmpr	Yes	No
VC	0VC033YA	Papco/Opposed Bld Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0VC033YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC034YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC034YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC036YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC036YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC037YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC037YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC039YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC039YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC03CA(F)	BF/Fan 54E9	Yes	Yes
VC	0VC03CA(M)	Wsths/150 HP Mtr	Yes	Yes
VC	0VC03CA(M2)	BF/Vibration Isol For Fan	Yes	Yes
VC	0VC03CB(F)	BF/Fan 54E9	Yes	Yes
VC	0VC03CB(M)	Wsths/150HP Mtr	Yes	Yes
VC	0VC03CB(M2)	BF/Vibration Isol For Fan	Yes	Yes
VC	0VC040YA	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC040YB	Papco/HP Backdraft Dmpr	Yes	Yes
VC	0VC046Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC047Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC048YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC048YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC049YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC049YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC04CA	Wsths/TBAM 125HP	Yes	Yes
VC	0VC04CA(F)	BF/TypS/4809 Cont Rm Ret Fan	Yes	Yes
VC	0VC04CA(M2)	BF/Vibration Isolation	Yes	No
VC	0VC04CB	Wsths/TBAM 125HP	Yes	Yes
VC	0VC04CB(F)	BF/TypS/4809 Cont Rm Ret Fan	Yes	Yes
VC	0VC04CB(M2)	BF/Vibration Isolation	Yes	No
VC	0VC050Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC051Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC052Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC053Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC056A(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC056B(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC057A(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC057B(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC057Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC058A(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC058B(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC059A(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC059B(O)	Valcor/2 1/2" Sol Vlv	Yes	Yes
VC	0VC059Y	Ruskin/Balancing Dmpr	Yes	Yes
OV	0VC05CA(F)	AAF/Fan	Yes	Yes
VC	0VC05CB(F)	AAF/Fan	Yes	Yes
VP	0VC062Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC063Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0VC069Y	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC070Y	Papco/Opposed Bld Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0VC07SA	AAF/Supply Air Filter Pack(A)	Yes	Yes
VC	0VC07SB	AAF/Supply Air Filter Pack(B)	Yes	Yes
VC	0VC081YA	Papco/Opposed Blade Dmpr	Yes	Yes
VC	0VC081YB	Papco/Opposed Blade Dmpr	Yes	Yes
VC	0VC08PA(M)	SmnsAls/Pmp Mtr 326T	Yes	Yes
VC	0VC08PA(P)	Gld/Pmp 3196MT	Yes	Yes
VC	0VC08PB(M)	SmnsAls/Pmp Mtr 326T	Yes	Yes
VC	0VC08PB(P)	Gld/Pmp 3196MT	Yes	Yes
VC	0VC09SA	AAF/Make Up Air Filter Pack(A)	Yes	Yes
VC	0VC09SB	AAF/Make Up Air Filter Pack(B)	Yes	Yes
VC	0VC09YA	Ame.WarVent/7402 Dmprs	Yes	Yes
VC	0VC09YB	Amer.WarVent/7402 Dmprs	Yes	Yes
VC	0VC101Y	Papco/Backdraft Dmpr	Yes	Yes
VC	0VC103Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC104Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC105Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC10SA	AAF/Coil Cab	Yes	Yes
VC	0VC10SB	AAF/Coil Cab	Yes	Yes
VC	0VC10YA	Amer.WarVent/7402 Dmpr	Yes	Yes
VC	0VC10YB	Amer.WarVent/7402 Dmprs	Yes	Yes
VC	0VC111Y	Rurkin/Fire Dmpr	Yes	Yes
VC	0VC114YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC114YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC115YA	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC115YB	Papco/Opposed Bld Dmpr	Yes	Yes
VC	0VC116Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC11YA	Amer.WarVent/7402 Dmprs	Yes	Yes
VC	0VC11YB	Amer.WarVent/7402 Dmprs	Yes	Yes
VC	0VC121Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC12YA	AAF/Damper	Yes	Yes
VC	0VC12YB	AAF/Damper	Yes	Yes
VC	0VC132YA	PlmnCnst/FD-200V	No	Yes
VC	0VC132YB	PlmnCnst/FD-200V	No	Yes
VC	0VC134YA	PlmnCnst/FD-200V	Yes	Yes
VC	0VC134YB	PlmnCnst/FD-400V	Yes	Yes
VC	0VC135YA	PlmnCnst/FD-400V	Yes	Yes
VC	0VC135YB	PlmnCnst/FD-400V	Yes	Yes
VC	0VC136YA	PlmnCnst/FD-200V	Yes	Yes
VC	0VC136YB	PlmnCnst/FD-400V	Yes	Yes
VC	0VC137YA	PlmnCnst/FD-200V	Yes	Yes
VC	0VC137YB	PlmnCnst/FD-400V	Yes	Yes
VC	0VC138YA	PlmnCnst/FD-200V	No	Yes
VC	0VC138YB	PlmnCnst/FD-400V	No	Yes
VC	0VC139YA	PlmnCnst/FD-200V	No	Yes
VC	0VC139YB	PlmnCnst/FD-400V	No	Yes
VC	0VC13CA	Carrier/Chiller A 19EA	Yes	Yes
VC	0VC13CB	Carrier/Chiller B 19EA	Yes	Yes
VC	0VC13YA	AAF/Damper	Yes	Yes
VC	0VC13YB	AAF/Damper	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0VC140YA	PlmnCnst/FD-400V	Yes	Yes
VC	0VC140YB	PlmnCnst/FD-400V	Yes	Yes
VC	0VC14TA	Reco/24"0.0x36"Lngx60Gal	Yes	Yes
VC	0VC14TB	Reco/24"0.0x36"Lngx60Gal	Yes	Yes
VC	0VC14YA	AAF/Damper	Yes	Yes
VC	0VC14YB	AAF/Damper	Yes	Yes
VC	0VC15YA	AAF/Damper	Yes	Yes
VC	0VC15YB	AAF/Damper	Yes	Yes
VC	0VC16YA	AAF/Damper	Yes	Yes
VC	0VC16YB	AAF/Damper	Yes	Yes
VC	0VC17YA	AAF/Damper	Yes	Yes
VC	0VC17YB	AAF/Damper	Yes	Yes
VC	0VC18AA	AAF/Spcl Coil Cab	Yes	Yes
VC	0VC18AB	AAF/Spcl Coil Cab	Yes	Yes
VC	0VC18CA(F)	BF/22A5 Arrangement4	Yes	Yes
VC	0VC18CA(M)	Wsths/TBAM2HP1750R	Yes	Yes
VC	0VC18CB(F)	BF/22A5 Arrangement4	Yes	Yes
VC	0VC18CB(M)	Wsths/TBAM2HP1750R	Yes	Yes
VC	0VC18SA	AAF/Coil Cab	Yes	Yes
VC	0VC18SB	AAF/Coil Cab	Yes	Yes
VC	0VC18YA	AAF/Damper	Yes	Yes
VC	0VC18YB	AAF/Damper	Yes	Yes
VC	0VC21FA	AAF/Pre-Filter	Yes	Yes
VC	0VC21FB	AAF/Pre Filter	Yes	Yes
VC	0VC22FA	AAF/Med Eff Filter	Yes	Yes
VC	0VC22FB	AAF/Med Eff Filter	Yes	Yes
VC	0VC239YB	PlmnCnst/FD-400V	No	Yes
VC	0VC23FA	AAF/Upstream Hepa Filter	No	Yes
VC	0VC23FB	AAF/Upstream Hepa Filter	No	Yes
VC	0VC23YA	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC23YB	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC24FA	AAF/Charcoal Absorb	Yes	Yes
VC	0VC24FB	/Charcoal Absorb	Yes	Yes
VC	0VC25FA	AAF/Downstream Hepa Filter	No	Yes
VC	0VC25FB	/Hepa Filters	Yes	Yes
VC	0VC26FA	AAF/Med Eff Filter	Yes	Yes
VC	0VC26FB	AAF/Med Eff Filter	Yes	Yes
VC	0VC26YA	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC27FA	AAF/Charcoal Absorb	Yes	Yes
VC	0VC27FB	AAF/Charcoal Absorb	Yes	Yes
VC	0VC29YB	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC35YA	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC35YB	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC38YB	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC67Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC82Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC83Y	Ruskin/Fire Dmpr	Yes	Yes
VC	0VC85Y	Ruskin/Fire Dmpr	Yes	Yes
VF	0VF66Y	PlmnCnst/FD-100V	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	0VG01CA(F)	BF/AX 38A9 Fan	Yes	Yes
VG	0VG01CA(M)	Wsths/TBAM 5HP Mtr	Yes	Yes
VG	0VG01CB(F)	BF/AX 38A9 Fan	Yes	Yes
VG	0VG01CB(M)	Wsths/TBAM 5HP Mtr	Yes	Yes
VG	0VG01SA	AAF/Stby Gas Trt Ctr A	Yes	Yes
VG	0VG01SB	AAF/Stby Gas Trt Ctr B	Yes	Yes
VG	0VG01YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	0VG01YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	0VG02CA(F)	Wsths/Mod 411A & 505 Fans	Yes	Yes
VG	0VG02CA(M)	Wsths/TBDP	Yes	Yes
VG	0VG02CB(F)	Wsths/Mod 411A & 505 Fans	Yes	Yes
VG	0VG02CB(M)	Wsths/TBDP	Yes	Yes
VG	0VG02YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	0VG02YB	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG03CA(F)	Wsths/Mod 411A & 505 Fans	Yes	Yes
VG	0VG03CA(M)	Wsths/TBFC	Yes	Yes
VG	0VG03CB(F)	Wsths/Mod 411A & 505 Fans	Yes	Yes
VG	0VG03CB(M)	Wsths/TBFC	Yes	Yes
VG	0VG03YA	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG03YB	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG04AA	Nthrm/Stndby Gas Sys Htr	Yes	Yes
VG	0VG04AB	Nthrm/Stndby Gas Sys Htr	Yes	Yes
VG	0VG04YA	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG04YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	0VG05CA(F)	BF/38A9	Yes	Yes
VG	0VG05CA(M)	BF-Wsths/TBAM 5 HP Fan Mtr	Yes	Yes
VG	0VG05CB(F)	BF/38A9	Yes	Yes
VG	0VG05CB(M)	BF-Wsths/TBAM 5HP Fan Mtr	Yes	Yes
VG	0VG05FA	AAF/Demister	Yes	Yes
VG	0VG05FB	AAF/Demister	Yes	Yes
VG	0VG05SA	AAF/Coil Cab	Yes	Yes
VG	0VG05SB	AAF/Cubicle Cooler	Yes	Yes
VG	0VG05YA	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG05YB	Papco/Btrfly Dmpr	Yes	Yes
VG	0VG06FA	AAF/Pre Filter	No	Yes
VG	0VG06FB	AAF/Pre Filter	No	Yes
VG	0VG07FA	AAF/HEPA Filter	No	Yes
VG	0VG07FB	AAF/HEPA Filter	Yes	Yes
VG	0VG07SA	AAF/Coil Cab	Yes	Yes
VG	0VG07SB	AAF/Coil Cab	Yes	Yes
VG	0VG08FA	AAF/Charcoal Absorb	Yes	Yes
VG	0VG08FB	AAF/Charcoal Absorb	Yes	Yes
VG	0VG10YA	Papco/SL100BPL HVAC Dmpr	Yes	Yes
VG	0VG10YB	Papco/SL100BPL HVAC Dmpr	Yes	Yes
VG	0VG11FA	AAF/HEPA Filter	No	Yes
VG	0VG11FB	AAF/HEPA Filter	No	Yes
VJ	0VJ026YA	Papco/Parallel Bld Dmpr	Yes	Yes
VJ	0VJ026YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL01YA	Papco/Parallel Bld Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VL	0VL01YB	Papco/Parallel Dmpr	Yes	Yes
VL	0VL08YA	Papco/Opposed Bld Dmpr	Yes	Yes
VL	0VL08YB	Papco/Opposed Bld Dmpr	Yes	Yes
VL	0VL16YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL16YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL17Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	0VL25Y	Papco/LP Backdraft Dmpr	Yes	No
VL	0VL29Y	Papco/LP Backdraft Dmpr	Yes	Yes
VL	0VL32YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL32YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL33YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL33YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL34Y	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL36Y	Papco/Opposed Blade Dmpr	Yes	Yes
VL	0VL44YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL44YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL49Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL50Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL53Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL54Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL55Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL56Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL57Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL59Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL60Y	Ruskin/Balancing Dmpr	Yes	Yes
VL	0VL63YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL63YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL64YA	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL64YB	Papco/Parallel Bld Dmpr	Yes	Yes
VL	0VL74YA	PlmnCnst/FD-400V	Yes	Yes
VL	0VL74YB	PlmnCnst/FD-400V	Yes	Yes
VL	0VL75Y	PlmnCnst/FD-200V	Yes	Yes
VL	0VL76Y	PlmnCnst/FD-400V	Yes	Yes
VL	0VL77Y	PlmnCnst/FD-100V	Yes	Yes
VL	0VL78Y	PlmnCnst/FD-200V	Yes	Yes
VL	0VL79YA	PlmnCnst/FD-200V	Yes	Yes
VL	0VL79YB	PlmnCnst/FD-400V	Yes	Yes
VL	0VL80Y	PlmnCnst/FD-200V	Yes	Yes
VD	0VD05YA	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD05YB	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD05YC	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD06YA	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD06YB	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD06YC	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD07YA	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD07YB	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD07YC	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD08YA	Papco/Parallel Bld Dmpr	Yes	Yes
VD	0VD08YB	Papco/Parallel Bld Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VQ	0VQ08YC	Papco/Parallel Bld Dmpr	Yes	Yes
VQ	0VQ11Y	Ruskin/Fire Dmpr	Yes	Yes
VQ	0VQ24YA	Papco/Parallel Bld Dmpr	Yes	Yes
VQ	0VQ24YB	Papco/Opposed Bld Dmpr	Yes	Yes
VW	0VW005YA	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW005YB	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW006YA	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW006YB	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW007YA	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW007YB	Papco/Parallel Bld Dmpr	Yes	Yes
VW	0VW008Y	Ruskin/Balancing Dmpr	Yes	Yes
VW	0VW013Y	Ruskin/Fire Dmpr	Yes	Yes
VW	0VW094Y	Ruskin/Fire Dmpr	Yes	Yes
VW	0VW100Y	Ruskin/Fire Dmpr	Yes	Yes
VW	0VW141Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	0XE-VC018A	MCCPwrs/MDA Chlorine Det	Yes	Yes
VC	0XE-VC018B	MCCPwrs/MDA Chlorine Det	Yes	Yes
VC	0XE-VC095A	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC095B	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC095C	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC095D	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC095E	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC118A	MDAScntf/Chlorine Det	Yes	Yes
VC	0XE-VC118B	MDAScntf/Chlorine Det	Yes	Yes
VC	0XE-VC195A	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC195B	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC195C	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC195D	Pyrtrncs/CA-4	Yes	Yes
VC	0XE-VC195E	Pyrtrncs/CA-4	Yes	Yes
VC	0ZL-VC003AA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003BA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003CA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003DA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003EA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003FA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC003GA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC005A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC006A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC011A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC012A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC014A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC016AA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC016BA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC017A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC022A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC023A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC024A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC025A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC026A	GE/ET-16#127B8177G9	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0ZL-VC068A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC072A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC096A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103AA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103BA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103CA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103DA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103EA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103FA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC103GA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC105A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC106A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC111A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC112A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC114A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC116AA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC116BA	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC117A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC122A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC123A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC124A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC125A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC126A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC168A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC172A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC196A	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC250	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC350	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZL-VC601A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC601B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC604A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC604B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC610A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC610B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC610C	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC610D	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC611A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC611B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC612A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC612B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC616A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC616B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC620A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC620B	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC621A	Carrier/Pos. Light	Yes	Yes
VC	0ZL-VC621B	Carrier/Pos. Light	Yes	Yes
VG	0ZL-VG140	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG141	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG142	GE/ET-16#127B8177G9	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	0ZL-VG143	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG155	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG157	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG159	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG160	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG161	GE/ET-16#127B8177G9	Yes	Yes
VG	0ZL-VG163	GE/ET-16#127B8177G9	Yes	Yes
VC	0ZS-VC003AA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003AB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003BA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003BB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003CA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003CB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003DA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003DB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003EA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003EB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003FA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003FB*	Namco/EA170	Yes	Yes
VC	0ZS-VC003GA*	Namco/EA170	Yes	Yes
VC	0ZS-VC003GB*	Namco/EA170	Yes	Yes
VC	0ZS-VC005A*	Namco/EA170	Yes	Yes
VC	0ZS-VC005B*	Namco/EA170	Yes	Yes
VC	0ZS-VC006A	Namco/EA170	Yes	Yes
VC	0ZS-VC006B	Namco/EA170	Yes	Yes
VC	0ZS-VC011A	Namco/EA170	Yes	Yes
VC	0ZS-VC011B	Namco/EA170	Yes	Yes
VC	0ZS-VC012A*	Namco/EA170	Yes	Yes
VC	0ZS-VC012B*	Namco/EA170	Yes	Yes
VC	0ZS-VC014A	Namco/EA170	Yes	Yes
VC	0ZS-VC014B	Namco/EA170	Yes	Yes
VC	0ZS-VC016AA	Namco/EA180	Yes	Yes
VC	0ZS-VC016AB	Namco/EA180	Yes	Yes
VC	0ZS-VC016BA	Namco/EA180	Yes	Yes
VC	0ZS-VC016BB	Namco/EA180	Yes	Yes
VC	0ZS-VC017A*	Namco/EA180	Yes	Yes
VC	0ZS-VC017B*	Namco/EA180	Yes	Yes
VC	0ZS-VC022A*	Namco/EA170	Yes	Yes
VC	0ZS-VC022B*	Namco/EA170	Yes	Yes
VC	0ZS-VC023A*	Namco/EA170	Yes	Yes
VC	0ZS-VC023AA	Namco/EA170	Yes	Yes
VC	0ZS-VC023B*	Namco/EA170	Yes	Yes
VC	0ZS-VC024A*	Namco/EA170	Yes	Yes
VC	0ZS-VC024B*	Namco/EA170	Yes	Yes
VC	0ZS-VC025A*	Namco/EA170	Yes	Yes
VC	0ZS-VC025B*	Namco/EA170	Yes	Yes
VC	0ZS-VC026A*	Namco/EA170	Yes	Yes
VC	0ZS-VC026B*	Namco/EA170	Yes	Yes
VC	0ZS-VC068A*	Namco/EA170	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
VC	0ZS-VC068B*	Namco/EA170	Yes	Yes
VC	0ZS-VC072A*	Namco/EA170	Yes	Yes
VC	0ZS-VC072B*	Namco/EA170	Yes	Yes
VC	0ZS-VC096A*	Namco/EA170	Yes	Yes
VC	0ZS-VC096B*	Namco/EA170	Yes	Yes
VC	0ZS-VC103AA	Namco/EA170	Yes	Yes
VC	0ZS-VC103AB	Namco/EA170	Yes	Yes
VC	0ZS-VC103BA	Namco/EA170	Yes	Yes
VC	0ZS-VC103BB	Namco/EA170	Yes	Yes
VC	0ZS-VC103CA	Namco/EA170	Yes	Yes
VC	0ZS-VC103CB	Namco/EA170	Yes	Yes
VC	0ZS-VC103DA	Namco/EA170	Yes	Yes
VC	0ZS-VC103DB	Namco/EA170	Yes	Yes
VC	0ZS-VC103EA	Namco/EA170	Yes	Yes
VC	0ZS-VC103EB	Namco/EA170	Yes	Yes
VC	0ZS-VC103FA	Namco/EA170	Yes	Yes
VC	0ZS-VC103FB	Namco/EA170	Yes	Yes
VC	0ZS-VC103GA	Namco/EA170	Yes	Yes
VC	0ZS-VC105A*	Namco/EA170	Yes	Yes
VC	0ZS-VC105B*	Namco/EA170	Yes	Yes
VC	0ZS-VC106A	Namco/EA170	Yes	Yes
VC	0ZS-VC106B	Namco/EA170	Yes	Yes
VC	0ZS-VC111A	Namco/EA170	Yes	Yes
VC	0ZS-VC111B	Namco/EA170	Yes	Yes
VC	0ZS-VC112A*	Namco/EA170	Yes	Yes
VC	0ZS-VC112B*	Namco/EA170	Yes	Yes
VC	0ZS-VC114A	Namco/EA170	Yes	Yes
VC	0ZS-VC114B	Namco/EA170	Yes	Yes
VC	0ZS-VC116AA	Namco/EA170	Yes	Yes
VC	0ZS-VC116AB	Namco/EA170	Yes	Yes
VC	0ZS-VC116AB	Namco/EA180	Yes	Yes
VC	0ZS-VC116BA	Namco/EA180	Yes	Yes
VC	0ZS-VC116BB	Namco/EA180	Yes	Yes
VC	0ZS-VC117A*	Namco/EA180	Yes	Yes
VC	0ZS-VC117B*	Namco/EA180	Yes	Yes
VC	0ZS-VC122A*	Namco/EA170	Yes	Yes
VC	0ZS-VC122AA	Namco/EA170	Yes	Yes
VC	0ZS-VC122B*	Namco/EA170	Yes	Yes
VC	0ZS-VC123A*	Namco/EA170	Yes	Yes
VC	0ZS-VC123B*	Namco/EA170	Yes	Yes
VC	0ZS-VC124A*	Namco/EA170	Yes	Yes
VC	0ZS-VC124B*	Namco/EA170	Yes	Yes
VC	0ZS-VC125A*	Namco/EA170	Yes	Yes
VC	0ZS-VC125B*	Namco/EA170	Yes	Yes
VC	0ZS-VC126A*	Namco/EA170	Yes	Yes
VC	0ZS-VC126B*	Namco/EA170	Yes	Yes
VC	0ZS-VC168A*	Namco/EA170	Yes	Yes
VC	0ZS-VC168AA	Namco/EA170	Yes	Yes
VC	0ZS-VC168B*	Namco/EA170	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VC	0ZS-VC172A*	Namco/EA170	Yes	Yes
VC	0ZS-VC172B*	Namco/EA170	Yes	Yes
VC	0ZS-VC196A*	Namco/EA170	Yes	Yes
VC	0ZS-VC196B*	Namco/EA170	Yes	Yes
VG	0ZS-VG003AA	Namco/EA180	Yes	Yes
VG	0ZS-VG003AA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG003AB	Namco/EA180	Yes	Yes
VG	0ZS-VG003AB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG003BA	Namco/EA180	Yes	Yes
VG	0ZS-VG003BA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG003BB	Namco/EA180	Yes	Yes
VG	0ZS-VG003BB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG004A	Namco/EA180	Yes	Yes
VG	0ZS-VG004A(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG004B	Namco/EA180	Yes	Yes
VG	0ZS-VG004B(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG006AA	Namco/EA180	Yes	Yes
VG	0ZS-VG006AA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG006AB	Namco/EA180	Yes	Yes
VG	0ZS-VG006AB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG006BA	Namco/EA180	Yes	Yes
VG	0ZS-VG006BA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG006BB	Namco/EA180	Yes	Yes
VG	0ZS-VG006BB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG103AA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG103AA*	Namco/EA180	Yes	Yes
VG	0ZS-VG103AB	Namco/EA180	Yes	Yes
VG	0ZS-VG103AB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG103BA	Namco/EA180	Yes	Yes
VG	0ZS-VG103BA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG103EB	Namco/EA180	Yes	Yes
VG	0ZS-VG103BB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG104A	Namco/EA180	Yes	Yes
VG	0ZS-VG104A(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG104B	Namco/EA180	Yes	Yes
VG	0ZS-VG104B(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG106AA	Namco/EA180	Yes	Yes
VG	0ZS-VG106AA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG106AB	Namco/EA180	Yes	Yes
VG	0ZS-VG106AB(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG106BA	Namco/EA180	Yes	Yes
VG	0ZS-VG106BA(LS)	Conax/7F20-11002-03	Yes	Yes
VG	0ZS-VG106BB	Namco/EA180	Yes	Yes
VG	0ZS-VG106BB(LS)	Conax/7F20-11002-03	Yes	Yes
VL	0ZS-VL011A	Namco/EA170	Yes	No
VL	0ZS-VL011B	Namco/EA170	Yes	No
VL	0ZS-VL013A	Namco/EA170	Yes	No
VL	0ZS-VL013B	Namco/EA170	Yes	No
VQ	0ZS-VQ013A	Namco/EA170	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VQ	0ZS-VQ013B	Namco/EA170	Yes	Yes
VQ	0ZS-VQ014A	Namco/EA170	Yes	Yes
VQ	0ZS-VQ014B	Namco/EA170	Yes	Yes
VQ	0ZS-VQ016A	Namco/EA170	Yes	Yes
VQ	0ZS-VQ016B	Namco/EA170	Yes	Yes
VQ	0ZS-VQ017A	Namco/EA170	Yes	Yes
VQ	0ZS-VQ017B	Namco/EA170	Yes	Yes
VQ	0ZS-VQ019A	Namco/EA170	Yes	Yes
VQ	0ZS-VQ019B	Namco/EA170	Yes	Yes
VQ	0ZS-VQ020A	Namco/EA170	Yes	Yes
VQ	0ZS-VQ020B	Namco/EA170	Yes	Yes
CM	1AI-CM171	Foxboro/N257H-2-C	Yes	Yes
CM	1AI-CM172	Foxboro/N257H-2-C	Yes	Yes
CM	1AI-CM173	Foxboro/N257H-2-C	Yes	Yes
CM	1AI-CM174	Foxboro/N257H-2-C	Yes	Yes
AP	1AP04E	Wsths/Swgr	Yes	Yes
AP	1AP04EA	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EB	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EC	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04ED	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EE	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EF	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EG	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EH	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EJ	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EK	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP04EL	Wsths/Swgr Bus1A Bkr 75DHP500	Yes	Yes
AP	1AP05E	Wsths/Swgr	Yes	Yes
AP	1AP05EA	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EB	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EC	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05ED	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EE	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EF	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EG	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EH	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EJ	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP05EK	Wsths/Swgr Bus1B Bkr 75DHP500	Yes	Yes
AP	1AP07E	Wsths/Swgr	Yes	Yes
AP	1AP07EA	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EB	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EC	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07ED	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EE	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EF	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EG	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EH	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EJ	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes
AP	1AP07EK	Wsths/Swgr Bus1A Bkr 50DHP350	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
AP	1AP09E	Wsths/Swgr	Yes	Yes
AP	1AP09EA	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EB	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EC	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09ED	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EE	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EF	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EG	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EH	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EJ	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP09EK	Wsths/Swgr Bus1B Bkr 50DHP350	Yes	Yes
AP	1AP11E	Gld-BB/480V Substn	Yes	Yes
AP	1AP12E	Gld-BB/480V Substn	Yes	Yes
AP	1AP29E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	1AP30E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	1AP31E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	1AP41E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP42E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP60E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	1AP61E	Gld-TIE/5600 Series MCC	Yes	Yes
AP	1AP72E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP73E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP74E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP75E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP76E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP77E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP78E	Gld-ITE/5600 Series MCC	Yes	Yes
AP	1AP93E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP94E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP95E	ITE/Series 5600 MCC	Yes	Yes
AP	1AP96E	ITE/Series 5600 MCC	Yes	Yes
NB	1B21-A001A	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A001B	Richmond Eng/Tank 20" AirAcc	Yes	Yes
MS	1B21-A001C	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A001D	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A002A	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A002B	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A002C	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A002D	Richmond Eng/Tank 20" AirAcc	Yes	Yes
NB	1B21-A003B	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003C	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003D	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003E	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003H	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003K	Reco/55Gal Tank	Yes	Yes
NB	1B21-A003S	Reco/55Gal Tank	Yes	Yes
NB	1B21-A004A	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004F	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004G	Richmond Eng/Tank 12" AirAcc	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-A004J	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004L	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004M	Richmond Eng/Tank 12" AirAcc	Yes	No
NB	1B21-A004N	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004P	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A004R	Richmond Eng/Tank 12" AirAcc	Yes	Yes
NB	1B21-A300A	Reco/12" Air Accum Vessel	Yes	Yes
NB	1B21-A300B	Reco/12" Air Accum Vessel	Yes	Yes
NB	1B21-D301A	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301B	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301C	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301D	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301E	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301F	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301G	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301H	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301J	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301K	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301L	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301M	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301N	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301P	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301R	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D301S	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312A	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312B	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312C	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312D	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312E	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312F	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312G	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312H	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312J	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312K	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312L	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312M	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312N	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312P	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312R	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D312S	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372A	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372B	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372C	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372D	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372E	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372F	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372G	MetalBellows/Flx Hose Ass	Yes	Yes
NB	1B21-D372H	MetalBellows/Flx Hose Ass	Yes	Yes
HC	1B21-E300	Amr Mnr1/10TonMSIV&SRV Rem Mnr1	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-F001(A)	Lmt/SMB-00-10	Yes	Yes
NB	1B21-F001(V)	Rckw1/2" G1b V1v	Yes	Yes
NB	1B21-F002(A)	Lmt/SMB-00-10	Yes	Yes
NB	1B21-F002(V)	Rckw1/2" G1b V1v	Yes	Yes
NB	1B21-F005(A)	Lmt/SMB-00-10	Yes	Yes
NB	1B21-F005(V)	Rckw1/2" G1v V1v	Yes	Yes
FW	1B21-F011A(V)	AD/18" Gt V1v	Yes	Yes
NB	1B21-F011B(V)	AD/18" Gt V1v	Yes	Yes
MS	1B21-F016(A)	Lmt/SMB-000	Yes	Yes
MS	1B21-F016(V)	AD/3" Gt V1v	Yes	Yes
NB	1B21-F019(A)	Lmt/SMB-000	Yes	Yes
NB	1B21-F019(V)	AD/3" Gt V1v	Yes	Yes
MS	1B21-F022A(L)	Namco/EA740	Yes	Yes
NB	1B21-F022A(LS)	Conax/7F20-11002-01&11003-01	Yes	Yes
NB	1B21-F022A(OS)	Conax/	Yes	Yes
NB	1B21-F022A(V)	AtwdMr1/24" G1b V1v	Yes	Yes
NB	1B21-F022B(L)	Namco/EA740	Yes	Yes
NB	1B21-F022B(LS)	Conax/7F20-11002-01&11003-01	Yes	Yes
NB	1B21-F022B(OS)	Conax/	Yes	Yes
NB	1B21-F022B(V)	AtwdMr1/24" G1b V1v	Yes	Yes
NB	1B21-F022C(L)	Namco/EA740	Yes	Yes
NB	1B21-F022C(LS)	Conax/7F20-11002-01&11003-01	Yes	Yes
NB	1B21-F022C(OS)	Conax/	Yes	Yes
NB	1B21-F022C(V)	AtwdMr1/24" G1b V1v	Yes	Yes
NB	1B21-F022D(L)	Namco/EA740	Yes	Yes
NB	1B21-F022D(LS)	Conax/7F20-11002-01&11003-01	Yes	Yes
NB	1B21-F022D(OS)	Conax/	Yes	Yes
NB	1B21-F022D(V)	AtwdMr1/24" G1b V1v	Yes	Yes
MS	1B21-F028A(L)*	Namco/EA740	Yes	Yes
NB	1B21-F028A(LS)	Conax/7F20-11002-01	Yes	Yes
NB	1B21-F028A(OS)	Conax/7F20-11003-01	Yes	Yes
NB	1B21-F028A(V)	AtwdMr1/24" G1b V1v	Yes	Yes
MS	1B21-F028B(L)*	Namco/EA740	Yes	Yes
MS	1B21-F028B(LS)	Conax/7F20-11002-01	Yes	Yes
MS	1B21-F028B(OS)	Conax/7F20-11003-01	Yes	Yes
MS	1B21-F028B(V)	AtwdMr1/24" G1b V1v	Yes	Yes
MS	1B21-F028C(L)*	Namco/EA740	Yes	Yes
MS	1B21-F028C(LS)	Conax/7F20-11002-01	Yes	Yes
MS	1B21-F028C(OS)	Conax/7F20-11003-01	Yes	Yes
MS	1B21-F028C(V)	AtwdMr1/24" G1b V1v	Yes	Yes
MS	1B21-F028D(L)*	Namco/EA740	Yes	Yes
NB	1B21-F028D(LS)	Conax/7F20-11002-01	Yes	Yes
NB	1B21-F028D(OS)	Conax/7F20-11003-01	Yes	Yes
NB	1B21-F028D(V)	AtwdMr1/24" G1b V1v	Yes	Yes
MS	1B21-F032A(L)	Namco/EA180	Yes	Yes
NB	1B21-F032A(LS)	Conax/7F20-11000-01	Yes	Yes
NB	1B21-F032A(V)	AD/20" Ck V1v	Yes	Yes
MS	1B21-F032B(L)	Namco/EA180	Yes	Yes
MS	1B21-F032B(LS)	Conax/7F20-11000-01	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
MS	1B21-F032B(V)	AD/20" Ck Vlv	Yes	Yes
NB	1B21-F037A	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037B	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037C	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037D	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037E	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037F	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037G	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037H	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037J	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037K	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037L	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037M	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037N	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037P	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037R	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F037S	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F040	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F041A(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041A(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041B(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041B(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041C(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041C(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041D(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041D(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041F(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041F(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041G(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041G(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F041L(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F041L(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F047A(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F047A(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F047B(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F047B(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F047C(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F047C(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F047D(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F047D(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F047F(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F047F(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F051B(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F051B(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F051C(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F051C(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F051D(O)	Dkrs/Srv Sol/6A39	No	Yes
NB	1B21-F051D(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F051G(O)	Dkrs/Srv Sol/6A39	No	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-F051G(V)	Dkrs/G-471-6/125.04	No	Yes
NB	1B21-F065A(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F065A(V)	AD/20" Gt Vlv	Yes	Yes
NB	1B21-F065B(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F065B(V)	AD/20" Gt Vlv	Yes	Yes
NB	1B21-F067A(A)	Lmt/SMB-00-10-4T	Yes	Yes
NB	1B21-F067A(V)	Rckwl/1.5" Glb Vlv	Yes	Yes
NB	1B21-F067B(A)	Lmt/SMB-00-10-4T	Yes	Yes
NB	1B21-F067B(V)	Rckwl/1.5" Glb Vlv	Yes	Yes
NB	1B21-F067C(A)	Lmt/SMB-00-10-4T	Yes	Yes
NB	1B21-F067C(V)	Rckwl/1.5" Glb Vlv	Yes	Yes
NB	1B21-F067D(A)	Lmt/SMB-00-10-4T	Yes	Yes
NB	1B21-F067D(V)	Rckwl/1.5" Glb Vlv	Yes	Yes
NB	1B21-F068(A)	Lmt/SMB-00-10	Yes	Yes
NB	1B21-F068(V)	Rckwl/2" Glb Vlv	Yes	Yes
MS	1B21-F069(L)	Namco/EA180	Yes	Yes
MS	1B21-F069(LS)	Conax/7F20-11000-01	Yes	Yes
MS	1B21-F069(O)	Asco/2068323U	Yes	Yes
MS	1B21-F069(OS)	Conax/7F20-11001-01	Yes	Yes
MS	1B21-F069(V)	Fshr/1"AD Glb Vlv	Yes	Yes
NB	1B21-F078A	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078B	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078C	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078D	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078E	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078F	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078G	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078H	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078J	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078K	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078L	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078M	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078N	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078P	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078R	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F078S	AndersonGreen/10" VacRelVlv	Yes	Yes
NB	1B21-F098A(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F098A(V)	AD/24" Gt Vlv	Yes	Yes
NB	1B21-F098B(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F098B(V)	AD/24" Gt Vlv	Yes	Yes
NB	1B21-F098C(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F098C(V)	AD/24" Gt Vlv	Yes	Yes
NB	1B21-F098D(A)	Lmt/SMB-3	Yes	Yes
NB	1B21-F098D(V)	AD/24" Gt Vlv	Yes	Yes
NB	1B21-F379A	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379B	GPE/2" Val Rel Vlv	Yes	Yes
NB	1B21-F379C	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379D	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379E	GPE/2" Vac Rel Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-F379F	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379G	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379H	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F379J	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F379K	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F379L	GPE/Vac Rel Vlv	Yes	Yes
NB	1B21-F379M	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379N	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379P	GPE/2" Vac Rel Vlv	Yes	Yes
NB	1B21-F379Q	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F379R	GPE/2" 600# Chk Vac Rlf Vlv	Yes	Yes
NB	1B21-F381A	Valcor/.75" Sol Vlv	Yes	Yes
NB	1B21-F381B	Valcor/.75" Sol Vlv	Yes	Yes
NB	1B21-F381C	Valcor/.75" Sol Vlv	Yes	Yes
NB	1B21-F381D	Valcor/.75" Sol Vlv	Yes	Yes
NB	1B21-F388	Valcor/.75" Sol Vlv	Yes	Yes
NB	1B21-HS07	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS08	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS15	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS16	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS22	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS23	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS39	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS40	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS41	Cutler Hammer/E30	Yes	Yes
NB	1B21-HS42	Cutler Hammer/E30	Yes	Yes
MS	1B21-J500	TrnsntShlds/TEC 160-2	Yes	Yes
MS	1B21-J501	TrnsntShlds/TEC 160-2	Yes	Yes
MS	1B21-J502	TrnsntShlds/TEC 160-2	Yes	Yes
MS	1B21-J503	TrnsntShlds/TEC 160-2	Yes	Yes
MS	1B21-J504	TrnsntShlds/TEC 160-2	Yes	Yes
MS	1B21-J505	TrnsntShlds/TEC 160-2	Yes	Yes
NB	1B21-K621	TEC/Isol 156	Yes	Yes
NB	1B21-N004A	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004B	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004C	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004D	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004E	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004F	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004G	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004H	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004J	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004K	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004L	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004M	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004N	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004P	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004R	Pyco/Temp Elem PPD-133D9679	Yes	Yes
NB	1B21-N004S	Pyco/Temp Elem PPD-133D9679	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
NB	1B21-N027	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N032	Rsmt/1152	Yes	Yes
NB	1B21-N040	Rsmt/PPD159C4520	Yes	Yes
NB	1B21-N044C	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N044D	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N059	Pyco/Temp Elem PPD-159C4313	Yes	Yes
NB	1B21-N060	Pyco/Temp Elem PPD-159C4313	Yes	Yes
NB	1B21-N061	Pyco/Temp Elem PPD-159C4313	Yes	Yes
NB	1B21-N075A	Rsmt/1152	Yes	Yes
NB	1B21-N075B	Rsmt/1152	Yes	Yes
NB	1B21-N075C	Rsmt/1152	Yes	Yes
NB	1B21-N075D	Rsmt/1152	Yes	Yes
NB	1B21-N076B	Rsmt/1153	Yes	Yes
NB	1B21-N076C	Rsmt/1153	Yes	Yes
NB	1B21-N099A	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N099B	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N099E	Rsmt/1152 DP53	Yes	Yes
NB	1B21-N099F	Rsmt/1152 DP5E	Yes	Yes
NB	1B21-N400A	Rsmt/1153	Yes	Yes
NB	1B21-N400B	Rsmt/1153	Yes	Yes
NB	1B21-N400E	Rsmt/1153	Yes	Yes
NB	1B21-N400F	Rsmt/1153	Yes	Yes
NB	1B21-N401A	Rsmt/1153	Yes	Yes
NB	1B21-N401B	Rsmt/1153	Yes	Yes
NB	1B21-N401E	Rsmt/1153	Yes	Yes
NB	1B21-N401E(S)	Conax/N11058-05	Yes	No
NB	1B21-N401F	Rsmt/1153	Yes	Yes
NB	1B21-N401F(S)	Conax/N11058-05	Yes	No
NB	1B21-N523	Asco/NP832066(V)	Yes	Yes
NB	1B21-N523(OS)	Conax/7F20-11001-02	Yes	Yes
NB	1B21-N524	Asco/NP832066(V)	Yes	Yes
NB	1B21-N524(OS)	Conax/7F20-11001-02	Yes	Yes
NB	1B21-N525	Asco/NP832070(V)	Yes	Yes
NB	1B21-N525(OS)	Conax/7F20-11001-02	Yes	Yes
NB	1B21-N526	Asco/NP832070(V)	Yes	Yes
NB	1B21-N526(OS)	Conax/7F20-11001-02	Yes	Yes
FW	1B21-N527	Asco/NP832066(V)	Yes	Yes
FW	1B21-N527(OS)	Conax/7F20-11001-02	Yes	Yes
FW	1B21-N528	Asco/NP832066(V)	Yes	Yes
FW	1B21-N528(OS)	Conax/7F20-11001-02	Yes	Yes
FW	1B21-N529	Asco/NP832070(V)	Yes	Yes
FW	1B21-N529(OS)	Conax/7F20-11001-02	Yes	Yes
FW	1B21-N530	Asco/NP832070(V)	Yes	Yes
FW	1B21-N530(OS)	Conax/7F20-11001-02	Yes	Yes
NB	1B21-N542B	ITTBrtn/288A	Yes	Yes
NB	1B21-N542C	ITTBrtn/288A	Yes	Yes
NB	1B21-N542D	ITTBrtn/288A	Yes	Yes
NB	1B21-N542E	ITTBrtn/288A	Yes	Yes
NB	1B21-N542H	ITTBrtn/288A	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-N542K	ITTBrtn/288A	Yes	Yes
NB	1B21-N542S	ITTBrtn/288A	Yes	Yes
NB	1B21-N616E	Rsmt/510 DU	Yes	Yes
NB	1B21-N616F	Rsmt/510 DU	Yes	Yes
NB	1B21-N617A	Rsmt/510 DU	Yes	Yes
NB	1B21-N617B	Rsmt/510 DU	Yes	Yes
NB	1B21-N618A	Rsmt/510 DU	Yes	Yes
NB	1B21-N618B	Rsmt/510 DU	Yes	Yes
NB	1B21-N618E	Rsmt/510 DU	Yes	Yes
HP	1B21-N667C	Rsmt/510 DU	Yes	Yes
HP	1B21-N667D	Rsmt/510 DU	Yes	Yes
HP	1B21-N667G	Rsmt/510 DU	Yes	Yes
HP	1B21-N667H	Rsmt/510 DU	Yes	Yes
NB	1B21-N668A	Rsmt/510 DU	Yes	Yes
NB	1B21-N668B	Rsmt/510 DU	Yes	Yes
NB	1B21-N668E	Rsmt/510 DU	Yes	Yes
NB	1B21-N668F	Rsmt/510 DU	Yes	Yes
NB	1B21-N669A	Rsmt/510 DU	Yes	Yes
NB	1B21-N669B	Rsmt/510 DU	Yes	Yes
NB	1B21-N669E	Rsmt/510 DU	Yes	Yes
NB	1B21-N669F	Rsmt/510 DU	Yes	Yes
NB	1B21-N669F	Rsmt/510 DU	Yes	Yes
NB	1B21-N670A	Rsmt/510 DU	Yes	Yes
NB	1B21-N670B	Rsmt/510 DU	Yes	Yes
NB	1B21-N670E	Rsmt/510 DU	Yes	Yes
NB	1B21-N670F	Rsmt/510 DU	Yes	Yes
NB	1B21-N673C	Rsmt/510 DU	Yes	Yes
NB	1B21-N673D	GE/510 DU	Yes	Yes
NB	1B21-N673G	Rsmt/510 DU	Yes	Yes
NB	1B21-N673H	GE/510 DU	Yes	Yes
NB	1B21-N674C	Rsmt/510 DU	Yes	Yes
NB	1B21-N674D	GE/Trip Unit SR Lvl	Yes	Yes
NB	1B21-N674G	Rsmt/510 DU	Yes	Yes
NB	1B21-N675A	Rsmt/510 DU	Yes	Yes
NB	1B21-N675B	Rsmt/510 DU	Yes	Yes
NB	1B21-N675C	Rsmt/510 DU	Yes	Yes
NB	1B21-N675D	GE/Ind Sw	Yes	Yes
NB	1B21-N676A	GE/3" Press Ind Sw	Yes	Yes
NB	1B21-N676B	GE/4" Press Ind Sw	Yes	Yes
NB	1B21-N676C	GE/1" Press Ind Sw	Yes	Yes
NB	1B21-N676D	Rsmt/510 DU	Yes	Yes
NB	1B21-N678A	Rsmt/510 DU	Yes	Yes
NB	1B21-N678B	Rsmt/510 DU	Yes	Yes
NB	1B21-N678C	Rsmt/510 DU	Yes	Yes
NB	1B21-N678D	Rsmt/510 DU	Yes	Yes
NB	1B21-N679A	Rsmt/510 DU	Yes	Yes
NB	1B21-N679B	Rsmt/510 DU	Yes	Yes
NB	1B21-N679C	Rsmt/510 DU	Yes	Yes
NB	1B21-N679D	Rsmt/510 DU	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-N680A	Rsmt/510 DU	Yes	Yes
NB	1B21-N680B	Rsmt/510 DU	Yes	Yes
NB	1B21-N680C	Rsmt/510 DU	Yes	Yes
NB	1B21-N680D	Rsmt/510 DU	Yes	Yes
NB	1B21-N681A	Rsmt/510 DU	Yes	Yes
NB	1B21-N681B	Rsmt/510 DU	Yes	Yes
NB	1B21-N681C	Rsmt/510 DU	Yes	Yes
NB	1B21-N681D	Rsmt/510 DU	Yes	Yes
NB	1B21-N682A	Rsmt/510 DU	Yes	Yes
NB	1B21-N682B	Rsmt/510 DU	Yes	Yes
NB	1B21-N682C	Rsmt/510 DU	Yes	Yes
NB	1B21-N682D	Rsmt/510 DU	Yes	Yes
NB	1B21-N683A	Rsmt/510 DU	Yes	Yes
NB	1B21-N683B	Rsmt/510 DU	Yes	Yes
NB	1B21-N683C	Rsmt/510 DU	Yes	Yes
NB	1B21-N683D	Rsmt/510 DU	Yes	Yes
NB	1B21-N691A	Rsmt/510 DU	Yes	Yes
NB	1B21-N691B	Rsmt/510 DU	Yes	Yes
NB	1B21-N691E	Rsmt/510 DU	Yes	Yes
NB	1B21-N691F	Rsmt/510 DU	Yes	Yes
NB	1B21-N692A	Rsmt/510 DU	Yes	Yes
NB	1B21-N692B	Rsmt/510 DU	Yes	Yes
NB	1B21-N692E	Rsmt/510 DU	Yes	Yes
NB	1B21-N692F	Rsmt/510 DU	Yes	Yes
NB	1B21-N693A	Rsmt/510 DU	Yes	Yes
NB	1B21-N693B	Rsmt/510 DU	Yes	Yes
NB	1B21-N694A	Rsmt/510 DU	Yes	Yes
NB	1B21-N694B	Rsmt/510 DU	Yes	Yes
NB	1B21-N694E	Rsmt/510 DU	Yes	Yes
NB	1B21-N694F	Rsmt/510 DU	Yes	Yes
NB	1B21-N695A	Rsmt/510 DU	Yes	Yes
NB	1B21-N695B	Rsmt/510 DU	Yes	Yes
NB	1B21-N697A	Rsmt/510 DU	Yes	Yes
NB	1B21-N697B	Rsmt/510 DU	Yes	Yes
NB	1B21-N697E	Rsmt/510 DU	Yes	Yes
NB	1B21-N697F	Rsmt/510 DU	Yes	Yes
NB	1B21-N698A	Rsmt/510 DU	Yes	Yes
NB	1B21-N698B	Rsmt/510 DU	Yes	Yes
NB	1B21-N698E	Rsmt/510 DU	Yes	Yes
NB	1B21-N698F	Rsmt/510 DU	Yes	Yes
SV	1B21-N800	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N801	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N802	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N803	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N804	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N805	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N806	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N807	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N808	BBN/424-ISO-TEC	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
SV	1B21-N809	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N810	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N811	BBN/424-ISO-TEC	Yes	Yes
SV	1B21-N812	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N813	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N814	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N815	BBN/424-ISO-TEC	Yes	Yes
NB	1B21-N816A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N816B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N817A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N817B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N818A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N818B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N819A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N819B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N820A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N820B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N821A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N821B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N822A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N822B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N823A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N823B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N824A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N824B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N825A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N825B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N826A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N826B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N827A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N827B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N828A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N828B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N829A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N829B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N830A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N830B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-N831A	TEC/914 Mon Module	Yes	Yes
NB	1B21-N831B	TEC/133 Alarm Module	Yes	Yes
NB	1B21-R004A	R/Shaw/613B	Yes	Yes
NB	1B21-R004B	R/Shaw/613B	Yes	Yes
NB	1B21-R005	Barton/227	Yes	Yes
NB	1B21-R009A	Barton/227	Yes	Yes
NB	1B21-R009B	Barton/227	Yes	Yes
NB	1B21-R623A	L&N/Speedomax	Yes	Yes
NB	1B21-R623B	L&N/Speedomax	Yes	Yes
NB	1B21-R659A	GE/180 Vert Ind	Yes	Yes
NB	1B21-R659B	GE/180 Vert Ind	Yes	Yes
NB	1B21-R659C	GE/180 Vert Ind	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21-R659D	GE/180 Vert Ind	Yes	Yes
NB	1B21-R660A	GE/180 Vert Ind	Yes	Yes
NB	1B21-R660B	GE/180 Vert Ind	Yes	Yes
NB	1B21-R660C	GE/180 Vert Ind	Yes	Yes
NB	1B21-R660D	GE/180 Vert Ind	Yes	Yes
NB	1B21-R661A	GE/180 Vert Ind	Yes	Yes
NB	1B21-R661B	GE/180 Vert Ind	Yes	Yes
NB	1B21-R661C	GE/180 Vert Ind	Yes	Yes
NB	1B21-R661D	GE/180 Vert Ind	Yes	Yes
NB	1B21-R662A	GE/180 Vert Ind	Yes	Yes
NB	1B21-R662B	GE/180 Vert Ind	Yes	Yes
NB	1B21-R662C	GE/180 Vert Ind	Yes	Yes
NB	1B21-R662D	GE/180 Vert Ind	Yes	Yes
NB	1B21A-AT02	GE/Isol Card	Yes	Yes
NB	1B21AS004	GE/CR2940	Yes	Yes
NB	1B21AS005	GE/CR2940	Yes	Yes
NB	1B21AS006	GE/CR2940	Yes	Yes
VR	1B21AS007	GE/CR2940	Yes	Yes
NB	1B21AS020A	GE/CR2940	Yes	Yes
NB	1B21AS020B	GE/CR2940	Yes	Yes
NB	1B21AS020C	GE/CR2940	Yes	Yes
NB	1B21AS020D	GE/CR2940	Yes	Yes
VR	1B21AS021	GE/CR2940	Yes	Yes
VR	1B21AS022	GE/CR2940	Yes	Yes
NB	1B21C-S030A	Cutler Hammer/10250T	Yes	Yes
NB	1B21C-S030B	Cutler Hammer/10250T	Yes	Yes
NB	1B21C-S031A	Cutler Hammer/10250T	Yes	Yes
NB	1B21C-S031B	Cutler Hammer/10250T	Yes	Yes
NB	1B21CS008A	GE/CR2940	Yes	Yes
NB	1B21CS008B	GE/CR2940	Yes	Yes
NB	1B21CS010A	GE/CR2940	Yes	Yes
NB	1B21CS010B	GE/CR2940	Yes	Yes
NB	1B21CS016A	GE/CR2940	Yes	Yes
NB	1B21CS016B	GE/CR2940	Yes	Yes
NB	1B21CS017A	GE/CR2940	Yes	Yes
NB	1B21CS017B	GE/CR2940	Yes	Yes
NB	1B21CS019A	GE/CR2940	Yes	Yes
NB	1B21CS019B	GE/CR2940	Yes	Yes
NB	1B21CS020A	GE/CR2940	Yes	Yes
NB	1B21CS020B	GE/CR2940	Yes	Yes
NB	1B21CS022A	GE/CR2940	Yes	Yes
NB	1B21CS022B	GE/CR2940	Yes	Yes
NB	1B21CS023A	GE/CR2940	Yes	Yes
NB	1B21CS023B	GE/CR2940	Yes	Yes
NB	1B21CS024A	GE/CR2940	Yes	Yes
NB	1B21CS024B	GE/CR2940	Yes	Yes
NB	1B21CS025A	GE/CR2940	Yes	Yes
NB	1B21CS025B	GE/CR2940	Yes	Yes
NB	1B21CS026A	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1B21CS026B	GE/CR2940	Yes	Yes
NB	1B21CS027A	GE/CR2940	Yes	Yes
NB	1B21CS027B	GE/CR2940	Yes	Yes
NB	1B21CS028A	GE/CR2940	Yes	Yes
NB	1B21CS028B	GE/CR2940	Yes	Yes
NB	1B21CS029A	GE/CR2940	Yes	Yes
NB	1B21CS029B	GE/CR2940	Yes	Yes
NB	1B21CS030A	Cutler Hammer/10250T	Yes	Yes
NB	1B21CS030B	Cutler Hammer/10250T	Yes	Yes
NB	1B21CS031A	Cutler Hammer/10250T	Yes	Yes
NB	1B21CS031B	Cutler Hammer/10250T	Yes	Yes
NB	1B21CS032A	GE/CR2940	Yes	Yes
NB	1B21CS032B	GE/CR2940	Yes	Yes
NB	1B21CS050A	GE/CR2940	Yes	Yes
NB	1B21CS050B	GE/CR2940	Yes	Yes
NB	1B21H-S025A	Cutler Hammer/10250T	Yes	Yes
NB	1B21H-S025B	Cutler Hammer/10250T	Yes	Yes
NB	1B21H-S025C	Cutler Hammer/10250T	Yes	Yes
NB	1B21H-S025D	Cutler Hammer/1025T	Yes	Yes
NB	1B21HCR1A	GE/Diode	Yes	No
NB	1B21HCR1B	GE/Diode	Yes	No
NB	1B21HCR1C	GE/Diode	Yes	No
NB	1B21HCR1D	GE/Diode	Yes	No
NB	1B21HS001A	GE/CR2940	Yes	Yes
NB	1B21HS001B	GE/CR2940	Yes	Yes
NB	1B21HS001C	GE/CR2940	Yes	Yes
NB	1B21HS001D	GE/CR2940	Yes	Yes
NB	1B21HS002A	GE/CR2940	Yes	Yes
NB	1B21HS002B	GE/CR2940	Yes	Yes
NB	1B21HS002C	GE/CR2940	Yes	Yes
NB	1B21HS002D	GE/CR2940	Yes	Yes
NB	1B21HS003A	GE/CR2940	Yes	Yes
NB	1B21HS003B	GE/CR2940	Yes	Yes
NB	1B21HS003C	GE/CR2940	Yes	Yes
NB	1B21HS003D	GE/CR2940	Yes	Yes
NB	1B21HS004A	GE/CR2940	Yes	Yes
NB	1B21HS004B	GE/CR2940	Yes	Yes
NB	1B21HS004C	GE/CR2940	Yes	Yes
NB	1B21HS004D	GE/CR2940	Yes	Yes
NB	1B21HS005	GE/CR2940	Yes	Yes
NB	1B21HS006	GE/CR2940	Yes	Yes
NB	1B21HS009	GE/CR2940	Yes	Yes
NB	1B21HS010	GE/CR2940	Yes	Yes
NB	1B21HS012	GE/CR2940	Yes	Yes
NB	1B21HS013	GE/CR2940	Yes	Yes
NB	1B21HS014	GE/CR2940	Yes	Yes
NB	1B21HS017	GE/CR2940	Yes	Yes
NB	1B21HS018	GE/CR2940	Yes	Yes
MS	1B21HS024A	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 30-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
MS	1B21HS024B	GE/CR2940	Yes	Yes
MS	1B21HS024C	GE/CR2940	Yes	Yes
MS	1B21HS024D	GE/CR2940	Yes	Yes
NB	1B21HS025A	Cutler Hammer/110250T	Yes	Yes
NB	1B21HS025B	Cutler Hammer/110250T	Yes	Yes
NB	1B21HS025C	Cutler Hammer/110250T	Yes	Yes
NB	1B21HS025D	Cutler Hammer/110250T	Yes	Yes
NB	1B21HS035	GE/CR2940	Yes	Yes
NB	1B21HS036	GE/CR2940	Yes	Yes
NB	1B21HS037	GE/CR2940	Yes	Yes
NB	1B21HS038	GE/CR2940	Yes	Yes
NB	1B21HS069	GE/CR2940	Yes	Yes
NB	1B21HS070	GE/CR2940	Yes	Yes
RR	1B33-C001A(M)	BW/RCIC Mtr	Yes	Yes
RR	1B33-C001A(P)	GE/Rctr Rcrd Pmp	Yes	Yes
RR	1B33-C001B(M)	BW/RCIC Mtr	Yes	Yes
RR	1B33-C001B(P)	GE/Rctr Rcrd Pmp	Yes	Yes
RR	1B33-D014	GE/PPD166B72B4	Yes	Yes
RR	1B33-D300A	SB & Tank/Flow Div	Yes	Yes
RR	1B33-D300B	SB & Tank/Flow Div	Yes	Yes
RR	1B33-D311A	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D311B	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D311C	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D311D	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D312A	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D312B	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D312C	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D312D	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D313A	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D313B	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D313C	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D313D	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D314A	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D314B	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D314C	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-D314D	MetalBellows/F1x Hose Ass	Yes	Yes
RR	1B33-E300	AmerMonorail/26 Ton Crane	Yes	Yes
RR	1B33-F019(L)	Namco/EA180	Yes	Yes
RR	1B33-F019(LS)	Conax/7F20-11002-02,11005-01	Yes	Yes
RR	1B33-F019(O)	Asco/2068323U	Yes	Yes
RR	1B33-F019(OS)	Conax/7F20-11001-02	Yes	Yes
RR	1B33-F019(V)	Fshr/.75" AO G1b V1v	Yes	Yes
RR	1B33-F020(L)	Namco/EA180	Yes	Yes
RR	1B33-F020(LS)	Conax/7F20-11005-01	Yes	Yes
RR	1B33-F020(LS)	Conax/7F20-11002-02	Yes	Yes
RR	1B33-F020(O)	Asco/2068323U	Yes	Yes
RR	1B33-F020(OS)	Conax/7F20-11001-02	Yes	Yes
RR	1B33-F020(V)	Fshr/.75" AO G1b V1v	Yes	Yes
RR	1B33-F023(A)	GE/Lmt/Oper-SMB-1-40	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
RR	1B33-F023(V)	AD/20" Gt Vlv	Yes	Yes
RR	1B33-F023A(A)	Lmt/SMB-000	Yes	Yes
RR	1B33-F060A	GE/ITT/20" Recirc Ball Vlv	Yes	Yes
RR	1B33-F060B	GE/ITT/20" Recirc Ball Vlv	Yes	Yes
RR	1B33-F067A(A)	Lmt/SMB-1-40	Yes	Yes
RR	1B33-F067A(V)	AD/20" Gt Vlv	Yes	Yes
RR	1B33-F067B(A)	Lmt/SMB-1-40	Yes	Yes
RR	1B33-F067B(V)	AD/20" Gt Vlv	Yes	Yes
RR	1B33-F075A	GE/CV Vlv	Yes	Yes
RR	1B33-F075B	GE/CV Vlv	Yes	Yes
LD	1B33-F307A	Valcor/.75" Sol Vlv	Yes	Yes
LD	1B33-F307B	Valcor/.75" Sol Vlv	Yes	Yes
RR	1B33-F308A	Valcor/.75" Sol Vlv	Yes	Yes
LD	1B33-F308B	Valcor/.75" Sol Vlv	Yes	Yes
LD	1B33-F309A	Valcor/.75" Sol Vlv	Yes	Yes
LD	1B33-F309B	Valcor/.75" Sol Vlv	Yes	Yes
RR	1B33-N004A	SK/Instr/1900	Yes	No
RR	1B33-N004B	SK/Instr/1900	Yes	No
RR	1B33-N011A	Rsmt/1152 DP5E	Yes	Yes
RR	1B33-N011B	Rsmt/1152 DP5E	Yes	Yes
RR	1B33-N037A	Rsmt/1152	Yes	Yes
RR	1B33-N037B	Rsmt/1152	Yes	Yes
RR	1B33-N037C	Rsmt/1152	Yes	Yes
RR	1B33-N037D	Rsmt/1152	Yes	Yes
RR	1B33-N037E	Rsmt/1152	Yes	Yes
RR	1B33-N037F	Rsmt/1152	Yes	Yes
RR	1B33-N037G	Rsmt/1152	Yes	Yes
RR	1B33-N037H	Rsmt/1152	Yes	Yes
RR	1B33-N037J	Rsmt/1152	Yes	Yes
RR	1B33-N037K	Rsmt/1152	Yes	Yes
RR	1B33-N037L	Rsmt/1152	Yes	Yes
RR	1B33-N037M	Rsmt/1152	Yes	Yes
RR	1B33-N037N	Rsmt/1152	Yes	Yes
RR	1B33-N037P	Rsmt/1152	Yes	Yes
RR	1B33-N037R	Rsmt/1152	Yes	Yes
RR	1B33-N037S	Rsmt/1152	Yes	Yes
RR	1B33-N037T	Rsmt/1152	Yes	Yes
RR	1B33-N037U	Rsmt/1152	Yes	Yes
RR	1B33-N037V	Rsmt/1152	Yes	Yes
RR	1B33-N037W	Rsmt/1152	Yes	Yes
RR	1B33-N038A	Rsmt/1152	Yes	Yes
RR	1B33-N038B	Rsmt/1152	Yes	Yes
RR	1B33-N038C	Rsmt/1152	Yes	Yes
RR	1B33-N038D	Rsmt/1152	Yes	Yes
RR	1B33-N040	Rsmt/1152 DP5E	Yes	Yes
RR	1B33A-K101A	Agst/GP1C750	Yes	Yes
RR	1B33A-K101B	Agst/GP1C750	Yes	Yes
RR	1B33A-K101C	Agst/GP1C750	Yes	Yes
RR	1B33A-K101D	Agst/GP1C750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 30-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RR	1B33A-K147A	Agst/GP1C750	Yes	Yes
RR	1B33A-K147B	Agst/GP1C750	Yes	Yes
RD	1C11-D001	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AA	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AB	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AC	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AD	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AE	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AF	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AG	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AH	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AJ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AK	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AL	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AM	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AN	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AP	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AQ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AR	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AS	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AT	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AU	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AV	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AW	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001AY	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BA	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BB	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BC	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BD	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BE	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BF	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BG	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BH	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BJ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BK	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BL	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BM	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BN	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BP	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BQ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BR	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BS	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BT	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BU	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BV	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BW	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001BY	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CA	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CB	GE/Hyd Cnt Unit 767E800	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RD	1C11-D001CC	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CD	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CE	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CF	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CG	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CH	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CJ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CK	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CL	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CM	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CN	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CP	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CQ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CR	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CS	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CT	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CU	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CV	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CW	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001CY	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DA	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DB	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DC	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DD	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DE	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DF	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DG	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DH	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DJ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DK	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DL	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DM	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DN	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DP	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DQ	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DR	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DS	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DT	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DU	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DV	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DW	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001DY	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EA	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EB	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EC	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001ED	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EE	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EF	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EG	GE/Hyr Cnt Unit 767E800	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RD	1C11-D001EH	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EJ	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EK	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EL	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EM	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EN	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EP	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EQ	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001ER	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001ES	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001ET	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EU	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EV	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EW	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001EY	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FA	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FB	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FC	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FD	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FE	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FF	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FG	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FH	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FJ	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FK	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FL	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FM	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FN	GE/Hyr Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FP	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FQ	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FR	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FS	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FT	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FU	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FV	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FW	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001FY	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GA	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GB	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GC	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GD	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GE	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GF	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-D001GG	GE/Hyd Cnt Unit 767E800	Yes	Yes
RD	1C11-F010(V)	Fshr/1" Diaphragm Vlv	Yes	Yes
RD	1C11-F011(V)	Fshr/2" Diaphragm Vlv	Yes	Yes
RD	1C11-F003(A)	Lmt/SMB-000	Yes	Yes
RD	1C11-F003(V)	Yrwy/2" Glb Vlv	Yes	No
RD	1C11-F180(V)	ITTHamm/522JRR62HA29	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RD	1C11-F181(V)	ITTHamm/522JRR62HA29	Yes	Yes
RD	1C11-F182(O)	Valcor/V70900-45	Yes	No
RD	1C11-N012A	Gld/PD3218	Yes	Yes
RD	1C11-N012A(S)	Conax/TF20-11008-01	Yes	Yes
RD	1C11-N012B	Gld/PD3218	Yes	Yes
RD	1C11-N012B(S)	Conax/TF20-11008-01	Yes	Yes
RP	1C11-N012C	Gld/PD3218	Yes	Yes
RP	1C11-N012C(S)	Conax/TF20-11008-01	Yes	Yes
RP	1C11-N012D	Gld/PD3218	Yes	Yes
RP	1C11-N012D(S)	Conax/TF20-11008-01	Yes	Yes
RP	1C11-N013A	Magnetrol/C-751	Yes	No
RP	1C11-N013B	Magnetrol/C-751	Yes	No
RP	1C11-N013C	Magnetrol/C-751	Yes	No
RP	1C11-N013D	Magnetrol/C-751	Yes	No
RP	1C11-N017A	Gld/PD3218	Yes	Yes
RP	1C11-N017A(S)	Conax/TF20-11008-01	Yes	Yes
RP	1C11-N017B	Gld/PD3218	Yes	Yes
RP	1C11-N017B(S)	Conax/TF20-11008-01	Yes	Yes
RP	1C11-N054A	Rsmt/1152	Yes	Yes
RD	1C11-N054B	Rsmt/1152	Yes	Yes
RD	1C11-N054C	Rsmt/1152	Yes	Yes
RD	1C11-N054D	Rsmt/1152	Yes	Yes
RD	1C11-N601A	Rsmt/510 DU	Yes	Yes
RD	1C11-N601B	Rsmt/510 DU	Yes	Yes
RD	1C11-N601C	Rsmt/510 DU	Yes	Yes
RD	1C11-N601D	Rsmt/510 DU	Yes	Yes
RD	1C11-N602A	Rsmt/510 DU	Yes	Yes
RD	1C11-N602B	Rsmt/510 DU	Yes	Yes
RD	1C11-N602C	Rsmt/510 DU	Yes	Yes
RD	1C11-N602D	GE/Trip Unit Scrm Dis Drn	Yes	Yes
RD	1C11-N654A	Rsmt/510 DU	Yes	Yes
RC	1C11-N654B	Rsmt/510 DU	Yes	Yes
RD	1C11-N654C	Rsmt/510 DU	Yes	Yes
RC	1C11-N654D	Rsmt/510 DU	Yes	Yes
RD	1C11-N655A	Rsmt/510 DU	Yes	Yes
RC	1C11-N655B	Rsmt/510 DU	Yes	Yes
RD	1C11B-AT02	GE/Opt Isol	Yes	Yes
RD	1C11B5006	GE/CR2940	Yes	Yes
FW	1C34-N003A	Rsmt/1152	Yes	Yes
FW	1C34-N003B	Rsmt/1152	Yes	Yes
FW	1C34-N003C	Rsmt/1152	Yes	Yes
FW	1C34-N003D	Rsmt/1152	Yes	Yes
FW	1C34-N004A	Rsmt/1152 DP4E	Yes	Yes
FW	1C34-N004B	Rsmt/1152 DP4E	Yes	Yes
FW	1C34-N004C	Rsmt/1152 DP4E	Yes	Yes
FW	1C34-N005	Rsmt/1152 DP93	Yes	Yes
FW	1C34-N008A	Rsmt/1152 DP8E	Yes	Yes
FW	1C34-N008B	Rsmt/1152 DP8E	Yes	Yes
FW	1C34-N017	Rsmt/1152 DP5E	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SC	1C41-A001	GE/Standby Liq Cont Strge Tnk	Yes	Yes
SC	1C41-C001A(M)	RInc/40HP 364TCZ	Yes	Yes
SC	1C41-C001A(P)	UnPmpCo/TD-60	Yes	Yes
SC	1C41-C001B(M)	RInc/40HP 364TCZ	Yes	Yes
SC	1C41-C001B(P)	UnPmpCo/TD-60	Yes	Yes
SC	1C41-F001A(A)	Lmt/SMB-000	Yes	Yes
SC	1C41-F001A(V)	AD/3" G1b Vlv	Yes	Yes
SC	1C41-F001B(A)	Lmt/SMB-000	Yes	Yes
SC	1C41-F001B(V)	AD/3" 150# G1b Vlv	Yes	Yes
SC	1C41-F004A	Conax/1832-159-01	Yes	Yes
SC	1C41-F004B	Conax/1832-159-01	Yes	Yes
SC	1C41-F029A	Dresser/2 1 1/2" SRV	Yes	Yes
SC	1C41-F029B	Dresser/2 1 1/2" SRV	Yes	Yes
SC	1C41-F031(LS)	Conax/7F20-1102-03	Yes	Yes
SC	1C41-F334	AD/3" G1b Vlv	Yes	Yes
SC	1C41-N001	Rsmt/1153	Yes	Yes
SC	1C41-N001(S)	Conax/7F20-11006-02	Yes	Yes
SC	1C41-N003	Fenwal/Temp Sw/22810	Yes	Yes
SC	1C41-N006	GE/Fenwal Temp Element 103	Yes	Yes
SC	1C41-N600	Bly/7000 Srs Typ 745 Lvl Alrm	Yes	Yes
SC	1C41-R001	RbtShw/7138D	Yes	Yes
SC	1C41-R003	RbtShw/613B	Yes	Yes
SC	1C41-R004	SK-Instr/Flw Cont 7210 PPD16	Yes	Yes
SC	1C41-R600	GE/180 Vert Ind	Yes	Yes
SC	1C41-R601	GE/180 Vert Ind.	Yes	Yes
SC	1C41A-K02B	Agst/GP1C750	Yes	Yes
SC	1C41AK02A	Agst/GP1C750	Yes	Yes
RP	1C41AS001A	ElctrSw/20K Hand Sw	Yes	Yes
SC	1C41AS001B	ElctrSw/20K Hand Sw	Yes	Yes
SC	1C41AS003A	GE/CR2940	Yes	Yes
SC	1C41AS003B	GE/CR2940	Yes	Yes
SC	1C41AS004A	GE/CR2940	Yes	Yes
SC	1C41AS004B	GE/CR2940	Yes	Yes
SC	1C41AS005A	GE/CR2940	Yes	Yes
SC	1C41AS005B	GE/CR2940	Yes	Yes
SC	1C41AS006A	GE/CR2940	Yes	Yes
SC	1C41AS006B	GE/CR2940	Yes	Yes
NR	1C51-K001A	GE/SRM Preamp	Yes	Yes
NR	1C51-K001B	GE/SRM Preamp	Yes	Yes
NR	1C51-K001C	GE/Srm Preamp	Yes	Yes
NR	1C51-K001D	GE/SRM Preamp	Yes	Yes
NR	1C51-K002A	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002B	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002C	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002D	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002E	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002F	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002G	GE/Volt/Preamp 163C1263AAG001	Yes	Yes
NR	1C51-K002H	GE/Volt/Preamp 163C1263AAG001	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
NR	1C51-K600A	GE/PPD368X101BB	Yes	Yes
NR	1C51-K600B	GE/PPD368X101BB	Yes	Yes
NR	1C51-K600C	GE/PPD368X101BB	Yes	Yes
NR	1C51-K600D	GE/PPD368X101BB	Yes	Yes
NR	1C51-K601A	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601B	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601C	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601D	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601E	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601F	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601G	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K601H	GE/Wide Rng Mon Dwg 268X102BB	Yes	Yes
NR	1C51-K605AA	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AB	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AC	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AD	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AE	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AF	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AG	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AH	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AJ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AK	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AL	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AM	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AN	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AP	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AR	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AS	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AT	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AU	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AV	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AW	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AY	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605AZ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BA	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BB	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BC	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BD	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BE	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BF	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BG	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BH	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BJ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BK	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BL	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BM	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BN	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BP	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BR	GE/LCL Pwr Rng Mon Det	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NR	1C51-K605BS	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BT	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BU	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BW	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BY	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605BZ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CA	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CB	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CC	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CD	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CE	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CF	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CG	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CH	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CJ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CK	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CL	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CM	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CN	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CP	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CR	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CS	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CT	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CU	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CV	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CW	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CY	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605CZ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DA	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DB	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DC	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DD	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DE	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DF	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DG	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DH	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DJ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DK	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DL	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DM	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DN	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DP	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DR	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DS	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DT	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DU	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DV	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DW	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605DY	GE/LCL Pwr Rng Mon Det	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NR	1C51-K605DZ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EA	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EB	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EC	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605ED	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EE	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EF	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EG	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EH	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EJ	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EK	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EL	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EM	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EN	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EP	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605ER	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605ER	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605ES	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605ET	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EU	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EV	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EW	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605EY	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605F	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605G	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605H	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605J	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605K	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605L	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605M	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605N	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605P	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605R	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605S	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605T	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605U	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605V	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605W	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605Y	GE/LCL Pwr Rng Mon Det	Yes	Yes
NR	1C51-K605Z	GE/LCL Pwr Rng Mon Det	Yes	Yes
RS	1C61-K001	Bailey/7500020AAAE1	Yes	Yes
RS	1C61-K002	Topaz/PPD#184C4723	Yes	Yes
RS	1C61-K005	GE/Rem Shtdwn Pwr Sup SW Inst	Yes	No
RS	1C61-K010	GE/Rem Shtdwn Pwr Sup SW Inst	Yes	No
RS	1C61-K501	Wd/4000R	Yes	Yes
RS	1C61-K502	Wd/4000R	Yes	Yes
RS	1C61-K506	Wd/4000R	Yes	Yes
RS	1C61-K507	Wd/4000R	Yes	Yes
RS	1C61-K508	Wd/4000R	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RS	1C61-K509	Wd/4000R	Yes	Yes
RS	1C61-K510	Wd/4000R	Yes	Yes
RS	1C61-K511	Wd/4000R	Yes	Yes
RS	1C61-N001	Rsmt/1152 DP5E	Yes	Yes
RS	1C61-N006	Rsmt/1152 GP9E	Yes	Yes
RS	1C61-N010	Rsmt/1152 DP5E	Yes	Yes
RS	1C61-N501	Wd/RTD-611-1B-A-3-C-6-A2-0	Yes	Yes
RS	1C61-N502	Wd/RTD-611-1B-A-3-C-6-A2-0	Yes	Yes
RS	1C61-N503	Rsmt/1153	Yes	Yes
RS	1C61-N505	Rsmt/1153	Yes	Yes
RS	1C61-N505(S)	Conax/7F20-11006-01	Yes	Yes
RS	1C61-N506	Rsmt/1153	Yes	Yes
RS	1C61-N506(S)	Conax/7F20-11006-02	Yes	Yes
RS	1C61-N507	Rsmt/1153	Yes	Yes
RS	1C61-N507(S)	Conax/7F20-11006-02	Yes	Yes
RS	1C61-N508	Rsmt/1153	Yes	Yes
RS	1C61-N508(S)	Conax/7F20-11006-02	Yes	Yes
RS	1C61-N509	Rsmt/1153	Yes	Yes
RS	1C61-N509(S)	Conax/7F20-11006-02	Yes	Yes
RS	1C61-P001	GE/Rem ShtdwnPwr Sup SW/Instr	Yes	Yes
RS	1C61-P001A	GE/Rmt Shtdwn Pnl	Yes	Yes
RS	1C61-P001B	GE/Rmt Shtdwn Pnl	Yes	Yes
RS	1C61-P001C	GE/Rmt Shtdwn Pnl	Yes	Yes
RS	1C61-P001D	GE/Rmt Shtdwn Pnl	Yes	Yes
RS	1C61-P001E	GE/Rmt Shtdwn Pnl	Yes	Yes
RS	1C61-R001	Bailey/701	Yes	Yes
RS	1C61-R003	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R005	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R010	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R011	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R501	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R502	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R503	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R504	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R505	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R506	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R507	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R508	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R509	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R510	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R511	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R512	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R513	GE/180 Vert Ind.	Yes	Yes
RS	1C61-R514	GE/180 Vert Ind.	Yes	Yes
RS	1C61AS001	GE/SB-9	Yes	Yes
RS	1C61AS002	GE/SB-9	Yes	Yes
RS	1C61AS003	GE/SB-9	Yes	Yes
RS	1C61AS004	GE/SB-9	Yes	Yes
RS	1C61AS005	GE/SB-9	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
RS	1C61AS006	GE/SB-9	Yes	Yes
RS	1C61AS007	GE/SB-9	Yes	Yes
RS	1C61AS008	GE/SB-9	Yes	Yes
RS	1C61AS009	GE/SB-9	Yes	Yes
RS	1C61AS010	GE/SB-9	Yes	Yes
RS	1C61AS011	GE/SB-9	Yes	Yes
RS	1C61AS012	GE/SB-9	Yes	Yes
RS	1C61AS019	GE/SBM Sw	Yes	Yes
RS	1C61AS020	GE/SBM Sw	Yes	Yes
RS	1C61AS021	GE/SBM Sw	Yes	Yes
RS	1C61AS022	GE/SBM Sw	Yes	Yes
RS	1C61AS023	GE/SBM Sw	Yes	Yes
RS	1C61AS024	GE/SBM Sw	Yes	Yes
RS	1C61AS025	GE/SBM Sw	Yes	Yes
RS	1C61AS026	GE/SBM Sw	Yes	Yes
RS	1C61AS027	GE/SBM Sw	Yes	Yes
RS	1C61AS028	GE/SBM Sw	Yes	Yes
RS	1C61AS029	GE/SBM Sw	Yes	Yes
RS	1C61AS030	GE/SBM Sw	Yes	Yes
RS	1C61AS031	GE/SBM Sw	Yes	Yes
RS	1C61AS032	GE/SBM Sw	Yes	Yes
RS	1C61AS033	GE/SBM Sw	Yes	Yes
RS	1C61AS034	GE/SBM Sw	Yes	Yes
RS	1C61AS035	GE/SBM Sw	Yes	Yes
RS	1C61AS036	GE/SBM Sw	Yes	Yes
RS	1C61AS037	GE/SBM Sw	Yes	Yes
RS	1C61AS038	GE/SBM Sw	Yes	Yes
RS	1C61AS039	GE/SBM Sw	Yes	Yes
RS	1C61AS040	GE/SBM Sw	Yes	Yes
RS	1C61AS041	GE/SBM Sw	Yes	Yes
RS	1C61AS042	GE/SBM Sw	Yes	Yes
RS	1C61AS043	GE/SBM Sw	Yes	Yes
RS	1C61AS044	GE/SBM Sw	Yes	Yes
RS	1C61AS045	GE/SBM Sw	Yes	Yes
RS	1C61AS046	GE/SBM Sw	Yes	Yes
RS	1C61AS047	GE/SBM Sw	Yes	Yes
RS	1C61AS048	GE/SBM Sw	Yes	Yes
RS	1C61AS049	GE/SBM Sw	Yes	Yes
RS	1C61AS050	GE/SBM Sw	Yes	Yes
RS	1C61AS051	GE/SBM Sw	Yes	Yes
RS	1C61AS052	GE/SBM Sw	Yes	Yes
RS	1C61AS053	GE/SBM Sw	Yes	Yes
RS	1C61AS054	GE/SMB Sw	Yes	Yes
RS	1C61AS055	GE/SBM Sw	Yes	Yes
RS	1C61AS056	GE/SBM Sw	Yes	Yes
RS	1C61AS057	GE/SBM Sw	Yes	Yes
RS	1C61AS058	GE/SBM Sw	Yes	Yes
RS	1C61AS059	GE/SMB Sw	Yes	Yes
RS	1C61AS060	GE/SMB Sw	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
RS	1C61AS061	GE/SMB Sw	Yes	Yes
RS	1C61DS501	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS502	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS503	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS504	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS505	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS506	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS507	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS508	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS509	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS510	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61DS511	GE/ET-16 Ind. Light	Yes	Yes
RS	1C61HS501	GE/SB-9	Yes	Yes
RS	1C61HS502	GE/SB-9	Yes	Yes
RS	1C61HS503	GE/SBM Sw	Yes	Yes
RS	1C61HS504	GE/CR2940	Yes	Yes
RS	1C61HS505	GE/CR2940	Yes	Yes
RS	1C61HS506	GE/CR2940	Yes	Yes
RS	1C61HS507	GE/SBM Sw	Yes	Yes
RS	1C61HS508	GE/SB-9	Yes	Yes
RS	1C61HS509	GE/SB-9	Yes	Yes
RS	1C61HS510	GE/SB-9	Yes	Yes
RS	1C61HS511	GE/SB-9	Yes	Yes
RS	1C61HS512	GE/SMB Sw	Yes	Yes
RS	1C61HS524	GE/SMB Sw	Yes	Yes
RS	1C61HS525	GE/SMB Sw	Yes	Yes
RS	1C61HS526	GE/SMB Sw	Yes	Yes
RS	1C61HS527	GE/SM-9	Yes	Yes
RP	1C71-N005A	Barksdale/TC 9622	Yes	Yes
RP	1C71-N005B	Barksdale/TC 9622	Yes	Yes
RP	1C71-N005C	Barksdale/TC 9622	Yes	Yes
RP	1C71-N005D	Barksdale/TC 9622	Yes	Yes
RP	1C71-N006A	Namco/EA170	Yes	Yes
RP	1C71-N006B	Namco/EA170	Yes	Yes
RP	1C71-N006C	Namco/EA170	Yes	Yes
RP	1C71-N006D	Namco/EA170	Yes	Yes
RP	1C71-N050A(S)	Conax/7F20-11006-02	Yes	Yes
RP	1C71-N050B(S)	Conax/7F20-11006-02	Yes	Yes
RP	1C71-N050C(S)	Conax/7F20-11006-02	Yes	Yes
RP	1C71-N050D(S)	Conax/7F20-11006-02	Yes	Yes
RP	1C71-N052A	Rsmt/1152	Yes	Yes
RP	1C71-N052B	Rsmt/1152	Yes	Yes
RP	1C71-N052C	Rsmt/1152	Yes	Yes
RP	1C71-N052D	Rsmt/1152	Yes	Yes
RP	1C71-N650A	Rsmt/510 DU	Yes	Yes
NB	1C71-N650B	Rsmt/510 DU	Yes	Yes
RP	1C71-N650C	Rsmt/510 DU	Yes	Yes
NB	1C71-N650D	Rsmt/510 DU	Yes	Yes
RP	1C71-N651A	Rsmt/510 DU	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
NB	1C71-N651B	Rsmt/510 DU	Yes	Yes
RP	1C71-N651C	Rsmt/510 DU	Yes	Yes
NB	1C71-N651D	Rsmt/510 DU	Yes	Yes
RP	1C71-N652A	Rsmt/510 DU	Yes	Yes
SP	1C71-N652B	Rsmt/510 DU	Yes	Yes
RP	1C71-N652C	Rsmt/510 DU	Yes	Yes
SP	1C71-N652D	Rsmt/510 DU	Yes	Yes
RP	1C71-P001A	GE/Pwr Dist Pnl	Yes	Yes
RP	1C71-P001B	GE/Pwr Dist Pnl	Yes	Yes
RP	1C71-P001C	GE/Pwr Dist Pnl	Yes	Yes
RP	1C71-P001D	GE/Pwr Dist Pnl	Yes	Yes
RP	1C71-S001A	Elgar/752-1-101	Yes	Yes
RP	1C71-S001B	Elgar/752-1-101	Yes	Yes
RP	1C71-S001C	Elgar/752-1-101	Yes	Yes
RP	1C71-S001D	Elgar/752-1-101	Yes	Yes
RP	1C71A-S001	GE/Mode Sw	Yes	Yes
RP	1C71A-S003A	Cutler Hammer/10250T	Yes	Yes
RP	1C71A-S003B	Cutler Hammer/10250T	Yes	Yes
RP	1C71A-S003C	Cutler Hammer/10250T	Yes	Yes
RP	1C71A-S003D	Cutler Hammer/10250T	Yes	Yes
RP	1C71A-S004A	GE/CR2940	Yes	Yes
RP	1C71A-S004B	GE/CR2940	Yes	Yes
RP	1C71A-S004C	GE/CR2940	Yes	Yes
RP	1C71A-S004D	GE/CR2940	Yes	Yes
RP	1C71A-S007A	GE/CR2940	Yes	Yes
RP	1C71A-S007B	GE/CR2940	Yes	Yes
RP	1C71A-S007C	GE/CR2940	Yes	Yes
RP	1C71A-S007D	GE/CR2940	Yes	Yes
RP	1C71A-S008A	GE/CR2940	Yes	Yes
RP	1C71A-S008B	GE/CR2940	Yes	Yes
RP	1C71A-S008C	GE/CR2940	Yes	Yes
RP	1C71A-S008D	GE/CR2940	Yes	Yes
RP	1C71A-S01	GE/Rund/PPD163C1487	Yes	Yes
RP	1C71A-S02A	Cutler Hammer E30	Yes	Yes
RP	1C71A-S02B	Cutler Hammer E30	Yes	Yes
RP	1C71A-S05A	GE/CR2940	Yes	Yes
RP	1C71A-S05B	GE/CR2940	Yes	Yes
RP	1C71A-S05C	GE/CR2940	Yes	Yes
RP	1C71A-S05D	GE/CR2940	Yes	Yes
RP	1C71BCB01	GE/TED & TEF	Yes	Yes
RP	1C71BCB02	GE/TED & TEF	Yes	Yes
RP	1C71BCB03	GE/TED & TEF	Yes	Yes
RP	1C71BCB05	GE/TED & TEF	Yes	Yes
RP	1C71BCB06	GE/TED & TEF	Yes	Yes
RP	1C71BCB07	GE/TED & TEF	Yes	Yes
RP	1C71BCB09	GE/TED & TEF	Yes	Yes
RP	1C71BCB10	GE/TED & TEF	Yes	Yes
RP	1C71BCB11	GE/TED & TEF	Yes	Yes
RP	1C71BCB12	GE/TED & TEF	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RP	1C71BCB13	GE/TED & TEF	Yes	Yes
RP	1C71BCB15	GE/TED & TEF	Yes	Yes
RP	1C71BCB16	GE/TED & TEF	Yes	Yes
RP	1C71BCB17	GE/TED & TEF	Yes	Yes
RP	1C71BCB19	GE/TED & TEF	Yes	Yes
RP	1C71BCB20	GE/TED & TEF	Yes	Yes
RP	1C71BCB32	GE/Ckt Bkr	Yes	No
CC	1CC01MA	MtlBlws/Metal Bellows	Yes	No
CC	1CC01MB	MtlBlws/Metal Bellows	Yes	No
CC	1CC02MA	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MB	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MC	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MD	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02ME	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MF	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MG	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC02MH	MetalBellows/1.0 IPS	Yes	Yes
CC	1CC03MA	MetalBellows/2.0 IPS	Yes	Yes
CC	1CC03MB	MetalBellows/2.0 IPS	Yes	Yes
CC	1CC03MC	MetalBellows/2.0 IPS	Yes	Yes
CC	1CC03MD	MetalBellows/2.0 IPS	Yes	Yes
CC	1CC049(A)	Lmt/SMB-000	Yes	Yes
CC	1CC049(V)	AD/10" 150# Flx Gt Vlv	Yes	Yes
CC	1CC050(A)	Lmt/SMB-000	Yes	Yes
CC	1CC050(V)	AD/6" Gt Vlv	Yes	Yes
CC	1CC053(A)	Lmt/SMB-000	Yes	Yes
CC	1CC053(V)	AD/6" 150# Gt Vlv	Yes	Yes
CC	1CC054(A)	Lmt/SMB-000	Yes	Yes
CC	1CC054(V)	AD/10" Gt Vlv	Yes	Yes
CC	1CC057(A)	Lmt/SMB-000	Yes	Yes
CC	1CC057(V)	AD/8" 150# Gt Vlv	Yes	Yes
CC	1CC060(A)	Lmt/SMB-000	Yes	Yes
CC	1CC060(V)	AD/8" Gt Vlv	Yes	Yes
CC	1CC065(A)	Lmt/SMB-000	Yes	Yes
CC	1CC065(V)	AD/2.5" Gt Vlv	Yes	Yes
CC	1CC067(A)	Lmt/SMB-000	Yes	Yes
CC	1CC067(V)	AD/2.5" Gt Vlv	Yes	Yes
CC	1CC068(A)	Lmt/SMB-000	Yes	Yes
CC	1CC068(V)	AD/2.5" Gt Vlv	Yes	Yes
CC	1CC070(A)	Lmt/SMB-000	Yes	Yes
CC	1CC070(V)	AD/2.5" Gt Vlv	Yes	Yes
CC	1CC071(A)	Lmt/SMB-000	Yes	Yes
CC	1CC071(V)	AD/4" Gt Vlv	Yes	Yes
CC	1CC072(A)	Lmt/SMB-000	Yes	Yes
CC	1CC072(V)	AD/4" Gt Vlv	Yes	Yes
CC	1CC073(A)	Lmt/SMB-000	Yes	Yes
CC	1CC073(V)	AD/4" Gt Vlv	Yes	Yes
CC	1CC074(A)	Lmt/SMB-000	Yes	Yes
CC	1CC074(V)	AD/4" Gt Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CC	1CC075A(A)	Lmt/H1BC/SMB-000	Yes	Yes
CC	1CC075A(V)	PosiSl/14" 150# Btrfly Vlv	Yes	Yes
CC	1CC075B(A)	Lmt/H1BC/SMB-000	Yes	Yes
CC	1CC075B(V)	PosiSl/14" 150# Btrfly Vlv	Yes	Yes
CC	1CC076A(A)	Lmt/H1BC/SMB-000	Yes	Yes
CC	1CC076A(V)	PosiSl/14" 150# Btrfly Vlv	Yes	Yes
CC	1CC076B(A)	Lmt/H1BC/SMB-000	Yes	Yes
CC	1CC076B(V)	PosiSl/14" 150# Btrfly Vlv	Yes	Yes
CC	1CC127(A)	Lmt/SMB-000	Yes	Yes
CC	1CC127(V)	AD/8" Gt Vlv	Yes	Yes
CC	1CC128(A)	Lmt/SMB-000	Yes	Yes
CC	1CC128(V)	AD/8" Gt Vlv	Yes	Yes
CC	1CC185A	Crosby/3/4x1 JR, SRV	Yes	Yes
CC	1CC185B	Crosby/3/4x1 JR, SRV	Yes	Yes
CM	1CM011	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM011(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM012	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM012(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM014	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM014(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM015	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM015(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM016	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM016(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM017	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM017(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM018	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM018(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM01SA*	Sentry/CNT Atmos Smpl Pnl	Yes	Yes
CM	1CM01SB*	Sentry/CNT Atmos Smpl Pnl	Yes	Yes
CM	1CM01TA	Sentry/ASCM	Yes	Yes
CM	1CM01TB	Sentry/ASCM	Yes	Yes
CM	1CM022	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM022(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM023	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM023(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM025	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM025(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM026	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM026(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM028	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM028(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM031	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM031(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM032	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM032(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM033	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM034	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM034(OS)	Conax/7F20-11007-01	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1CM047	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM047(OS)	Conax/7F20-11007-01	Yes	Yes
CM	1CM048	Valcor/.75" Sol Vlv	Yes	Yes
CM	1CM048(OS)	Conax/7F20-11007-01	Yes	Yes
CY	1CY016(A)	Lmt/SMB-000	Yes	Yes
CY	1CY016(V)	AD/6" Gt Vlv	Yes	Yes
CY	1CY017(A)	Lmt/SMB-000	Yes	Yes
CY	1CY017(V)	AD/6" Gt Vlv	Yes	Yes
CY	1CY020(A)	Lmt/SMB-000	Yes	Yes
CY	1CY020(V)	AD/3" Gt Vlv	Yes	Yes
CY	1CY021(A)	Lmt/SMB-000	Yes	Yes
CY	1CY021(V)	AD/3" Gt Vlv	Yes	Yes
CZ	1CZ01J	TEC/2200-2 Isol Cbnt	Yes	Yes
CZ	1CZ02J	TEC/2200-2 Isol Cbnt	Yes	Yes
CZ	1CZ03J	TEC/2200-2 Isol Cbnt	Yes	Yes
CZ	1CZ04J	Hoffman/A-30C24ABLP	Yes	No
CZ	1CZ05J	Hoffman/A-30C24ABLP	Yes	No
CZ	1CZ06J	BA/Trndcr Cab	Yes	No
CZ	1CZ07J	BA/Trndcr Cab	No	No
PR	1D17-K610A	GE/Log Rad Mon Dwg 238X660	Yes	Yes
PR	1D17-K610B	GE/Log Rad Mon Dwg 238X660	Yes	Yes
PR	1D17-K610C	GE/Log Rad Mon Dwg 238X660	Yes	Yes
PR	1D17-K610D	GE/Log Rad Mon Dwg 238X660	Yes	Yes
PR	1D17-N003A	GE/237X731G001	Yes	Yes
PR	1D17-N003B	GE/237X731G001	Yes	Yes
PR	1D17-N003C	GE/237X731G001	Yes	Yes
PR	1D17-N003D	GE/237X731G001	Yes	Yes
DC	1DC01E	C&D/LC-17 Bat Rack	Yes	Yes
DC	1DC02E	C&D/LC-17 Bat Rack	Yes	Yes
DC	1DC03E	C&D/KC-11 Bat Rack	Yes	Yes
DC	1DC06E	C&D/125V DC Bat Chgr	Yes	Yes
DC	1DC07E	C&D/125V DC Bat Chgr	Yes	Yes
DC	1DC08E	C&D/125V DC Bat Chgr	Yes	Yes
DC	1DC13E	ITE/Series 5600 MCC	Yes	Yes
DC	1DC14E	ITE/Series 5600 MCC	Yes	Yes
DC	1DC15E	Gld-ITE/5600 Series MCC	Yes	Yes
DG	1DG01CA	IngrslRnd/1R-T15 Comp	Yes	Yes
DG	1DG01CB	IngrslRnd/1R-T15 Comp	Yes	Yes
RH	1DG01FE	Air Intake Fltr	Yes	Yes
DG	1DG01JA(M)	S&S/Transf Pnl	Yes	Yes
DG	1DG01JB(M)	S&S/Transf Pnl	Yes	Yes
DG	1DG01KA	IdEl/Diesel Gen 1A	Yes	Yes
DG	1DG01KB	IdEl/Diesel Gen 1B	Yes	Yes
DG	1DG01TA	Reco/DG Day Tank	Yes	Yes
DG	1DG01TB	Reco/DG Day Tank	Yes	Yes
DG	1DG01TC	Reco/DG Day Tank	Yes	Yes
DG	1DG02CA	IngrslRnd/1R-T15 Comp	Yes	Yes
DG	1DG02CB	IngrslRnd/1R-T15 Comp	Yes	Yes
DG	1DG02MA	PathBell/2" Exp Joint	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DG	1DG02MB	PathBell/2" Exp Joint	Yes	Yes
DG	1DG02MC	PathBell/2" Exp Joint	Yes	Yes
DG	1DG02MD	PathBell/2" Exp Joint	Yes	Yes
DG	1DG02ME	PathBell/2" Exp Joint	Yes	Yes
DG	1DG02MF	PathBell/2" Exp Joint	Yes	Yes
DG	1DG03CA (M)	IngRand/Air Comp	Yes	Yes
DG	1DG03CB (M)	Ing Rand/Air Comp	Yes	Yes
DG	1DG04TA	S&S/700 Gal Air Rcvr	Yes	Yes
DG	1DG04TB	S&S/700 Gal Air Rcvr	Yes	Yes
DG	1DG05TA	S&S/700 Gal Air Rcvr	Yes	Yes
DG	1DG05TB	S&S/700 Gal Air Rcvr	Yes	Yes
DG	1DG06SA	S&S/Air St Unit 1 Skid	Yes	Yes
DG	1DG06SB	S&S/Air St Unit 1 Skid	Yes	Yes
DG	1DG06SC (M)	S&S/	Yes	Yes
DG	1DG06TA (M)	S&S/	Yes	Yes
DG	1DG06TB (M)	S&S/	Yes	Yes
DG	1DG11AA	AmStd/Ht Exch	Yes	Yes
DG	1DG11AB	AmStd/Ht Exch	Yes	Yes
DG	1DG12AA	AmStd/Ht Exch	Yes	Yes
DG	1DG12AB	AmStd/Ht Exch	Yes	Yes
DG	1DG13A (M)	AmStack/Ht Exch	Yes	No
DG	1DG14AA	GM/EMD/LO Cooler	Yes	Yes
DG	1DG14AB	GM/EMD/LO Cooler	Yes	Yes
DG	1DG15AA	GM/EMD/LO Cooler	Yes	Yes
DG	1DG15AB	GM/EMD/LO Cooler	Yes	Yes
DG	1DG17TA	GM/Emd/Exp Tank	Yes	Yes
DG	1DG17TB	GM/Emd/Exp Tank	Yes	Yes
DG	1DG18TA	GM/Emd/Exp Tank	Yes	Yes
DG	1DG18TB	GM/Emd/Exp Tank	Yes	Yes
DG	1DG19PA	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG19PB	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG19PC	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG19PD	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG19T (M)	S&S/	Yes	No
DG	1DG20MA	Path Bell/36" Exp Joint	Yes	Yes
DG	1DG20MB	Path Bell/36" Exp Joint	Yes	Yes
DG	1DG20MC	Path Bell/36" Exp Joint	Yes	Yes
DG	1DG20PA	GM/EMD/Cooling Wtr Pmp	Yes	Yes
DG	1DG20PB	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG20PC	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG20PD	GM/Emd/Cooling Wtr Pmp	Yes	Yes
DG	1DG21PA (M)	S&S/	Yes	No
DG	1DG21PB (M)	S&S/	Yes	No
DO	1DO005A	Dresser/.75" SRV	Yes	Yes
DO	1DO005B	Dresser/.75 SRV	Yes	Yes
DO	1DO005C	Dresser/.75 SRV	Yes	Yes
DO	1DO01PA (M)	Wsths/DO Tran Pmp Mtr	Yes	Yes
DO	1DO01PA (P)	TrnsAmDiv1/DO Tran Pmp	Yes	Yes
DO	1DO01PB (M)	Wsths/DO Tran Pmp Mtr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DO	1D001PB(P)	TrnsAmDiv1/DO Tran Pmp	Yes	Yes
DO	1D001PC(M)	Wsths/DO Tran Pmp Mtr	Yes	Yes
DO	1D001PC(P)	TrnsAmDiv1/DO Tran Pmp	Yes	Yes
DO	1D001TA	CB&I/DO Tank	Yes	Yes
DO	1D001TB	CB&I/DO Tank	Yes	Yes
DO	1D001TC	Reco/Tank	Yes	Yes
DO	1D006MA	Leslie/Y-Type Strainer	Yes	Yes
DO	1D006MB	Leslie/Y-Type Strainer	Yes	Yes
DO	1D006MC	Leslie/Y-Type Strainer	Yes	Yes
DO	1D0609	S&S/3/4" Chk Vlv 212C-2	Yes	Yes
RH	1E12-B001A	GE/RHR Heat Exchanger	Yes	Yes
RH	1E12-B001B	GE/RHR Heat Exchanger	Yes	Yes
RH	1E12-C002A(M)	GE/5K634BXC106A	Yes	Yes
RH	1E12-C002A(P)	ByrnJksn/28DX1 3Stage	Yes	Yes
RH	1E12-C002B(M)	GE/5K634BXC106A	Yes	Yes
RH	1E12-C002B(P)	ByrnJksn/28DX1 3Stage	Yes	Yes
RH	1E12-C002C(M)	GE/5K634BXC106A	Yes	Yes
RH	1E12-C002C(P)	ByrnJksn/28DX1 3Stage	Yes	Yes
RH	1E12-C003(M)	Rlnc/5HP 215T	Yes	Yes
RH	1E12-C003(P)	Gld/Pmp 3196ST	Yes	Yes
RH	1E12-D301A	JohnsonDiv/Strainer	Yes	Yes
RH	1E12-D301B	JohnsonDiv/Strainer	Yes	Yes
RH	1E12-D301C	JohnsonDiv/Strainer	Yes	Yes
RH	1E12-F003A(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F003A(V)	AD/14" G1b Vlv	Yes	Yes
RH	1E12-F003B(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F003B(V)	AD/14" 300# G1b Vlv	Yes	Yes
RH	1E12-F004A(A)	Lmt/SMB-0	Yes	Yes
RH	1E12-F004A(V)	AD/20" 300#FlxWdgGtVlv/SMB-0	Yes	Yes
RH	1E12-F004B(A)	Lmt/SMB-0	Yes	Yes
RH	1E12-F004B(V)	AD/20" 300#FlxWdgGtVlv/SMB-0	Yes	Yes
RH	1E12-F005	Dresser/1.5" SRV	Yes	Yes
RH	1E12-F006A(A)	Lmt/SMB-0-5	Yes	Yes
RH	1E12-F006A(V)	AD/16" 300#FlxWdgGtVlv/SMB-0	Yes	Yes
RH	1E12-F006B(A)	Lmt/SMB-0-5	Yes	Yes
RH	1E12-F006B(V)	AD/16" 300#FlxWdgGtVlv/SMB-0	Yes	Yes
RH	1E12-F008(A)	Lmt/SMB-0	Yes	Yes
RH	1E12-F008(V)	AD/18" 600# Gt Vlv	Yes	Yes
RH	1E12-F009(A)	Lmt/SMB-0	Yes	Yes
RH	1E12-F009(V)	AD/18"-600#Flwd Gt Vlv	Yes	Yes
RH	1E12-F010(L)	Namco/EA-180	Yes	Yes
RH	1E12-F010(V)	AD/18" 600# Gt Vlv	Yes	Yes
RH	1E12-F011A(A)	Lmt/SMB-000-2	Yes	Yes
RH	1E12-F011A(V)	AD/4" 300# CS G1bVlv /SMB-00	Yes	Yes
RH	1E12-F011B(A)	Lmt/SMB-000-2	Yes	Yes
RH	1E12-F011B(V)	AD/4" 300# CS G1bVlv /SMB-00	Yes	Yes
RH	1E12-F014A(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F014A(V)	AD/18" 150# CS Flx Wdg Gt Vlv	Yes	Yes
SX	1E12-F014B(A)	Lmt/SMB-0-25	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12-F014B(V)	AD/18" 150#CSF1xWdgGtV1v/SMB-0	Yes	Yes
RH	1E12-F017A	Dresser/1.5" SRV	Yes	Yes
RH	1E12-F017B	Dresser/1.5" SRV	Yes	Yes
RH	1E12-F021(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F021(V)	AD/14" G1b V1v	Yes	Yes
RH	1E12-F023(A)	Lmt/SMB-00	Yes	Yes
RH	1E12-F023(V)	AD/4" G1b V1v	Yes	Yes
RH	1E12-F024A(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F024A(V)	AD/14"300#F1xWdgGtV1v/SMB-0	Yes	Yes
RH	1E12-F024B(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F024B(V)	AD/14"300#F1xWdgGtV1v/SMB-0	Yes	Yes
RH	1E12-F025A	Dresser/1" SRV	Yes	Yes
RH	1E12-F025B	Dresser/1" SRV	Yes	Yes
RH	1E12-F025C	Dresser/1" SRV	Yes	Yes
RH	1E12-F026A(A)	Lmt/SMB-000	Yes	Yes
RH	1E12-F026A(V)	AD/4"300#F1xWdgGtV1v/SMB-000	Yes	Yes
RH	1E12-F026B(A)	Lmt/SMB-000	Yes	Yes
RH	1E12-F026B(V)	AD/4"300#F1xWdgGtV1v/SMB-000	Yes	Yes
RH	1E12-F027A(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F027A(V)	AD/12" 300#F1xWdgGtV1v	Yes	Yes
RH	1E12-F027B(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F027B(V)	AD/Gt V1v 12"	Yes	Yes
RH	1E12-F028A(A)	Lmt/SMB-00-10	Yes	Yes
RH	1E12-F028A(V)	AD/10" 300#F1xWdgGtV1/SMB-00	Yes	Yes
RH	1E12-F028B(A)	Lmt/SMB-00-10	Yes	Yes
RH	1E12-F028B(V)	AD/10" 300#F1xWdgGtV1/SMB-00	Yes	Yes
RH	1E12-F029A(V)	AD/14" Gt V1v	Yes	Yes
RH	1E12-F029B(V)	AD/14" Gt V1v	Yes	Yes
RH	1E12-F029C(V)	AD/14" Gt V1v	Yes	Yes
RH	1E12-F030	Dresser/V1v	Yes	Yes
RH	1E12-F036	Dresser/4" SRV	Yes	Yes
RH	1E12-F037A(A)	Lmt/SMB-1	Yes	Yes
RH	1E12-F037A(V)	AD/10" G1b V1v	Yes	Yes
RH	1E12-F037B(A)	Lmt/SMB-1	Yes	Yes
RH	1E12-F037B(V)	AD/10" G1b V1v	Yes	Yes
RH	1E12-F039A(L)	Namco/EA-180	Yes	Yes
RH	1E12-F039A(V)	AD/12" Gt V1v	Yes	Yes
RH	1E12-F039B(L)	Namco/EA-180	Yes	Yes
RH	1E12-F039B(V)	AD/12" Gt V1v	Yes	Yes
RH	1E12-F039C(L)	Namco/EA-180	Yes	Yes
RH	1E12-F039C(V)	AD/12" Gt V1v	Yes	Yes
RH	1E12-F040(V)	AD/3" 300# CS G1b V1v	Yes	Yes
RH	1E12-F041A(L)	Namco/EA180	Yes	Yes
RH	1E12-F041A(LS)	Conax/7F20-11005-02	Yes	Yes
RH	1E12-F041A(O)	Asco/NPB320(V)	Yes	Yes
RH	1E12-F041A(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F041A(V)	AD/12" Ck V1v	Yes	Yes
RH	1E12-F041B(L)	Namco/EA180	Yes	Yes
RH	1E12-F041B(LS)	Conax/7F20-11005-02	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12-F041B(O)	Asco/NP8320(V)	Yes	Yes
RH	1E12-F041B(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F041B(V)	AD/12" Ck Vlv	Yes	Yes
RH	1E12-F041C(L)	Namco/EA180	Yes	Yes
RH	1E12-F041C(LS)	Conax/7F20-11005-02	Yes	Yes
RH	1E12-F041C(O)	Asco/NP8320(V)	Yes	Yes
RH	1E12-F041C(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F041C(V)	AD/12" Ck Vlv	Yes	Yes
RH	1E12-F042A(A)	Lmt/SMB-1	Yes	Yes
RH	1E12-F042A(V)	AD/Gt Vlv 12"	Yes	Yes
RH	1E12-F042B(A)	Lmt/SMB-1	Yes	Yes
RH	1E12-F042B(V)	AD/Gt Vlv 12"	Yes	Yes
RH	1E12-F042C(A)	Lmt/SMB-1	Yes	Yes
RH	1E12-F042C(V)	AD/Gt Vlv 12"	Yes	Yes
RH	1E12-F047A(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F047A(V)	AD/14" Gt Vlv	Yes	Yes
RH	1E12-F047B(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F047B(V)	AD/14" Gt Vlv	Yes	Yes
RH	1E12-F048A(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F048A(V)	AD/14" G1b Vlv	Yes	Yes
RH	1E12-F048B(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F048B(V)	AD/14" G1b Vlv	Yes	Yes
RH	1E12-F049(A)	Lmt/SMB-000-2	Yes	Yes
RH	1E12-F049(V)	AD/3" 300# Flx Wdg Gt Vlv	Yes	Yes
RH	1E12-F051A(L)	Namco/EA180	Yes	Yes
RH	1E12-F051A(O)	Asco/2068323U	Yes	Yes
RH	1E12-F051A(OS)	Conax/7F20-11001-01	Yes	Yes
RH	1E12-F051A(V)	Fshr/6" AD G1b Vlv	Yes	Yes
RH	1E12-F051B(L)	Namco/EA180	Yes	Yes
RH	1E12-F051B(O)	Asco/2068323U	Yes	Yes
RH	1E12-F051B(OS)	Conax/7F20-11001-01	Yes	Yes
RH	1E12-F051B(V)	Fshr/6" AD G1b Vlv	Yes	Yes
RH	1E12-F052A(A)	Lmt/SMB-2-40	Yes	Yes
RH	1E12-F052A(V)	AD/8" 900#F1xWdgG1bVlv/SMB-2	Yes	Yes
RH	1E12-F052B(A)	Lmt/SMB-2-40	Yes	Yes
RH	1E12-F052B(V)	AD/8" 900#F1xWdgG1bVlv/SMB-2	Yes	Yes
RH	1E12-F053A(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F053A(V)	AD/10"1500#CSF1xWdgG1bVlvSMB-2	Yes	Yes
RH	1E12-F053B(A)	Lmt/SMB-2	Yes	Yes
RH	1E12-F053B(V)	AD/10"1500#CSF1xWdgG1bVlvSMB-2	Yes	Yes
RH	1E12-F055A	Crosby/SRV	Yes	Yes
RH	1E12-F055B	Crosby/SRV	Yes	Yes
RH	1E12-F060A	Valcor/.75"SolVlv V526-5295-81	Yes	Yes
RH	1E12-F060A(OS)	Conax/7F20-11002-01	Yes	Yes
RH	1E12-F060B	Valcor/.75"SolVlv V526-5295-81	Yes	Yes
RH	1E12-F060B(OS)	Conax/7F20-11002-01	Yes	Yes
RH	1E12-F064A(A)	Lmt/SB-00	Yes	Yes
RH	1E12-F064A(V)	AD/4"300#F1xWdgGtVlv/SMB-00	Yes	Yes
RH	1E12-F064B(A)	Lmt/SB-00	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

DUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12-F064B(V)	AD/4"300#F1xWdgGtVlv/SMB-00	Yes	Yes
RH	1E12-F064C(A)	Lmt/SB-00	Yes	Yes
RH	1E12-F064C(V)	AD/4"300#F1xWdgGtVlv/SMB-00	Yes	Yes
RH	1E12-F065A(L)	Namco/EA180	Yes	Yes
RH	1E12-F065A(LS)	Conax/7F20-11008-01	Yes	Yes
RH	1E12-F065A(O)	Asco/2068323U	Yes	Yes
RH	1E12-F065A(OS)	Conax/7F20-11001-03	Yes	Yes
RH	1E12-F065A(V)	Fshr/2.5" AD G1b Vlv	Yes	Yes
RH	1E12-F065B(L)	Namco/EA180	Yes	Yes
RH	1E12-F065B(LS)	Conax/7F20-11008-01	Yes	Yes
RH	1E12-F065B(O)	Asco/2068323U	Yes	Yes
RH	1E12-F065B(OS)	Conax/7F20-11001-03	Yes	Yes
RH	1E12-F065B(V)	Fshr/2.5" AD G1b Vlv	Yes	Yes
RH	1E12-F066	AD/16" Gt Vlv	Yes	Yes
RH	1E12-F067	AD/14" Gt Vlv	Yes	Yes
RH	1E12-F068A(A)	Lmt/SMB-0-25	Yes	Yes
RH	1E12-F068A(V)	AD/18" Gt Vlv	Yes	Yes
SX	1E12-F068B(A)	Lmt/F1B-0-25	Yes	Yes
SX	1E12-F068B(V)	AD/18" Gt Vlv	Yes	Yes
RH	1E12-F073A(A)	Lmt/SMB-000-5	Yes	Yes
RH	1E12-F073A(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
RH	1E12-F073B(A)	Lmt/SMB-000-5	Yes	Yes
RH	1E12-F073B(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
RH	1E12-F074A(A)*	Lmt/SMB-000-5	Yes	Yes
RH	1E12-F074A(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
RH	1E12-F074B(A)	Lmt/SMB-000-5	Yes	Yes
RH	1E12-F074B(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
RH	1E12-F075A	Valcor/.75"SolVlv V526-5295-81	Yes	Yes
RH	1E12-F075A(OS)	Conax/7F20-11002-01	Yes	Yes
RH	1E12-F075B	Valcor/.75"SolVlv V526-5295-81	Yes	Yes
RH	1E12-F075B(OS)	Conax/7F20-11002-01	Yes	Yes
RH	1E12-F087A(V)	AD/6" G1b Vlv	Yes	Yes
RH	1E12-F087B(V)	AD/6" G1b Vlv	Yes	Yes
RH	1E12-F094(A)	Lmt/SMB-000	Yes	Yes
RH	1E12-F094(V)	AD/4" Gt Vlv	Yes	Yes
RH	1E12-F095	Valcor/.75"SolVlv V527-6131-15	Yes	Yes
RH	1E12-F095(OS)	Conax/7F20-11001-01	Yes	Yes
RH	1E12-F096(A)	Lmt/SMB-000	Yes	Yes
RH	1E12-F096(V)	AD/4" Gt Vlv	Yes	Yes
RH	1E12-F101	Dresser/1" SRV	Yes	Yes
RH	1E12-F103A	GPE/2" Vac Rel Vlv	Yes	Yes
RH	1E12-F103B	GPE/2" Vac Rel Vlv	Yes	Yes
RH	1E12-F104A	GPE/2" Vac Rel Vlv	Yes	Yes
RH	1E12-F104B	GPE/2" Vac Rel Vlv	Yes	Yes
RH	1E12-F105(A)	Lmt/SMB-0	Yes	Yes
RH	1E12-F105(V)	AD/20" 150# F1x Wdg Gt Vlv	Yes	Yes
RH	1E12-F110A(V)	GPE/2" Vac Rlf Vlv	Yes	Yes
RH	1E12-F110B	GPE/2" Vac Rel Vlv	Yes	Yes
RH	1E12-F111A	GPE/2" Vac Rlf Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12-F111B	GPE/2" Vac Rlf Vlv	Yes	Yes
RH	1E12-F301A(L)	Namco/EA180	Yes	Yes
RH	1E12-F301A(LS)	Conax/7F20-11005-01	Yes	Yes
RH	1E12-F301A(O)	Asco/206B323U	Yes	Yes
RH	1E12-F301A(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F301A(V)	Fshr/.75" AO G1b Vlv	Yes	Yes
RH	1E12-F301B(L)	Namco/EA180	Yes	Yes
RH	1E12-F301B(LS)	Conax/7F20-11005-01	Yes	Yes
RH	1E12-F301B(O)	Asco/206B323U	Yes	Yes
RH	1E12-F301B(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F301B(V)	Fshr/.75" AO G1b Vlv	Yes	Yes
RH	1E12-F301C(L)	Namco/EA180	Yes	Yes
RH	1E12-F301C(LS)	Conax/7F20-11005-01	Yes	Yes
RH	1E12-F301C(O)	Asco/206B323U	Yes	Yes
RH	1E12-F301C(OS)	Conax/7F20-11001-02	Yes	Yes
RH	1E12-F301C(V)	Fshr/.75" AO G1b Vlv	Yes	Yes
RH	1E12-F304A	AD/20" Gt Vlv	Yes	Yes
RH	1E12-F304B	AD/20" Gt Vlv	Yes	Yes
RH	1E12-F304C(V)	AD/20" 150# Flx Wdg Gt Vlv	Yes	Yes
RH	1E12-F31B	AD/14" Gt Vlv	Yes	Yes
RH	1E12-F320A	Valcor/.75" Sol Vlv	Yes	Yes
RH	1E12-F320B	Valcor/.75" Sol Vlv	Yes	Yes
RH	1E12-F320C	Valcor/.75" Sol Vlv	Yes	Yes
RH	1E12-F326	Valcor/.75" Sol Vlv	Yes	Yes
RH	1E12-N008A(S)	Conax/7F20-11006-01	Yes	Yes
RH	1E12-N053A	Rsmt/1152 GP8E	Yes	Yes
RH	1E12-N053B	Rsmt/1152 GP8E	Yes	Yes
RH	1E12-N053C	Rsmt/1152 GP8E	Yes	Yes
RH	1E12-N055B	Rsmt/1153	Yes	Yes
RH	1E12-N055B(S)	Conax/7F20-11006-02	Yes	Yes
RH	1E12-N055C	Rsmt/1153	Yes	Yes
RH	1E12-N055C(S)	Conax/7F20-11006-01	Yes	Yes
RH	1E12-N056A	Rsmt/1153	Yes	Yes
RH	1E12-N056A(S)	Conax/7F20-11006-02	Yes	Yes
RH	1E12-N056B	Rsmt/1153	Yes	Yes
RH	1E12-N056B(S)	Conax/7F20-11006-02	Yes	Yes
RH	1E12-N057	Rsmt/1152 GP8E	Yes	Yes
RH	1E12-N062A	Rsmt/1153	Yes	Yes
RH	1E12-N062A(S)	Conax/7F20-11006-02	Yes	Yes
RH	1E12-N062B	Rsmt/1153	Yes	Yes
RH	1E12-N062B(S)	Conax/7F20-11006-02	Yes	Yes
RH	1E12-N550	Wd/Thermowell	Yes	No
RH	1E12-N551	Wd/Thermowell	Yes	No
RH	1E12-N575	Wsths/Current Transducers V-4	Yes	Yes
RH	1E12-N576	Wsths/Current Transducers V-4	Yes	Yes
RH	1E12-N577	Wsths/Current Transducers V-4	Yes	Yes
RH	1E12-N578	Rsmt/1153	Yes	Yes
RH	1E12-N579	Rsmt/1153	Yes	Yes
RH	1E12-N580	ITBrtn/LqdLv1Msrng Sys 352/752	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
RH	1E12-N581	ITTBrtn/LqsLviMarg Sys 352/752	Yes	Yes
RH	1E12-N582	Wd/Thermowell	Yes	Yes
RH	1E12-N583	Wd/RTD-612-1B-A-3-C-12-0-0	Yes	Yes
RH	1E12-N584	Wd/Thermowell	Yes	Yes
RH	1E12-N585	Wd/RTD-612-1B-A-3-C-12-0-0	Yes	Yes
RH	1E12-N586	Wd/Thermowell	Yes	Yes
RH	1E12-N587	Wd/RTD-612-1B-A-3-C-12-0-0	Yes	Yes
RH	1E12-N588	Wd/Rtd	Yes	Yes
RH	1E12-N589	Wd/RTD-612-1B-A-3-C-12-0-0	Yes	Yes
RH	1E12-N590	Wd/Sig Conv	Yes	Yes
RH	1E12-N591	Wd/Sig Conv	Yes	Yes
RH	1E12-N592	Wd/Sig Conv	Yes	Yes
RH	1E12-N593	Wd/Sig Conv	Yes	Yes
RH	1E12-N594	Opt Isol	Yes	No
RH	1E12-N595	Opt Isol	Yes	No
RH	1E12-N596	Opt Isol	Yes	No
RH	1E12-N597	Opt Isol	Yes	No
RH	1E12-N598	Opt Isol	Yes	No
RH	1E12-N599	Opt Isol	Yes	No
RH	1E12-N647A	Rsmt/510 DU	Yes	Yes
RH	1E12-N647B	Rsmt/510 DU	Yes	Yes
RH	1E12-N647C	Rsmt/510 DU	Yes	Yes
RH	1E12-N650A	Rsmt/510 DU	Yes	Yes
RH	1E12-N650B	Rsmt/510 DU	Yes	Yes
RH	1E12-N651A	Rsmt/510 DU	Yes	Yes
RH	1E12-N651B	Rsmt/510 DU	Yes	Yes
RH	1E12-N652A	Rsmt/510 DU	Yes	Yes
RH	1E12-N652B	Rsmt/510 DU	Yes	Yes
RH	1E12-N652C	Rsmt/510 DU	Yes	Yes
RH	1E12-N653A	Rsmt/510 DU	Yes	Yes
RH	1E12-N653B	Rsmt/510 DU	Yes	Yes
RH	1E12-N654A	Rsmt/510 DU	Yes	Yes
RH	1E12-N654B	Rsmt/510 DU	Yes	Yes
RH	1E12-N654C	Rsmt/510 DU	Yes	Yes
RH	1E12-N655A	Rsmt/510 DU	Yes	Yes
RH	1E12-N655B	Rsmt/510 DU	Yes	Yes
RH	1E12-N655C	Rsmt/510 DU	Yes	Yes
RH	1E12-N656A	Rsmt/510 DU	Yes	Yes
RH	1E12-N656B	Rsmt/510 DU	Yes	Yes
RH	1E12-N656C	Rsmt/510 DU	Yes	Yes
RH	1E12-N657	Rsmt/510 DU	Yes	Yes
RH	1E12-N658A	Rsmt/510 DU	Yes	Yes
RH	1E12-N658B	Rsmt/510 DU	Yes	Yes
RH	1E12-N658C	Rsmt/510 DU	Yes	Yes
RH	1E12-N662A	Rsmt/510 DU	Yes	Yes
RH	1E12-N662B	Rsmt/510 DU	Yes	Yes
RH	1E12-N662C	Rsmt/510 DU	Yes	Yes
RH	1E12-N662D	Rsmt/510 DU	Yes	Yes
RH	1E12-R002A	RbtShaw/613B	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12-R002B	RbtShaw/613B	Yes	Yes
RH	1E12-R002C	RbtShaw/613B	Yes	Yes
RH	1E12-R008A	R/Shaw/613B	Yes	Yes
RH	1E12-R008B	R/Shaw/613B	Yes	Yes
RH	1E12-R008C	R/Shaw/613B	Yes	Yes
RH	1E12-R555	GE/180 Vert Ind	Yes	Yes
RH	1E12-R556	GE/180 Vert Ind	Yes	Yes
RH	1E12-R557	GE/180 Vert Ind	Yes	Yes
RH	1E12-R563	GE/180 Vert Ind	Yes	Yes
RH	1E12-R564	GE/180 Vert Ind	Yes	Yes
RH	1E12-R565	GE/180 Vert Ind	Yes	Yes
RH	1E12-R566	GE/180 Vert Ind	Yes	Yes
RH	1E12-R602A	GE/180 Vert Indc	Yes	Yes
RH	1E12-R602B	GE/180 Vert Indc	Yes	Yes
RH	1E12-R603A	GE/180 Vert Indc	Yes	Yes
RH	1E12-R603B	GE/180 Vert Indc	Yes	Yes
RH	1E12-R603C	GE/180 Vert Indc	Yes	Yes
RH	1E12-R607	GE/180 Vert Indc	Yes	Yes
RH	1E12A-S002A	Cutler Hammer/Push Button Sw	Yes	No
RH	1E12A-S021	Cutler Hammer/Push Button Sw	Yes	Yes
RH	1E12A-S022A	Cutler Hammer/Push Button Sw	Yes	Yes
RH	1E12A-S022B	Cutler Hammer/Push Button Sw	Yes	Yes
RH	1E12A-S063A	Cutler Hammer/Push Button Sw	Yes	Yes
RH	1E12A-S063B	Cutler Hammer/Push Button Sw	Yes	Yes
RH	1E12AS002A	GE/CR2940	Yes	Yes
RH	1E12AS002B	GE/CR2940	Yes	Yes
RH	1E12AS003A	ElctrSw/20K Hand Sw	Yes	Yes
RH	1E12AS003B	ElctrSw/20K Hand Sw	Yes	Yes
RH	1E12AS003C	ElctrSw/20K Hand Sw	Yes	Yes
RH	1E12AS004A	GE/CR2940	Yes	Yes
RH	1E12AS004B	GE/CR2940	Yes	Yes
RH	1E12AS004C	GE/CR2940	Yes	Yes
RH	1E12AS005A	GE/CR2940	Yes	Yes
RH	1E12AS005B	GE/CR2940	Yes	Yes
RH	1E12AS006A	GE/CR2940	Yes	Yes
RH	1E12AS006B	GE/CR2940	Yes	Yes
RH	1E12AS007A	GE/CR2940	Yes	Yes
RH	1E12AS007B	GE/CR2940	Yes	Yes
RH	1E12AS010A	GE/CR2940	Yes	Yes
RH	1E12AS010B	GE/CR2940	Yes	Yes
RH	1E12AS010C	GE/CR2940	Yes	Yes
RH	1E12AS012A	GE/CR2940	Yes	Yes
RH	1E12AS012B	GE/CR2940	Yes	Yes
RH	1E12AS012C	GE/CR2940	Yes	Yes
RH	1E12AS016A	GE/CR2940	Yes	Yes
RH	1E12AS016B	GE/CR2940	Yes	Yes
RH	1E12AS016C	GE/CR2940	Yes	Yes
RH	1E12AS020A	GE/CR2940	Yes	Yes
RH	1E12AS020B	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RH	1E12AS020C	GE/CR2940	Yes	Yes
RH	1E12AS034A	GE/CR2940	Yes	Yes
RH	1E12AS034B	GE/CR2940	Yes	Yes
RH	1E12AS035A	GE/CR2940	Yes	Yes
RH	1E12AS035B	GE/CR2940	Yes	Yes
RH	1E12AS036A	GE/CR2940	Yes	Yes
RH	1E12AS036B	GE/CR2940	Yes	Yes
RH	1E12AS037A	GE/CR2940	Yes	Yes
RH	1E12AS037B	GE/CR2940	Yes	Yes
RH	1E12AS039A	GE/CR2940	Yes	Yes
RH	1E12AS039B	GE/CR2940	Yes	Yes
RH	1E12AS040A	GE/CR2940	Yes	Yes
RH	1E12AS040B	GE/CR2940	Yes	Yes
RH	1E12AS041A	GE/CR2940	Yes	Yes
RH	1E12AS041B	GE/CR2940	Yes	Yes
RH	1E12AS043A	GE/CR2940	Yes	Yes
RH	1E12AS043B	GE/CR2940	Yes	Yes
RH	1E12AS043C	GE/CR2940	Yes	Yes
RH	1E12AS054A	GE/CR2940	Yes	Yes
RH	1E12AS054B	GE/CR2940	Yes	Yes
RH	1E12AS056	GE/CR2940	Yes	Yes
RH	1E12AS057	ElctrSw/20K Hand Sw	Yes	Yes
RH	1E12AS058A	GE/CR2940	Yes	Yes
RH	1E12AS058B	GE/CR2940	Yes	Yes
RH	1E12AS059A	GE/CR2940	Yes	Yes
RH	1E12AS059B	GE/CR2940	Yes	Yes
RH	1E12AS060	GE/CR2940	Yes	Yes
RH	1E12AS061	GE/CR2940	Yes	Yes
RH	1E12AS062A	GE/CR2940	Yes	Yes
RH	1E12AS062B	GE/CR2940	Yes	Yes
RH	1E12AS064A	GE/CR2940	Yes	Yes
RH	1E12AS064B	GE/CR2940	Yes	Yes
RH	1E12AS068A	GE/CR2940	Yes	Yes
RH	1E12AS068B	GE/CR2940	Yes	Yes
RH	1E12AS069A	GE/CR2940	Yes	Yes
RI	1E12AS069B	GE/CR2940	Yes	Yes
LP	1E21-C001	GE/LPCS Pmp Mtr 5K6339XC191A	Yes	Yes
LP	1E21-C001(P)	BynJksn/28DX21 4Stage	Yes	Yes
LP	1E21-C002(M)	RInc/5HP, 215T	Yes	Yes
LP	1E21-C002(P)	Gld/Pmp 3196ST	Yes	Yes
LP	1E21-D301	JohnsonDiv/Strainer	Yes	Yes
LP	1E21-F001(A)	Lmt/SMB-0	Yes	Yes
LP	1E21-F001(V)	AD/20" 150# Flx Wdg Gt Vlv	Yes	Yes
LP	1E21-F005(A)	Lmt/SMB-1	Yes	Yes
LP	1E21-F005(V)	AD/Gt Vlv 10"	Yes	Yes
LP	1E21-F006(L)	Namco/EA180	Yes	Yes
LP	1E21-F006(LS)	Conax/7F20-11000-01	Yes	Yes
LP	1E21-F006(O)	Asco/NP8320(V)	Yes	Yes
LP	1E21-F006(OS)	Conax/7F20-11001-02	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LP	1E21-F006(V)	AD/10" Tit Dsc Ck	Yes	Yes
LP	1E21-F007	AD/10"-600# Gt Vlv	Yes	Yes
LP	1E21-F007(L)	Namco/EA-180	Yes	Yes
LP	1E21-F011(A)	Lmt/SMB-000	Yes	Yes
LP	1E21-F011(V)	AD/4" Gt Vlv	Yes	Yes
LP	1E21-F012(A)	Lmt/SMB-1	Yes	Yes
LP	1E21-F012(V)	AD/10" 300# Glb Vlv	Yes	No
LP	1E21-F018	Dresser/1 1/2" SRV	Yes	Yes
LP	1E21-F031	Dresser/1" SRV	Yes	Yes
LP	1E21-F301(V)	AD/20" 150# Flx Wdg Gt Vlv	Yes	Yes
LP	1E21-F309(V)	AD/12" Gt Vlv	Yes	Yes
LP	1E21-F340(L)	Namco/EA180	Yes	Yes
LP	1E21-F340(LS)	Conax/7F20-11005-01	Yes	Yes
LP	1E21-F340(O)	Asco/2068323U	Yes	Yes
LP	1E21-F340(OS)	Conax/7F20-11001-02	Yes	Yes
LP	1E21-F340(V)	Fshr/.75" AD Glb Vlv	Yes	Yes
LP	1E21-F342	Valcor/.75" Sol Vlv	Yes	Yes
LP	1E21-N054	Rsmr/1152	Yes	Yes
LP	1E21-N558	GE/Type 180 Ammeter	Yes	Yes
LP	1E21-N561	GE/180 Vert	Yes	Yes
LP	1E21-N649	Rsmr/510 DU	Yes	Yes
LP	1E21-N650	Rsmr/510 DU	Yes	Yes
LP	1E21-N651	Rsmr/510 DU	Yes	Yes
LP	1E21-N652	Rsmr/510 DU	Yes	Yes
LP	1E21-N653	Rsmr/510 DU	Yes	Yes
LP	1E21-N654	Rsmr/510 DU	Yes	Yes
LP	1E21-N655	Rsmr/510 DU	Yes	Yes
LP	1E21-R001	RbtShaw/613B	Yes	Yes
LP	1E21-R002	RbtShaw/613B	Yes	Yes
LP	1E21-R600	GE/180 Vert Ind	Yes	Yes
LP	1E21A-S009	Cutler Hammer/10250T	Yes	Yes
LP	1E21AS001	GE/CR2940	Yes	Yes
LP	1E21AS002	GE/CR2940	Yes	Yes
LP	1E21AS003	GE/CR2940	Yes	Yes
LP	1E21AS004	GE/CR2940	Yes	Yes
LP	1E21AS005	GE/CR2940	Yes	Yes
LP	1E21AS006	ElctrSw/20K Hand Sw	Yes	Yes
LP	1E21AS007	ElctrSw/20K Hand Sw	Yes	Yes
LP	1E21AS008	GE/CR2940	Yes	Yes
LP	1E21AS010	GE/CR2940	Yes	Yes
LP	1E21AS011	GE/CR2940	Yes	Yes
HP	1E22-C001	GE/HPCS Pmp Mtr 5K6340XC106A	Yes	Yes
HP	1E22-C001(P)	BrnJksn/28DX18CKXL	Yes	Yes
HP	1E22-C003(M)	Rlnc/5HP 215T	Yes	Yes
HP	1E22-C003(P)	Gld/Pmp 3196ST	Yes	Yes
DG	1E22-C302	Delco/C-992 Mtr	No	No
HP	1E22-D301	JohnsonDiv/Strainer	Yes	Yes
HP	1E22-F001(A)	Lmt/SMB-00-10	Yes	Yes
HP	1E22-F001(V)	AD/16" Gt Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
HP	1E22-F004(A)	Lmt/SB-3-80	Yes	Yes
HP	1E22-F004(V)	AD/10" Gt Vlv	Yes	Yes
HP	1E22-F005(L)	Namco/EA180	Yes	Yes
HP	1E22-F005(LS)	Conax/7F20-11005-01	Yes	Yes
HP	1E22-F005(O)	Asco/NP8320(V)	Yes	Yes
HP	1E22-F005(OS)	Conax/7F20-11001-02	Yes	Yes
HP	1E22-F005(V)	AD/10" Nsl Ck (Air Oper)	Yes	Yes
HP	1E22-F010(A)	Lmt/SMB-4-200	Yes	Yes
HP	1E22-F010(V)	AD/10" G1b Vlv	Yes	Yes
HP	1E22-F011(A)	Lmt/SMB-4-200	Yes	Yes
HP	1E22-F011(V)	AD/10" G1b Vlv	Yes	Yes
HP	1E22-F012(A)	Lmt/SB-0-25	Yes	Yes
HP	1E22-F012(V)	AD/4" Gt Vlv	Yes	Yes
HP	1E22-F014	Dresser/.75" SRV	Yes	Yes
HP	1E22-F015(A)	Lmt/SB-1-40	Yes	Yes
HP	1E22-F015(V)	AD/20" Gt Vlv	Yes	Yes
HP	1E22-F023(A)	Lmt/SMB-3-150	Yes	Yes
HP	1E22-F023(V)	AD/10" G1b Vlv	Yes	Yes
HP	1E22-F035	Dresser/.75" SRV	Yes	Yes
HP	1E22-F036(L)	Namco/EA-180	Yes	Yes
HP	1E22-F036(V)	AD/10"-900# Gt Vlv	Yes	Yes
HP	1E22-F039	Dresser/.75" SRV	Yes	Yes
HP	1E22-F301(V)	AD/14" Gt Vlv	Yes	Yes
HP	1E22-F304(L)	Namco/EA180	Yes	Yes
HP	1E22-F304(LS)	Conax/7F20-11005-01	Yes	Yes
HP	1E22-F304(O)	Asco/NP8320(V)	Yes	Yes
HP	1E22-F304(OS)	Conax/7F20-11001-02	Yes	Yes
HP	1E22-F304(V)	Fshr/.75" A0 G1b Vlv	Yes	Yes
HP	1E22-F314(V)	AD/20" 150# Flx Wdg Gt Vlv	Yes	Yes
HP	1E22-F318(V)	AD/16" Gt Vlv	Yes	Yes
HP	1E22-F339	Valcor/.75" Sol Vlv	Yes	Yes
HP	1E22-N050	Rsmt/1153	Yes	Yes
HP	1E22-N052	Rsmt/1152 GP6E	Yes	Yes
HP	1E22-N055C	Gld/PD3218	Yes	Yes
HP	1E22-N055C(S)	Conax/7F20-11008-01	Yes	Yes
HP	1E22-N055G	Gld/PD3218	Yes	Yes
HP	1E22-N055G(S)	Conax/7F20-11008-01	Yes	Yes
HP	1E22-N650	Rsmt/510 DU	Yes	Yes
HP	1E22-N651	Rsmt/510 DU	Yes	Yes
HP	1E22-N652	Rsmt/510 DU	Yes	Yes
HP	1E22-N653	Rsmt/510 DU	Yes	Yes
HP	1E22-N654C	Rsmt/510 DU	Yes	Yes
HP	1E22-N654G	Rsmt/510 DU	Yes	Yes
HP	1E22-N655C	Rsmt/510 DU	Yes	Yes
HP	1E22-N655G	Rsmt/510 DU	Yes	Yes
HP	1E22-N656	Rsmt/510 DU	Yes	Yes
HP	1E22-R001	R/Shaw/613B	Yes	Yes
HP	1E22-R002	R/Shaw/613B	Yes	Yes
HP	1E22-R003	R/Shaw/613B	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
HP	1E22-R601	GE/180 Vert Indc	Yes	Yes
HP	1E22-R603	GE/180 Vert Indc	Yes	Yes
HP	1E22-R604	GE/180 Vert Indc	Yes	Yes
HP	1E22-R606	GE/180 Vert Indc	Yes	Yes
HP	1E22-R620	GE/180 Vert Ind	Yes	Yes
HP	1E22-R621	GE/180 Vert Ind	Yes	Yes
HP	1E22-R625	GE/180 Vert Ind	Yes	Yes
HP	1E22-S001	S&S/2200KW Gen Set	Yes	No
HP	1E22-S001	BPS/DG HPCS	Yes	No
DG	1E22-S001A(M)	BPS/Div 3 DG	Yes	No
HP	1E22-S001B(M)	GE/Div 3 DG Cnt Pnl	Yes	No
HP	1E22-S001C(M)	GE/Div 3 DG Cubicle	Yes	No
HP	1E22-S001D(M)	GE/Batt	Yes	Yes
HP	1E22-S001E	C&D/ARR130HK100	Yes	Yes
DG	1E22-S001F(M)	GE/Div 3 Lo Mon	Yes	No
DG	1E22-S001F(M)	Delco/Dv 3 DG Circ Oil Pmp Mtr	Yes	No
DG	1E22-S001G	GE/Div 3 DG Air Comp	Yes	No
HP	1E22-S001H(M)	GE/Div 3 DG Space Htr	Yes	No
HP	1E22-S001J(M)	GE/Div 3 DG Immersion Htr	Yes	No
HP	1E22-S002	PwlElct/MCC For HPCS Syst	Yes	Yes
HP	1E22-S003	Elma/HPCS Xtrmr 225KVA	Yes	Yes
HP	1E22-S004	GE/4.16KV HPCS Switchgr	Yes	Yes
HP	1E22AS001	GE/CR2940	Yes	Yes
DG	1E22AS002	Cutler Hammer/10250T	Yes	Yes
HP	1E22AS003	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22AS004	GE/CR2940	Yes	Yes
HP	1E22AS005	GE/CR2940	Yes	Yes
HP	1E22AS006	GE/CR2940	Yes	Yes
HP	1E22AS007	GE/CR2940	Yes	Yes
HP	1E22AS008	GE/CR2940	Yes	Yes
HP	1E22AS009	GE/CR2940	Yes	Yes
HP	1E22AS010	GE/CR2940	Yes	Yes
HP	1E22AS011	GE/CR2940	Yes	Yes
HP	1E22AS012	GE/CR2940	Yes	Yes
HP	1E22AS013	GE/CR2940	Yes	Yes
HP	1E22AS014	GE/CR2940	Yes	Yes
HP	1E22AS015	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22BK01	GE/HEA Rly	Yes	Yes
HP	1E22BK02	GE/HMA Rly	Yes	Yes
HP	1E22BK03	GE/HMA Rly	Yes	Yes
HP	1E22BK04	GE/HMA Rly	Yes	Yes
HP	1E22BK05	GE/HMA Rly	Yes	Yes
HP	1E22BK07	GE/HFA Rly	Yes	Yes
HP	1E22BK08	GE/PVJ Rly	Yes	Yes
HP	1E22BK09	GE/HFA Rly	Yes	Yes
HP	1E22BK10	GE/PVJ Rly	Yes	Yes
HP	1E22BK11	GE/HFA Rly	Yes	Yes
HP	1E22BK12	GE/HMA Rly	Yes	Yes
HP	1E22BK13	GE/HMA Rly	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
HP	1E22BK16	GE/HFA Rly	Yes	Yes
HP	1E22BK30A	GE/PVD Rly	Yes	Yes
HP	1E22BK30B	GE/PVD Rly	Yes	Yes
HP	1E22BK30C	GE/PVD Rly	Yes	Yes
HP	1E22BK31	GE/CEH Rly	Yes	Yes
HP	1E22BK32	GE/GGP Rly	Yes	Yes
HP	1E22BK33A	GE/IAC Rly	Yes	Yes
HP	1E22BK33B	GE/IAC Rly	Yes	Yes
HP	1E22BK34	GE/IAV Rly	Yes	Yes
HP	1E22BK35A	GE/IJCV Rly	Yes	Yes
HP	1E22BK35B	GE/IJCV Rly	Yes	Yes
HP	1E22BK35C	GE/IJCV Rly	Yes	Yes
HP	1E22BS001	GE/CR2940	Yes	Yes
HP	1E22BS003	GE/CR2940	Yes	Yes
HP	1E22BS004	GE/CR2940	Yes	Yes
HP	1E22BS005	GE/CR2940	Yes	Yes
HP	1E22BS006	GE/CR2940	Yes	Yes
HP	1E22BS007	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22BS008	GE/CR2940	Yes	Yes
HP	1E22BS009	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22BS010	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22BS011	GE/CR2940	Yes	Yes
HP	1E22BS012	ElctrSw/20K Hand Sw	Yes	Yes
HP	1E22BS013	GE/CR2940	Yes	Yes
HP	1E22BS014	GE/CR2940	Yes	Yes
HP	1E22BS015	ElctrSw/20K Hand Sw	Yes	Yes
LD	1E31-F014	Valcor/1" Sol Vlv V526-5960-1	Yes	Yes
LD	1E31-F014(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-F015	Valcor/1" Sol Vlv V526-5960-2	Yes	Yes
LD	1E31-F015(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-F016	Valcor/1" Sol Vlv V526-5960-1	Yes	Yes
LD	1E31-F016(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-F017	Valcor/1" Sol Vlv V526-5960-3	Yes	Yes
LD	1E31-F017(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-F018	Valcor/1" Sol Vlv V526-5960-1	Yes	Yes
LD	1E31-F018(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-F019	Valcor/1" Sol Vlv V526-5960-1	Yes	Yes
LD	1E31-F019(OS)	Conax/7F20-11002-03	Yes	Yes
LD	1E31-K600F	Sola/9T66Y	Yes	Yes
LD	1E31-K600B	Sola/9T66Y	Yes	Yes
LD	1E31-K602A	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-K602B	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-K603A	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-K603B	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-K604A	Bailey/RWCUSysDiffFlwSumr/752	Yes	Yes
LD	1E31-K604B	Bailey/RWCUSysDiffFlwSumr/752	Yes	Yes
LD	1E31-K605A	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-K605B	Bailey/750 SQ R Convtr	Yes	Yes
LD	1E31-N001A	Pyco/TE-102-9039-11-6,Type E	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31-N001A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N001B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N001B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N002A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N002B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N003A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N003B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N004A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N004A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N004B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N004B(S)	Conax/7F10-11009-01	Yes	Yes
LD	1E31-N005A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N005B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N006A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N006B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N017A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N017A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N017B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N017B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N017C	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
NB	1E31-N017C(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N017D	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N017D(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N018A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N018A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N018B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N018B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N027A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N027B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N028A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N028B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N029A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N029B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N029C	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N029D	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N030A	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N030B	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N030C	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N030D	Wd/TC-E4B250U-8A5	Yes	Yes
LD	1E31-N031A	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N031A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N031B	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N031B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N031C	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N031C(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N031D	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N031D(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N034A	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N034A(S)	Conax/7F20-11009-01	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31-N034B	Pyco/TE-102-9039-08-6, Type T	Yes	Yes
LD	1E31-N034B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N035A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N035B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N036A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N036B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N037A	Pyco/TE-102-9039-11-6, Type T	Yes	Yes
LD	1E31-N037A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N037B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N037B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N037E	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N037E(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N037F	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N037F(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N038A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N038B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N038E	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N038F	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N039A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N039B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N039E	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N039F	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N040A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N040A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N040B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N040B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N041A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N041B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N042A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N042B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N044A	Pyco/TE-102-9039-11-6, Type E	No	Yes
LD	1E31-N044A(S)	Conax/7F20-11009-01	No	Yes
LD	1E31-N044B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N044B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N045A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N045A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N045B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N045B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N052A	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N052A(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N052B	Pyco/TE-102-9039-11-6, Type E	Yes	Yes
LD	1E31-N052B(S)	Conax/7F20-11009-01	Yes	Yes
LD	1E31-N053A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N053B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N054A	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N054B	Wd/TC-E4B250U-BAS	Yes	Yes
LD	1E31-N059A	Wd/Temp Elem	Yes	Yes
LD	1E31-N059B	Wd/Temp Elem	Yes	Yes
LD	1E31-N059C	Wd/Temp Elem	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31-N059D	Wd/Temp Elem	Yes	Yes
LD	1E31-N060A	Wd/Temp Elem	Yes	Yes
LD	1E31-N060B	Wd/Temp Elem	Yes	Yes
LD	1E31-N060C	Wd/Temp Elem	Yes	Yes
LD	1E31-N060D	Wd/Temp Elem	Yes	Yes
LD	1E31-N061A	Wd/Temp Elem	Yes	Yes
LD	1E31-N061B	Wd/Temp Elem	Yes	Yes
LD	1E31-N061C	Wd/Temp Elem	Yes	Yes
LD	1E31-N061D	Wd/Temp Elem	Yes	Yes
LD	1E31-N062A	Wd/Temp Elem	Yes	Yes
LD	1E31-N062B	Wd/Temp Elem	Yes	Yes
LD	1E31-N062C	Wd/Temp Elem	Yes	Yes
LD	1E31-N062D	Wd/Temp Elem	Yes	Yes
LD	1E31-N063A	Wd/Temp Elem	Yes	Yes
LD	1E31-N063B	Wd/Temp Elem	Yes	Yes
LD	1E31-N063C	Wd/Temp Elem	Yes	Yes
LD	1E31-N063D	Wd/Temp Elem	Yes	Yes
LD	1E31-N063A	Rsmt/1152 DP5E	Yes	Yes
LD	1E31-N080B	Rsmt/1152 DP5E	Yes	Yes
LD	1E31-N081	Rsmt/1152 DP5E	Yes	Yes
LD	1E31-N089A	Rsmt/1153	Yes	Yes
LD	1E31-N089A(S)	Conax/7F20-11006-02	Yes	Yes
LD	1E31-N089B	Rsmt/1153	Yes	Yes
LD	1E31-N089B(S)	Conax/7F20-11006-02	Yes	Yes
LD	1E31-N092	Rsmt/1152 GP8E	Yes	Yes
LD	1E31-N557A	Riley/86PD164C568 Temp Sw	Yes	Yes
LD	1E31-N557B	Riley/86PD164C568 Temp Sw	Yes	Yes
LD	1E31-N557C	Riley/86PD164C568 Temp Sw	Yes	Yes
LD	1E31-N558A	Riley/PPD#164C56861 Temp Sw	Yes	Yes
LD	1E31-N558B	Riley/PPD#164C56861 Temp Sw	Yes	Yes
LD	1E31-N558C	Riley/PPD#164C56861 Temp Sw	Yes	Yes
LD	1E31-N559A	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N559B	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N559C	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N559D	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N560A	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N560B	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N560C	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N560D	Riley/PPD#164C56861 Temp Sw	Yes	Yes
LD	1E31-N561A	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N561B	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N561C	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N561D	Riley/PPD#164C56861 Temp Sw	Yes	Yes
LD	1E31-N562A	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N562B	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N562C	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N562D	Riley/PPD#164C5686 Temp Sw	Yes	Yes
LD	1E31-N563A	Riley/PPD#164C56871 Temp Sw	Yes	Yes
LD	1E31-N563B	Riley/PPD#164C56871 Temp Sw	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM EQUIPMENT NUMBER MANUFACTURER/MODEL NUMBER INSTALLED QUALIFIED

LD	1E31-N563C	Riley/PPD#164C56871 Temp SW	Yes	Yes
LD	1E31-N563D	GE/Temp Switch/PPD#164C568	Yes	Yes
LD	1E31-N577	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N578	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N578	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N578	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N579	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N579	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N579 1*	BlyCntrlr/Auto Sys Instratn	Yes	Yes
LD	1E31-N580	Mgntrl/MiscAutoConSysSerB2Prop	Yes	Yes
LD	1E31-N580 1*	B&W/LVI Xmtg Prob Mtg	Yes	Yes
LD	1E31-N600A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N600B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N602A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N602B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N603A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N603B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N604A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N604B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N604C	GE/PPDI64C568 Temp Monitor	Yes	Yes
LD	1E31-N604D	GE/PPDI64C568 Temp Monitor	Yes	Yes
LD	1E31-N604E	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N604F	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N605A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N605B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N605C	GE/PPDI64C568 Temp Monitor	Yes	Yes
LD	1E31-N605D	GE/PPDI64C568 Temp Monitor	Yes	Yes
LD	1E31-N605E	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N605F	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N608A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N608B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N609A	Bly/7000 Srs Typ 745 LVI Alrm	Yes	Yes
SC	1E31-N609B	Bly/7000 Srs Typ 745 LVI Alrm	Yes	Yes
LD	1E31-N610A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N610B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N611A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N611B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N612A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N612B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N613A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N613B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N613C	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N614A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N614B	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N615A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N618A	Riley/86PDI64C568 Temp Mon	Yes	Yes
LD	1E31-N619A	Riley/86PDI64C568 Temp Mon	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31-N620B	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N621A	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N621B	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N621E	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N621F	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N622A	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N622B	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N626A	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N626B	Riley/86PD164C56B Temp Mon	Yes	Yes
LD	1E31-N680A	Rsmt/510 DU	Yes	Yes
LD	1E31-N680B	Rsmt/510 DU	Yes	Yes
LD	1E31-N680E	Rsmt/510 DU	Yes	Yes
RH	1E31-N680F	Rsmt/510 DU	Yes	Yes
NB	1E31-N681	Rsmt/510 DU	Yes	Yes
LD	1E31-N683A	Rsmt/510 DU	Yes	Yes
RI	1E31-N683B	Rsmt/510 DU	Yes	Yes
RI	1E31-N684A	Rsmt/510 DU	Yes	Yes
RI	1E31-N684B	Rsmt/510 DU	Yes	Yes
RI	1E31-N685A	Rsmt/510 DU	Yes	Yes
RI	1E31-N685B	Rsmt/510 DU	Yes	Yes
RI	1E31-N686A	Rsmt/510 DU	Yes	Yes
MS	1E31-N686B	Rsmt/510 DU	Yes	Yes
MS	1E31-N686C	Rsmt/510 DU	Yes	Yes
LD	1E31-N686D	Rsmt/510 DU	Yes	Yes
LD	1E31-N687A	Rsmt/510 DU	Yes	Yes
MS	1E31-N687B	Rsmt/510 DU	Yes	Yes
MS	1E31-N687C	Rsmt/510 DU	Yes	Yes
LD	1E31-N687D	Rsmt/510 DU	Yes	Yes
LD	1E31-N688A	Rsmt/510 DU	Yes	Yes
MS	1E31-N688B	Rsmt/510 DU	Yes	Yes
MS	1E31-N688C	Rsmt/510 DU	Yes	Yes
LD	1E31-N688D	Rsmt/510 DU	Yes	Yes
LD	1E31-N689A	Rsmt/510 DU	Yes	Yes
MS	1E31-N689B	Rsmt/510 DU	Yes	Yes
MS	1E31-N689C	Rsmt/510 DU	Yes	Yes
LD	1E31-N689D	Rsmt/510 DU	Yes	Yes
LD	1E31-N690A	Rsmt/510 DU	Yes	Yes
RI	1E31-N690B	Rsmt/510 DU	Yes	Yes
LD	1E31-N691A	Rsmt/510 DU	Yes	Yes
RI	1E31-N691B	Rsmt/510 DU	Yes	Yes
LD	1E31-N692	Rsmt/510 DU	Yes	Yes
LD	1E31-N693A	Wd/Thermowell	Yes	Yes
LD	1E31-N693B	Wd/Thermowell	Yes	Yes
SX	1E31-N694A	Wd/Thermowell	Yes	Yes
SX	1E31-N694B	Wd/Thermowell	Yes	Yes
WO	1E31-N701B	Wd/Thermowell	Yes	Yes
LD	1E31-N703A	Wd/Thermowell	Yes	Yes
SX	1E31-N703B	Wd/Thermowell	Yes	Yes
SX	1E31-N704A	Wd/Thermowell	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31-N704B	Wd/Thermowell	Yes	Yes
LD	1E31-N705A	Wd/Thermowell	Yes	Yes
LD	1E31-N705B	Wd/Thermowell	Yes	Yes
SX	1E31-N706A	Wd/Thermowell	Yes	Yes
SX	1E31-N706B	Wd/Thermowell	Yes	Yes
LD	1E31-N709A	Wd/Thermowell	Yes	Yes
WO	1E31-N709B	Wd/Thermowell	Yes	Yes
WO	1E31-N710A	Wd/Thermowell	Yes	Yes
LD	1E31-R550	TrWstr/MultiPnt Rec M11E	Yes	Yes
LD	1E31-R615A	Eagle Timer/HP5	Yes	Yes
LD	1E31-R615B	Eagle Timer/HP5	Yes	Yes
LD	1E31-R617E	Eagle Timer/HP5	Yes	Yes
LD	1E31-R617F	Eagle Timer/HP5	Yes	Yes
LD	1E31A-AT02 1	GE/Opt Isol	Yes	No
LD	1E31A-AT04 0	GE/Opt Isol	Yes	Yes
LD	1E31A-AT05 0	GE/Opt Isol	Yes	Yes
LD	1E31A-AT05 1	GE/Opt Isol	Yes	Yes
LD	1E31A-AT06 0	GE/Opt Isol	Yes	Yes
LD	1E31A-AT06 1	GE/Opt Isol	Yes	Yes
LD	1E31A-AT07 0	GE/Opt Isol	Yes	Yes
LD	1E31A-AT07 1	GE/Opt Isol	Yes	Yes
LD	1E31A-AT09 0	GE/Opt Isol	Yes	Yes
LD	1E31A-AT09 1	GE/Opt Isol	Yes	Yes
LD	1E31A-K01A	Agst/GP1C750	Yes	Yes
LD	1E31A-K01B	Agst/GP1C750	Yes	Yes
LD	1E31A-K02A	Agst/GP1C750	Yes	Yes
LD	1E31A-K02B	Agst/GP1C750	Yes	Yes
LD	1E31A-K03A	Agst/GP1C750	Yes	Yes
LD	1E31A-K03B	Agst/GP1C750	Yes	Yes
LD	1E31A-K04A	Agst/GP1C750	Yes	Yes
LD	1E31A-K04B	Agst/GP1C750	Yes	Yes
LD	1E31A-K05A	Agst/GP1C750	Yes	Yes
LD	1E31A-K05B	Agst/GP1C750	Yes	Yes
LD	1E31A-K06A	Agst/GP1C750	Yes	Yes
LD	1E31A-K06B	Agst/GP1C750	Yes	Yes
LD	1E31A-K07A	Agst/GP1C750	Yes	Yes
LD	1E31A-K07B	Agst/GP1C750	Yes	Yes
LD	1E31A-K08	Agst/GP1C750	Yes	Yes
LD	1E31A-K23	Agst/GP1C750	Yes	Yes
LD	1E31A-K24A	Agst/TR, PPD164C5257	Yes	Yes
LD	1E31A-K24B	Agst/TR, PPD164C5257	Yes	Yes
LD	1E31A-K25A	Agst/Rly	Yes	Yes
LD	1E31A-K25B	Agst/GP1C750	Yes	Yes
LD	1E31A-K26A	Agst/GP1C750	Yes	Yes
LD	1E31A-K26B	Agst/GP1C750	Yes	Yes
LD	1E31A-K27A	Agst/GP1C750	Yes	Yes
LD	1E31A-K27B	Agst/GP1C750	Yes	Yes
LD	1E31A-K28A	Agst/GP1C750	Yes	Yes
LD	1E31A-K28B	Agst/GP1C750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1E31A-K29A	Agst/TR, PPD164C5257	Yes	Yes
LD	1E31A-K29B	Agst/TR, PPD164C5257	Yes	Yes
LD	1E31A-Z4C	GE/Temp Mon/PPD#204B6623	Yes	Yes
LD	1E31A-Z4D	GE/Temp Mon/PPD#204B6623	Yes	Yes
LD	1E31A-Z4D	GE/Temp Mon/PPD#204B6623	Yes	Yes
LD	1E31AS001A	GE/CR2940	Yes	Yes
LD	1E31AS001B	GE/CR2940	Yes	Yes
LD	1E31AS002A	GE/CR2940	Yes	Yes
LD	1E31AS002B	GE/CR2940	Yes	Yes
LD	1E31AS004A	GE/CR2940	Yes	Yes
LD	1E31AS004B	GE/CR2940	Yes	Yes
LD	1E31AS013A	GE/CR2940	Yes	Yes
LD	1E31AS013B	GE/CR2940	Yes	Yes
LD	1E31AZ4CM1C	Riley/86	Yes	Yes
LD	1E31AZ4CM2C	Riley/86	Yes	Yes
LD	1E31AZ4DM1D	Riley/86	Yes	Yes
LD	1E31AZ4DM2D	Riley/86	Yes	Yes
LD	1E31AZ6DM1D	Riley/86	Yes	Yes
LD	1E31AZ6DM2D	Riley/86	Yes	Yes
IS	1E32-B001A(C)	Okonite/Okozei MSIV-LCS HtrCbl	Yes	Yes
IS	1E32-B001A(H)	GE/47D518673 Heater	Yes	Yes
IS	1E32-B001E(C)	Okonite/Okozei MSIV-LCS HtrCbl	Yes	Yes
IS	1E32-B001E(H)	GE/47D518673 Heater	Yes	Yes
IS	1E32-B001J(C)	Okonite/Okozei MSIV-LCS HtrCbl	Yes	Yes
IS	1E32-B001J(H)	GE/47D518673 Heater	Yes	Yes
IS	1E32-B001N(C)	Okonite/Okozei MSIV-LCS HtrCbl	Yes	Yes
IS	1E32-B001N(H)	GE/47D518673 Heater	Yes	Yes
IS	1E32-C001(F)	MSIV Leak Blower	Yes	Yes
IS	1E32-C001(M)	Sms/MSIV L B Mtr 2CH6-041-1U	Yes	Yes
IS	1E32-C002B(F)	MSIV Exh. Blower B	Yes	Yes
IS	1E32-C002B(M)	Sms/MSIV L B Mtr 2CH6-041-1U	Yes	Yes
IS	1E32-C002F(F)	MSIV Exh. Blower F	Yes	Yes
IS	1E32-C002F(M)	Sms/MSIV L B Mtr 2CH6-041-1U	Yes	Yes
IS	1E32-D301	Temp Flex/Exp Joint 3"	Yes	Yes
IS	1E32-D303B	Temp Flex/Exp Joint 4"	Yes	Yes
IS	1E32-D303F	Temp Flex/Exp Joint 4"	Yes	Yes
IS	1E32-F001A(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F001A(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F001E(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F001E(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F001J(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F001J(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F001N(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F001N(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F002A(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F002A(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F002E(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F002E(V)	Yrwy/1.5" G1b Vlv	Yes	Yes
IS	1E32-F002J(A)	Lmt/SMB-000	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
IS	1E32-F002J(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F002N(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F002N(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F003A(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F003A(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F003E(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F003E(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F003J(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F003J(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F003N(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F003N(V)	Yrwy/1.5" G1b V1v	Yes	Yes
IS	1E32-F006(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F006(V)	AD/2.5" Gt V1v	Yes	Yes
IS	1E32-F007(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F007(V)	AD/2.5" Gt V1v	Yes	Yes
IS	1E32-F008(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F008(V)	AD/2.5" Gt V1v	Yes	Yes
IS	1E32-F009(A)	Lmt/SMB-000	Yes	Yes
IS	1E32-F009(V)	AD/2.5" Gt V1v	Yes	Yes
LD	1E32-F015(OS)	Conax/7F20-11002-03	No	No
IS	1E32-K601	Sola/9T66Y	Yes	Yes
IS	1E32-K602	Sola/9T66Y	Yes	Yes
IS	1E32-N006A(S)	Conax/7F20-11002-03	Yes	Yes
IS	1E32-N006E(S)	Conax/7F20-11002-03	Yes	Yes
IS	1E32-N006J(S)	Conax/7F20-11002-03	Yes	Yes
IS	1E32-N006N(S)	Conax/7F20-11002-03	Yes	Yes
IS	1E32-N050(S)	Conax/7F20-11006-02	Yes	Yes
IS	1E32-N051A	Rsmt/1152	Yes	Yes
IS	1E32-N051E	Rsmt/1152	Yes	Yes
IS	1E32-N051J	Rsmt/1152	Yes	Yes
IS	1E32-N051N	Rsmt/1152	Yes	Yes
IS	1E32-N054	Rsmt/1152	Yes	Yes
IS	1E32-N055	Rsmt/1152	Yes	Yes
IS	1E32-N056	Rsmt/1152	Yes	Yes
IS	1E32-N059	Rsmt/1152	Yes	Yes
IS	1E32-N061A	Rsmt/1152	Yes	Yes
IS	1E32-N061E	Rsmt/1152	Yes	Yes
IS	1E32-N061J	Rsmt/1152	Yes	Yes
IS	1E32-N061N	Rsmt/1152	Yes	Yes
IS	1E32-N500	Rsmt/1153	Yes	Yes
IS	1E32-N500(S)	Conax/7F20-11006-02	Yes	Yes
IS	1E32-N501	Rsmt/1153	Yes	Yes
IS	1E32-N501(S)	Conax/7F20-11006-02	Yes	Yes
IS	1E32-N600A	Eagle/HP5	Yes	Yes
IS	1E32-N600E	Eagle/HP5	Yes	Yes
IS	1E32-N600J	Eagle/HP5	Yes	Yes
IS	1E32-N600N	Eagle/HP5	Yes	Yes
IS	1E32-N601A	GE/HP5	Yes	Yes
IS	1E32-N601E	GE/HP5	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
IS	1E32-N601J	GE/HP5	Yes	Yes
IS	1E32-N601N	GE/HP5	Yes	Yes
IS	1E32-N602A	GE/HP5	Yes	Yes
IS	1E32-N602E	GE/HP5	Yes	Yes
IS	1E32-N602J	GE/HP5	Yes	Yes
IS	1E32-N602N	GE/HP5	Yes	Yes
IS	1E32-N604	GE/HP5	Yes	Yes
IS	1E32-N650	Rsmt/510DU	Yes	Yes
IS	1E32-N651A	Rsmt/510DU	Yes	Yes
IS	1E32-N651E	Rsmt/510DU	Yes	Yes
IS	1E32-N651J	Rsmt/510DU	Yes	Yes
IS	1E32-N651N	Rsmt/510DU	Yes	Yes
IS	1E32-N653A	Rsmt/510DU	Yes	Yes
IS	1E32-N653E	Rsmt/510DU	Yes	Yes
IS	1E32-N653J	Rsmt/510DU	Yes	Yes
IS	1E32-N653N	Rsmt/510DU	Yes	Yes
IS	1E32-N654	Rsmt/510DU	Yes	Yes
IS	1E32-N655	Rsmt/510DU	Yes	Yes
IS	1E32-N656	Rsmt/510DU	Yes	Yes
IS	1E32-N657	Rsmt/510DU	Yes	Yes
IS	1E32-N658	Rsmt/510DU	Yes	Yes
IS	1E32-N659	Rsmt/510DU	Yes	Yes
IS	1E32-N661A	Rsmt/510DU	Yes	Yes
IS	1E32-N661E	Rsmt/510DU	Yes	Yes
IS	1E32-N661J	Rsmt/510DU	Yes	Yes
IS	1E32-N661N	Rsmt/510DU	Yes	Yes
IS	1E32-R500	GE/180 Vert Ind	Yes	Yes
IS	1E32-R501	GE/180 Vert Ind	Yes	Yes
IS	1E32-R602A	GE/180 Vert Ind	Yes	Yes
IS	1E32-R602E	GE/180 Vert Ind	Yes	Yes
IS	1E32-R602J	GE/180 Vert Ind	Yes	Yes
IS	1E32-R602N	GE/180 Vert Ind	Yes	Yes
IS	1E32ACU1	Rsmt/510 DU	Yes	Yes
IS	1E32ACU2	Rsmt/510 DU	Yes	Yes
IS	1E32ACU3	Rsmt/510 DU	Yes	Yes
IS	1E32AK046	Eagle/Hp5	Yes	Yes
IS	1E32AK049A	Eagle/Hp5	Yes	Yes
IS	1E32AK049E	Eagle/Hp5	Yes	Yes
IS	1E32AK049J	Eagle/Hp5	Yes	Yes
IS	1E32AK049N	Eagle/Hp5	Yes	Yes
IS	1E32AS001A	GE/CR2940	Yes	Yes
IS	1E32AS001E	GE/CR2849	Yes	Yes
IS	1E32AS001J	GE/CR2940	Yes	Yes
IS	1E32AS001N	GE/CR2940	Yes	Yes
IS	1E32AS002A	GE/CR2940	Yes	Yes
IS	1E32AS002E	GE/CR2940	Yes	Yes
IS	1E32AS002J	GE/CR2940	Yes	Yes
IS	1E32AS002N	GE/CR2940	Yes	Yes
IS	1E32AS003A	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
IS	1E32AS003E	GE/CR2940	Yes	Yes
IS	1E32AS003J	GE/CR2940	Yes	Yes
IS	1E32AS003N	GE/CR2940	Yes	Yes
IS	1E32AS004	GE/CR2940	Yes	Yes
IS	1E32AS005	GE/CR2940	Yes	Yes
IS	1E32AS006	GE/CR2940	Yes	Yes
IS	1E32AS007	GE/CR2940	Yes	Yes
IS	1E32AS008	GE/CR2940	Yes	Yes
IS	1E32AS009A	GE/CR2940	Yes	Yes
IS	1E32AS009E	GE/CR2940	Yes	Yes
IS	1E32AS009J	GE/CR2940	Yes	Yes
IS	1E32AS009N	GE/CR2940	Yes	Yes
IS	1E32AS010	GE/CR2940	Yes	Yes
IS	1E32AS011	GE/CR2940	Yes	Yes
IS	1E32AS012	GE/CR2940	Yes	Yes
IS	1E32AS013	GE/CR2940	Yes	Yes
IS	1E32AS014	GE/CR2940	Yes	Yes
IS	1E32AS015	GE/CR2940	Yes	Yes
IS	1E32AS016	GE/CR2940	Yes	Yes
RI	1E51-AS015	ElctrSw/20K Hand Sw	Yes	Yes
RI	1E51AS033	ElctrSw/20K Hand Sw	Yes	Yes
RI	1E51-C001(P)	EnglhmWlmtCo/6X6X10-5CP	Yes	Yes
RI	1E51-C002	Terry/RCIC Turbine/GS-2N	Yes	Yes
RI	1E51-C002D	GE/PPD96553E Turb Encl	Yes	Yes
RI	1E51-C002E(V)	GE/PPD96553E Stop Vlv	Yes	Yes
RI	1E51-C003(M)	Rlnc/5HP 215T	Yes	Yes
RI	1E51-C003(P)	Gld/Pmp 3196ST	Yes	Yes
RI	1E51-D001	BS&BSSyst/Rup Disc 8"	Yes	Yes
RI	1E51-D002	BS&BSSyst/Rup Disc 8"	Yes	Yes
RI	1E51-D301	Totinson/6" RCIC Pmp Str	Yes	Yes
RI	1E51-F004(L)	Namco/EA180	Yes	Yes
RI	1E51-F004(LS)	Conax/7F20-11005-01	Yes	Yes
RI	1E51-F004(O)	Asco/2063813U	Yes	Yes
RI	1E51-F004(OS)	Conax/7F20-11001-02	Yes	Yes
RI	1E51-F004(V)	Fshr/1" AD Glb Vlv	Yes	Yes
RI	1E51-F005(L)	Namco/EA180	Yes	Yes
RI	1E51-F005(LS)	Conax/7F20-11005-01	Yes	Yes
RI	1E51-F005(O)	Asco/2063813U	Yes	Yes
RI	1E51-F005(OS)	Conax/7F20-11001-02	Yes	Yes
RI	1E51-F005(V)	Fshr/1" AD Glb Vlv	Yes	Yes
RI	1E51-F010(A)	Lmt/SMB-000-2	Yes	Yes
RI	1E51-F010(V)	AD/6" Gt Vlv	Yes	Yes
RI	1E51-F013(A)	Lmt/SMB-0	Yes	Yes
RI	1E51-F013(V)	AD/6" Gt Vlv	Yes	Yes
RI	1E51-F015	TrgtRck/PresReqVlv1/2-2"1500#	Yes	Yes
RI	1E51-F018	Dresser/2" SRV	Yes	Yes
RI	1E51-F019(A)*	Lmt/SMB-0-25	Yes	Yes
RI	1E51-F019(V)	AD/3" Glb Vlv	Yes	Yes
RI	1E51-F022(A)	Lmt/SMB-0	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RI	1E51-F022(V)	AD/4" G1b Vlv	Yes	Yes
RI	1E51-F025(L)	Namco/EA180	Yes	Yes
RI	1E51-F025(LS)	Conax/7F20-11005-01	Yes	Yes
RI	1E51-F025(O)	Asco/2063813U	Yes	Yes
RI	1E51-F025(OS)	Conax/7F20-11001-03	Yes	Yes
RI	1E51-F025(V)	Fshr/1" AQ G1b Vlv	Yes	Yes
RI	1E51-F026(L)	Namco/EA180	Yes	Yes
RI	1E51-F026(LS)	Conax/7F20-11005-01	Yes	Yes
RI	1E51-F026(O)	Asco/2063813U	Yes	Yes
RI	1E51-F026(OS)	Conax/7F20-11001-03	Yes	Yes
RI	1E51-F026(V)	Fshr/1" AQ G1b Vlv	Yes	Yes
RI	1E51-F031(A)	Lmt/SMB-000	Yes	Yes
RI	1E51-F031(V)	AD/6" Gt Vlv	Yes	Yes
RI	1E51-F045(A)	Lmt/SMB-0	Yes	Yes
RI	1E51-F045(V)	AD/4" G1b Vlv	Yes	Yes
RI	1E51-F046(A)	Lmt/SMB-0-15	Yes	Yes
RI	1E51-F046(V)	AD/3" G1b Vlv	Yes	Yes
RI	1E51-F059(A)	Lmt/SMB-00	Yes	Yes
RI	1E51-F059(V)	AD/4" Gt Vlv	Yes	Yes
RI	1E51-F063(A)	Lmt/SMB-0	Yes	Yes
RI	1E51-F063(V)	AD/8" Gt Vlv	Yes	Yes
RI	1E51-F064(A)	Lmt/SMB-0	Yes	Yes
RI	1E51-F064(V)	AD/8" Gt Vlv	Yes	Yes
RI	1E51-F066(L)	Namco/EA180	Yes	Yes
RI	1E51-F066(LS)	Conax/7F20-11005-02	Yes	Yes
RI	1E51-F066(O)	Asco/NP8320(V)	Yes	Yes
RI	1E51-F066(OS)	Conax/7F20-11001-03	Yes	Yes
RI	1E51-F066(V)	AD/4" Nz1 Ck (Air Oper)	Yes	Yes
RI	1E51-F068(A)	Lmt/SMB-000	Yes	Yes
RI	1E51-F068(V)	AD/12" Gt Vlv	Yes	Yes
RI	1E51-F076(A)	Lmt/SMB-000-2	Yes	Yes
RI	1E51-F076(V)	Rckwl/G1b Vlv 1"	Yes	Yes
RI	1E51-F077(A)	Lmt/SMB-000-5	Yes	Yes
RI	1E51-F077(V)	Yrwy/1.5" Ang G1b Vlv	Yes	Yes
RI	1E51-F078(A)	Lmt/SMB-000	Yes	Yes
RI	1E51-F078(V)	AD/3" Gt Vlv	Yes	Yes
RI	1E51-F079	GPE/2" Vac Rel Vlv	Yes	Yes
RI	1E51-F081	GPE/2" Vac Rel Vlv	Yes	Yes
RI	1E51-F090	Dresser/.75" SRV	Yes	Yes
RI	1E51-F095(A)	Lmt/SMB-000	Yes	Yes
RI	1E51-F095(V)	AD/1" Gt Vlv	Yes	Yes
RI	1E51-F316(L)	Namco/EA180	No	Yes
RI	1E51-F316(LS)	Conax/7F20-11005-02	No	Yes
RI	1E51-F316(O)	Asco/2068323U	No	Yes
RI	1E51-F316(OS)	Conax/7F20-11001-03	No	Yes
RI	1E51-F316(V)	Fshr/.75" AQ G1b Vlv	No	Yes
RI	1E51-F333	Valcor/.75" Sol Vlv	Yes	Yes
RI	1E51-F335	Valcor/.75" Sol Vlv	No	Yes
RI	1E51-K601	Bailey/750 SQ R Convtr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RI	1E51-N010	Magnetrol/C-751	Yes	Yes
RI	1E51-N036A	Gould/PD-3218	Yes	Yes
RI	1E51-N036A(S)	Conax/7F20-11008-01	Yes	Yes
RI	1E51-N036E	Gould/PD-3218	Yes	Yes
RI	1E51-N036E(S)	Conax/TF20-11008-01	Yes	Yes
RI	1E51-N037	Magnetrol/C-751	Yes	Yes
RI	1E51-N501	Rsmt/1153	Yes	Yes
RI	1E51-N501(S)	Conax/7F20-11006-01	Yes	Yes
RI	1E51-N551	Wd/Thermowell	Yes	Yes
RI	1E51-N554	Wd/Thermowell	Yes	Yes
RI	1E51-N577	Woodward/1680-622 PRM Spd Elem	Yes	Yes
RI	1E51-N580	SQ.D/9012-ACW-3 Press Sw	Yes	Yes
RI	1E51-N581	SQ.D/9012-AEW-3 Press Diff Sw	Yes	Yes
RI	1E51-N589	GE/75952A13	Yes	Yes
RI	1E51-N590	Woodward/8271-083 Sign. Convtr	Yes	Yes
RI	1E51-N591	Woodward/8271-236 Spd Cont	Yes	Yes
RI	1E51-N592	Woodward/8271-281 Register Ass	Yes	Yes
RI	1E51-N593	GE/101894C Overspd Tst Cntrlr	Yes	Yes
RI	1E51-N594	Woodward/A8250133 Hyd Act	Yes	Yes
RI	1E51-N635A	Rsmt/510 DU	Yes	Yes
RI	1E51-N635E	Rsmt/510 DU	Yes	Yes
RI	1E51-N636A	Rsmt/510 DU	Yes	Yes
RI	1E51-N636E	Rsmt/510 DU	Yes	Yes
RI	1E51-N650	Rsmt/510 DU	Yes	Yes
RI	1E51-N651A	Rsmt/510 DU	Yes	Yes
RI	1E51-N651B	Rsmt/510 DU	Yes	Yes
RI	1E51-N652	Rsmt/510 DU	Yes	Yes
RI	1E51-N653	Rsmt/510 DU	Yes	Yes
RI	1E51-N654	Rsmt/510 DU	Yes	Yes
RI	1E51-N655A	Rsmt/510 DU	Yes	Yes
RI	1E51-N655B	Rsmt/510 DU	Yes	Yes
RI	1E51-N655E	Rsmt/510 DU	Yes	Yes
RI	1E51-N655F	Rsmt/510 DU	Yes	Yes
RI	1E51-N656A	Rsmt/510 DU	Yes	Yes
RI	1E51-N656E	Rsmt/510 DU	Yes	Yes
RI	1E51-N659	Rsmt/510 DU	Yes	Yes
SM	1E51-N801	Rsmt/510 DU	Yes	Yes
RI	1E51-R001	RbtShw/613B	Yes	Yes
RI	1E51-R002	RbtShw/613B	Yes	Yes
RI	1E51-R003	RbtShw/613B	Yes	Yes
RI	1E51-R004	RbtShw/613B	Yes	Yes
RI	1E51-R005	Weed/PPD145C3232	Yes	No
RI	1E51-R550	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R551	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R552	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R553	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R554	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R555	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R557	GE/PPD96553E Temp Ind	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RI	1E51-R558	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R559	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R560	GE/PPD96553E Temp Ind	Yes	Yes
RI	1E51-R600	Bailey/701	Yes	No
RI	1E51-R606	GE/180 Vert Ind	Yes	Yes
RI	1E51AS001	GE/CR2940	Yes	Yes
RI	1E51AS002	GE/CR2940	Yes	Yes
RI	1E51AS003	GE/CR2940	Yes	Yes
RI	1E51AS004	GE/CR2940	Yes	Yes
RI	1E51AS005	GE/CR2940	Yes	Yes
RI	1E51AS006	GE/CR2940	Yes	Yes
RI	1E51AS007	GE/CR2940	Yes	Yes
RI	1E51AS008	GE/CR2940	Yes	Yes
RI	1E51AS009	GE/CR2940	Yes	Yes
RI	1E51AS010	GE/CR2940	Yes	Yes
RI	1E51AS011	GE/CR2940	Yes	Yes
RI	1E51AS012	GE/CR2940	Yes	Yes
RI	1E51AS013	GE/CR2940	Yes	Yes
RI	1E51AS015	ElctrSw/20K Hand Sw	Yes	Yes
RI	1E51AS016	GE/CR2940	Yes	Yes
RI	1E51AS017	GE/CR2940	Yes	Yes
RI	1E51AS018	GE/CR2940	Yes	Yes
RI	1E51AS019A	GE/CR2940	Yes	Yes
RI	1E51AS019B	GE/CR2940	Yes	Yes
RI	1E51AS023	GE/CR2940	Yes	Yes
RI	1E51AS024	GE/CR2940	Yes	Yes
RI	1E51AS025	GE/CR2940	Yes	Yes
RI	1E51AS026	GE/CR2940	Yes	Yes
RI	1E51AS027	GE/CR2940	Yes	Yes
RI	1E51AS028	GE/CR2940	Yes	Yes
RI	1E51AS032	GE/CR2940	Yes	Yes
RI	1E51AS035	GE/CR2940	Yes	Yes
RI	1E51AS037	Cutler Hammer/10250T	Yes	Yes
RI	1E51AS038	GE/CR2940	Yes	Yes
RI	1E51AS039	GE/CR2940	Yes	Yes
RI	1E51AS040	GE/CR2940	Yes	Yes
RI	1E51AS041	GE/CR2940	Yes	Yes
RI	1E51AS042	GE/CR2940	Yes	Yes
EE	1EE01E	Conax/Elect Penet	Yes	Yes
EE	1EE02E	Conax/Elect Penet	Yes	Yes
EE	1EE03E	Conax/Elect Penet	Yes	Yes
EE	1EE04E	Conax/Elect Penet	Yes	Yes
EE	1EE05E	Conax/Elect Penet	Yes	Yes
EE	1EE06E	Conax/Elect Penet	Yes	Yes
EE	1EE07E	Conax/Elect Penet	Yes	Yes
EE	1EE08E	Conax/Elect Penet	Yes	Yes
EE	1EE09E	Conax/Elect Penet	Yes	Yes
EE	1EE10E	Conax/Elect Penet	Yes	Yes
EE	1EE11E	Conax/Elect Penet	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
EE	1EE12E	Conax/Elect Penet	Yes	Yes
EE	1EE13E	Conax/Elect Penet	Yes	Yes
EE	1EE14E	Conax/Elect Penet	Yes	Yes
EE	1EE15E	Conax/Elect Penet	Yes	Yes
EE	1EE16E	Conax/Elect Penet	Yes	Yes
EE	1EE17E	Conax/Elect Penet	Yes	Yes
EE	1EE18E	Conax/Elect Penet	Yes	Yes
EE	1EE19E	Conax/Elect Penet	Yes	Yes
EE	1EE20E	Conax/Elect Penet	Yes	Yes
EE	1EE21E	Conax/Elect Penet	Yes	Yes
EE	1EE22E	Conax/Elect Penet	Yes	Yes
EE	1EE23E	Conax/Elect Penet	Yes	Yes
EE	1EE24E	Conax/Elect Penet	Yes	Yes
EE	1EE25E	Conax/Elect Penet	Yes	Yes
EE	1EE26E	Conax/Elect Penet	Yes	Yes
EE	1EE27E	Conax/Elect Penet	Yes	Yes
EE	1EE28E	Conax/Elect Penet	Yes	Yes
EE	1EE29E	Conax/Elect Penet	Yes	Yes
EE	1EE30E	Conax/Elect Penet	Yes	Yes
EE	1EE31E	Conax/Elect Penet	Yes	Yes
EE	1EE32E	Conax/Elect Penet	Yes	Yes
EE	1EE33E	Conax/Elect Penet	Yes	Yes
EE	1EE34E	Conax/Elect Penet	Yes	Yes
EE	1EE35E	Conax/Elect Penet	Yes	Yes
EE	1EE36E	Conax/Elect Penet	Yes	Yes
EE	1EE37E	Conax/Elect Penet	Yes	Yes
EE	1EE38E	Conax/Elect Penet	Yes	Yes
EE	1EE39E	Conax/Elect Penet	Yes	Yes
EE	1EE40E	Conax/Elect Penet	Yes	Yes
EE	1EE41E	Conax/Elect Penet	Yes	Yes
EE	1EE42E	Conax/Elect Penet	Yes	Yes
EE	1EE43E	Conax/Elect Penet	Yes	Yes
EE	1EE44E	Conax/Elect Penet	Yes	Yes
EE	1EE45E	Conax/Elect Penet	Yes	Yes
EE	1EE46E	Conax/Elect Penet	Yes	Yes
EE	1EE47E	Conax/Elect Penet	Yes	Yes
EE	1EE48E	Conax/Elect Penet	Yes	Yes
EE	1EE49E	Conax/Elect Penet	Yes	Yes
AP	1EI-AP228	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP229	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP232	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP233	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP760	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP769	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP777	GE/NAV	Yes	Yes
AP	1EI-AP955	GE/180 Vert Ind	Yes	Yes
AP	1EI-AP957	GE/180 Volt Ind	Yes	Yes
DC	1EI-DC001	GE/180 Vert Ind	Yes	Yes
DC	1EI-DC002	GE/180 Vert Ind	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
DC	1EI-DC003	GE/180 Vert Ind	Yes	Yes
DC	1EI-DC014	Yokogawa/Volt Mtr	Yes	No
DC	1EI-DC015	Yokogawa/Volt Mtr	Yes	No
DC	1EI-DC019	Yokogawa/Volt Mtr	Yes	No
DC	1EI-DC020	Yokogawa/Volt Mtr	Yes	No
DC	1EI-DC032	Wsths/Elec Indc	Yes	No
DC	1EI-DC047	Yokogaw/Elec Indc	Yes	No
DC	1EI-DC048	Yokogaw/Elec Indc	Yes	No
DG	1EI-DG801	GE/180 Vert Ind	Yes	Yes
DG	1EI-DG807	GE/180 Vert Ind	Yes	Yes
DG	1EI-DG840	PwElc/Vlt Ind 250	Yes	Yes
DG	1EI-DG841	GE/Dist Bus Voltg	Yes	Yes
DG	1EI-DG843	GE/Batt To Dist Bus Curr	Yes	Yes
IP	1EI-RP002	GE/AB30	Yes	Yes
IP	1EI-RP004	GE/AB30	Yes	Yes
IP	1EI-RP006	GE/AB30	Yes	Yes
IP	1EI-RP008	GE/AB30	Yes	Yes
VF	1EL-VF038	GE/ET-16#127B8177G9	Yes	Yes
VF	1EL-VF039	GE/ET-16#127B8177G9	Yes	Yes
CA	1ES-CA501A	GE/Load Drvs	Yes	Yes
CC	1ES-CC516A	GE/Load Drvs	Yes	Yes
CC	1ES-CC516B	GE/Load Drvs	Yes	Yes
FL	1ES-FC510A	GE/Load Drvs	Yes	Yes
VD	1ES-VD507A	GE/Load Drvs	Yes	Yes
VD	1ES-VD508A	GE/Load Drvs	Yes	Yes
VD	1ES-VD509A	GE/Load Drvs	Yes	Yes
VG	1ES-VG509A	GE/Load Drvs	Yes	Yes
VG	1ES-VG509B	GE/Load Drvs	Yes	Yes
VG	1ES-VG509C	GE/Load Drvs	Yes	Yes
VG	1ES-VG509D	GE/Load Drvs	Yes	Yes
VG	1ES-VG509E	GE/Load Drvs	Yes	Yes
VG	1ES-VG509F	GE/Load Drvs	Yes	Yes
VG	1ES-VG509G	GE/Load Drvs	Yes	Yes
VG	1ES-VG509H	GE/Load Drvs	Yes	Yes
VG	1ES-VG512A	GE/Load Drvs	Yes	Yes
VG	1ES-VG512B	GE/Load Drvs	Yes	Yes
VG	1ES-VG512C	GE/Load Drvs	Yes	Yes
VG	1ES-VG512D	GE/Load Drvs	Yes	Yes
VG	1ES-VG512E	GE/Load Drvs	Yes	Yes
VG	1ES-VG512F	GE/Load Drvs	Yes	Yes
VG	1ES-VG512G	GE/Load Drvs	Yes	Yes
VG	1ES-VG512H	GE/Load Drvs	Yes	Yes
VP	1ES-VP511A	GE/Load Drvs	Yes	Yes
VP	1ES-VP511B	GE/Load Drvs	Yes	Yes
VP	1ES-VP511C	GE/Load Drvs	Yes	Yes
VP	1ES-VP512A	GE/Load Drvs	Yes	Yes
VP	1ES-VP512B	GE/Load Drvs	Yes	Yes
VP	1ES-VP512C	GE/Load Drvs	Yes	Yes
VP	1ES-VP512D	GE/Load Drvs	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VP	1ES-VP512F	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ503A	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ503B	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ503C	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ503D	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ504A	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505A	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505B	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505C	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505D	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505E	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ505F	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ506A	GE/Load Drvs	Yes	Yes
VQ	1ES-VQ506B	GE/Load Drvs	Yes	Yes
VR	1ES-VR507A	GE/Load Drvs	Yes	Yes
VR	1ES-VR507B	GE/Load Drvs	Yes	Yes
VX	1ES-VX507A	GE/Load Drvs	Yes	Yes
VX	1ES-VX508A	GE/Load Drvs	Yes	Yes
VX	1ES-VX509A	GE/Load Drvs	Yes	Yes
WX	1ES-WX501A	GE/Load Drvs	Yes	Yes
WX	1ES-WX501D	GE/Load Drvs	Yes	Yes
AP	1EY-AP022	Trnsmtn/530T-64-65-98	Yes	Yes
AP	1EY-AP760	Wsths/V-4	Yes	Yes
AP	1EY-AP769	Wsths/V-4	Yes	Yes
AP	1EY-AP776	GE/Nav	Yes	Yes
AP	1EY-AP777	Wsths/V-4	Yes	Yes
DC	1EY-DC011	PwrCnv/VltAlrmRly DSHV12052-01	Yes	No
DC	1EY-DC016	PwrCnv/VltAlrmRly DSHV12052-01	Yes	No
DC	1EY-DC059	Trnsmtn/530T-64-65-98	Yes	Yes
DC	1EY-DC061	Trnsmtn/530T-64-65-98	Yes	Yes
DC	1EY-DC063	Trnsmtn/530T-64-65-98	Yes	Yes
DC	1EY-DC065	Trnsmtn/530T-64-65-98	Yes	Yes
DC	1EY-DC066	PwrCnv/Anlg Rly DSLV120T2-01	Yes	No
DC	1EY-DC067	PwrCnv/Anlg Rly DSLV120T2-01	Yes	No
DC	1EY-DC068	PwrCnv/Anlg Rly DSLV120T2-01	Yes	No
DC	1EY-DC069	PwrCnv/Anlg Rly DSLV120T2-01	Yes	No
DC	1EY-DC070	Trnsmt/Relug	Yes	No
DC	1EY-DC071	PwrCnv/Analog Rly	Yes	No
DC	1EY-DC072	PwrCnv/Analog Rly	Yes	No
DC	1EY-DC073	PwrCnv/Analog Rly	Yes	No
DC	1EY-DC076	Voltg Rly	Yes	No
DC	1EY-DC077	Voltg Rly	Yes	No
DC	1EY-DC078	Voltg Rly	Yes	Yes
DC	1EY-DC079	Voltg Rly	Yes	Yes
DC	1EY-DC080	PwrCnv/Sgnl Conv ID-1577	Yes	No
DC	1EY-DC081	PwrCnv/Sgnl Conv ID-1577	Yes	No
DC	1EY-DC082	PwrCnv/Sgnl Conv ID-1577	Yes	No
DG	1EY-DG216	Trnsmtn/Sgnl Conv	Yes	Yes
DG	1EY-DG800	Wsths/V-4	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DG	1EY-DG806	Wsths/V-4	Yes	Yes
VX	1EY-VX112	ActPc/AP9046 Pwr Sply	Yes	Yes
VX	1EY-VX114	ActPc/AP9046 Pwr Sply	Yes	Yes
VX	1EY-VX116	ActPc/AP9046 Pwr Sply	Yes	Yes
FS	1F11-E001A	GE/F1 Prp Mch OV-283X759G001	Yes	Yes
FS	1F11-E001B	GE/F1 Prp Mach OV-283X759G001	Yes	Yes
FS	1F11-E001C	GE/F1 Prp Mach OV-283X759G001	Yes	Yes
FS	1F11-E001D	GE/F1 Prp Mach OV-283X759G001	Yes	Yes
FS	1F11-E002	GE/New Fuel Insp Std	Yes	Yes
FS	1F11-E011	GE/Grapple	Yes	No
FS	1F11-E012(M)	GE/Jib Crane	Yes	Yes
FS	1F11-E012A	GE/J1B Crane	Yes	Yes
FS	1F11-E012B	GE/Jib Crane	Yes	Yes
FS	1F11-E012C	GE/Jib Crane	Yes	Yes
FS	1F11-E012D	GE/Jib Crane	Yes	Yes
FS	1F11-E014	GE/Fuel Hand Plat	Yes	Yes
FS	1F11-E017	GE/Fuel Hand Plat	Yes	Yes
FS	1F13-E005	GE-RPV Head Hldg Predestal	Yes	Yes
FS	1F13-E008	GE/Dryer & Separator Stgbk	Yes	Yes
FS	1F13-E009	GE/Hd Strong Car	Yes	Yes
FS	1F15-E003	GE/Refueling Pltfrm	Yes	Yes
FS	1F15-E005(M)	GE/Aux Pltfrm	Yes	Yes
FS	1F15-E006	GE/Refueling Plat	Yes	Yes
FS	1F16-E009A	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009B	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009C	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009D	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009E	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009F	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E009G	GE/Def Fuel St Cont	Yes	Yes
FS	1F16-E011	GE/Equip St Rack	Yes	Yes
FS	1F16-E012	GE/Fuel St Vault	Yes	Yes
FS	1F16-E013(M)	GE/Fuel St Vault	Yes	No
FS	1F42-D001	GE/Incl Fuel Tube	Yes	Yes
FS	1F42-G001	GE/Bellows	Yes	Yes
FC	1FC001	PosiSl/16" Btrfly Vlv	Yes	Yes
FC	1FC002	PosiSl/16" Btrfly Vlv	Yes	Yes
FC	1FC003A	AD/12" Gt Vlv	Yes	Yes
FC	1FC003B	AD/12" Gt Vlv	Yes	Yes
FC	1FC004A(L)	Namco/EA180	Yes	Yes
FC	1FC004A(LS)	Conax/7F20-11005-01	Yes	Yes
FC	1FC004A(V)	Fshr/8" AD Glb Vlv	Yes	Yes
FC	1FC004B(L)	Namco/EA180	Yes	Yes
FC	1FC004B(LS)	Conax/7F20-11005-01	Yes	Yes
FC	1FC004B(V)	Fshr/8" AD Glb Vlv	Yes	Yes
FC	1FC007(A)	Lmt/SMB-000	Yes	Yes
FC	1FC007(V)	AD/Gt Vlv 10"	Yes	Yes
FC	1FC008(A)	Lmt/SMB-000	Yes	Yes
FC	1FC008(V)	AD/10" Gt Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
FC	1FC011A(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC011A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC011B(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC011B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC012A(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
FC	1FC012B(V)	PosiSl/6" Vlv	Yes	Yes
FC	1FC014A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC014B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC015A(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC015A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC015B(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC015B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC016A(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC016A(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC016B(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC016B(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC017(A)	GreerHyd/260625R80	Yes	Yes
FC	1FC017(L)	Namco/EA740	Yes	Yes
FC	1FC017(LS)	Conax/7F20-11005-01	Yes	Yes
FC	1FC017(O)	Asco/Hv2068326F	Yes	Yes
FC	1FC017(OS)	Conax/7F20-11004-01	Yes	Yes
FC	1FC017(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC019A(V)	PosiSl/12" Btrfly Vlv	Yes	Yes
FC	1FC019B(V)	PosiSl/2" Btrfly Vlv	Yes	Yes
FC	1FC01AA	Yuba/Heat Exchanger	Yes	Yes
FC	1FC01AB	Yuba/Heat Exchanger	Yes	Yes
FC	1FC021A(V)	PosiSl/12" Btrfly Vlv	Yes	Yes
FC	1FC021B(V)	PosiSl/12" Btrfly Vlv	Yes	Yes
FC	1FC023(A)	GreerHyd/260625R80	Yes	Yes
FC	1FC023(L)	Namco/EA740	Yes	Yes
FC	1FC023(LS)	Conax/7F20-11005-01	Yes	Yes
FC	1FC023(O)	Asco/Hv2068326F	Yes	Yes
FC	1FC023(OS)	Conax/7F20-11004-01	Yes	Yes
FC	1FC023(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC024A(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC024A(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC024B(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC024B(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
FC	1FC025B(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
FC	1FC026A(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC026A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC026B(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC026B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC027(A)	Lmt/H1BC-SMB-000	Yes	Yes
FC	1FC027(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
FC	1FC02PA(M)	Smns/AIs/350HP/507US Mtr	Yes	Yes
FC	1FC02PA(P)	Gld/3405L Pump	Yes	Yes
FC	1FC02PB(M)	Smns/AIs/350HP/507US Mtr	Yes	Yes
FC	1FC02PB(P)	Gld/3405L Pump	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
FC	1FC031A(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
FC	1FC031B(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
FC	1FC036(A)	Lmt/SMB-000	Yes	Yes
FC	1FC036(V)	AD/8" Gt Vlv	Yes	Yes
FC	1FC037(A)	Lmt/SMB-000	Yes	Yes
FC	1FC037(V)	AD/8" Gt Vlv	Yes	Yes
FC	1FC038(L)	Namco/EA180	Yes	Yes
FC	1FC038(LS)	Conax/7F20-11005-01	Yes	Yes
FC	1FC038(O)	Asco/2068323U	Yes	Yes
FC	1FC038(OS)	Conax/7F20-11001-02	Yes	Yes
FC	1FC038(V)	Fshr/3" AD Glb Vlv	Yes	Yes
FC	1FC076A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC076B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
FC	1FC085A	Dresser/4" SRV	Yes	Yes
FC	1FC085B	Dresser/4" SRV	Yes	Yes
FC	1FC090	AD/12" Gt Vlv	Yes	Yes
FC	1FC091	Dresser/4" SRV	Yes	Yes
FC	1FC095A	Crosby/3/4X1 JR,SRV	Yes	Yes
FC	1FC095B	Crosby/3/4X1 JR,SRV	Yes	Yes
FC	1FC135	PosiSl/10" C1150 Vlv	Yes	Yes
FC	1FC136(V)	PosiSl/6" w/Lvr Lk	Yes	Yes
FC	1FC156	PosiSl/8" Btrfly Vlv	Yes	No
FC	1FC157	PosiSl/8" 150# Btrfly Vlv	Yes	No
HG	1FE-HG051	Beth/22-FT-21-B Gas Flw Elem	Yes	Yes
VP	1FE-VP003	AirMontCorp/AirFlow Mon	No	Yes
HG	1FI-HG051	Triplett/Gas Flow Indctr -420R	Yes	Yes
VP	1FI-VP023	Lv/CRT Rly 48-8115-8174	Yes	Yes
VP	1FI-VP024	Lv/CRT Rly 48-8115-8174	Yes	Yes
FP	1FP050(A)	Lmt/SMB-000	Yes	Yes
FP	1FP050(V)	AD/6" Gt Vlv	Yes	Yes
FP	1FP051(A)	Lmt/SMB-000	Yes	Yes
FP	1FP051(V)	AD/10" Gt Vlv	Yes	Yes
FP	1FP052(A)	Lmt/SMB-000	Yes	Yes
FP	1FP052(V)	AD/10" Gt Vlv	Yes	Yes
FP	1FP053(A)	Lmt/SMB-000	Yes	Yes
FP	1FP053(V)	AD/10" Gt Vlv	Yes	Yes
FP	1FP054(A)	Lmt/SMB-000	Yes	Yes
FP	1FP054(V)	AD/10" Gt Vlv	Yes	Yes
FP	1FP078(A)	Lmt/SMB-000	Yes	Yes
FP	1FP078(V)	AD/4" Gt Vlv	Yes	Yes
FP	1FP079(A)	Lmt/SMB-000	Yes	Yes
FP	1FP079(V)	AD/4" Gt Vlv	Yes	Yes
FP	1FP092(A)	Lmt/SMB-000	Yes	Yes
FP	1FP092(V)	AD/6" Gt Vlv	Yes	Yes
CM	1FSL-CM175	Gems/FS-925	Yes	Yes
CM	1FSL-CM176	Gems/FS-925	Yes	Yes
CM	1FSV-CM205	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM206	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM207	Asco/NP830A187E	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1FSV-CM208	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM209	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM210	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM211	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM212	Asco/NP830A187E	Yes	Yes
CM	1FSV-CM213	Sentry/2-013011	Yes	Yes
CM	1FSV-CM214	Sentry/2-013011	Yes	Yes
FC	1FSV-FC110	Asco/2068323U	Yes	Yes
FC	1FSV-FC110(OS)	Conax/7F20-11001-03	Yes	Yes
FC	1FSV-FC111	Asco/2068323U	Yes	Yes
FC	1FSV-FC111(OS)	Conax/7F20-11001-03	Yes	Yes
VA	1FSV-VA002	Asco/HBX-8320B-2E	Yes	Yes
VF	1FSV-VF021	Asco/HBX-8320B-2E	Yes	Yes
VF	1FSV-VF022	Asco/HBX-8320B-2E	Yes	Yes
VF	1FSV-VF023	Asco/HBX-8320B-2E	Yes	Yes
VF	1FSV-VF024	Asco/HBX-8320B-2E	Yes	Yes
VG	1FSV-VG009	Asco/HBX-8320B-2E	Yes	Yes
VG	1FSV-VG009(OS)	Conax/7F20-11001-03	No	Yes
VG	1FSV-VG109	Asco/HBX-8320B-2E	Yes	Yes
VG	1FSV-VG109(OS)	Conax/7F20-11001-03	Yes	Yes
VQ	1FSV-VQ023B	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ023B(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ023C	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ023C(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ025C	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ025C(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ025D	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ025D(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ027B	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ027B(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ027C	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ027C(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ029D	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ029D(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ029E	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ029E(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ031B	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ031B(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ031C	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ031C(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ033B	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ033B(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ033C	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ033C(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ095B	Asco/NP831665E	Yes	Yes
VQ	1FSV-VQ095B(OS)	Conax/7F20-11004-01	Yes	Yes
VQ	1FSV-VQ095C	Asco/NP831665E	Yes	No
VQ	1FSV-VQ095C(OS)	Conax/7F20-11004-01	Yes	Yes
VR	1FSV-VR008B	Asco/NP831665E	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VR	1FSV-VR008B(OS)	Conax/7F20-11004-01	Yes	Yes
VR	1FSV-VR008C	Asco/NP831665E	Yes	Yes
VR	1FSV-VR008C(OS)	Conax/7F20-11001-03	Yes	Yes
VR	1FSV-VR009B	Asco/NP831665E	Yes	Yes
VR	1FSV-VR009B(OS)	Conax/7F20-11004-01	Yes	Yes
VR	1FSV-VR009C	Asco/NP831665E	Yes	Yes
VR	1FSV-VR009C(OS)	Conax/7F20-11001-03	Yes	Yes
VR	1FSV-VR108A	Asco/NP831665E	Yes	Yes
VR	1FSV-VR108A(OS)	Conax/7F20-11001-03	Yes	Yes
VR	1FSV-VR109A	Asco/NP831665E	Yes	Yes
VR	1FSV-VR109A(OS)	Conax/7F20-11001-03	Yes	Yes
VR	1FSV-VR162A	Asco/NP831665E	Yes	Yes
VR	1FSV-VR162A(OS)	Conax/7F20-11001-03	Yes	Yes
VR	1FSV-VR163A	Asco/NP831665E	Yes	Yes
VR	1FSV-VR163A(OS)	Conax/7F20-11001-03	Yes	Yes
HG	1FT-HG051	GLD/DP Transm PD3200	Yes	Yes
VP	1FT-VP023	Rsmt/1151	Yes	Yes
VP	1FT-VP023(S)	Conax/7F20-11006-02	Yes	Yes
VP	1FT-VP024(S)	Conax/7F20-11006-02	Yes	Yes
HG	1FY-HG051	MooreInd/Temp Sw Type 222	Yes	Yes
VP	1FY-VP023	Trnsmt/Cur Rly W221A-20-243	Yes	Yes
VP	1FY-VP024	Trnsmt/Cur Rly W221A-20-243	Yes	Yes
VD	1FZ-VD004	ITT/NH-95 Act	Yes	Yes
VD	1FZ-VD005	ITT/NH-95 Act	Yes	Yes
VD	1FZ-VD006	ITT/NH-95 Act	Yes	Yes
VF	1FZ-VF023	Cntrmtcs/275 Act	Yes	No
VF	1FZ-VF024	Cntrmtcs/375 Act	Yes	No
VG	1FZ-VG006A	ITT/NH-95	Yes	Yes
VG	1FZ-VG008B	ITT/NH-95	Yes	Yes
VG	1FZ-VG008D	ITT/NH-95	Yes	Yes
VG	1FZ-VG008E	ITT/NH-95	Yes	Yes
VG	1FZ-VG008F	ITT/NH-95	Yes	Yes
VG	1FZ-VG108A	ITT/NH-95	Yes	Yes
VG	1FZ-VG108B	ITT/NH-95	Yes	Yes
VG	1FZ-VG108D	ITT/NH-95	Yes	Yes
VG	1FZ-VG108E	ITT/NH-95	Yes	Yes
VG	1FZ-VG108F	ITT/NH-95	Yes	Yes
VG	1FZ-VG109A	Cntrmtcs/200 SR Act	Yes	No
VG	1FZ-VG109B	Cntrmtcs/200 SR Act	Yes	No
VQ	1FZ-VQ125	ITT/NH-95 Act	Yes	Yes
VR	1FZ-VR108	Bettis/NT-316-SR2	Yes	Yes
VR	1FZ-VR109	Bettis/NT-316-SR2	Yes	Yes
VR	1FZ-VR162	Bettis/NT-316-SR2	Yes	Yes
VR	1FZ-VR163	Bettis/NT-316-SR2	Yes	Yes
VX	1FZ-VX001	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX002	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX003	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX004	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX005	ITT/NH-95 Act	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1FZ-VX006	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX054	ITT/NH-95 Act	Yes	Yes
VX	1FZ-VX055	ITT/NH-95 Act	Yes	Yes
RT	1G33-F001(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F001(V)	AD/6" Gt Vlv	Yes	Yes
RT	1G33-F004(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F004(V)	AD/6" Gt Vlv	Yes	Yes
RT	1G33-F028(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F028(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F031(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F031(V)	AD/3" G1b Vlv	Yes	Yes
RT	1G33-F034(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F034(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F035(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F035(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F039(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F039(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F040(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F040(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F041(L)	Namco/EA180	Yes	Yes
RT	1G33-F041(LS)	Conax/7F20-11005-01	Yes	Yes
RT	1G33-F041(O)	Asco/2068323U	Yes	Yes
RT	1G33-F041(OS)	Conax/7F20-11001-02	Yes	Yes
RT	1G33-F041(V)	Fshr/1" AO G1b Vlv	Yes	Yes
RT	1G33-F042A(A)	Lmt/SMB-0	Yes	Yes
RT	1G33-F042A(V)	AD/4" G1b Vlv	Yes	Yes
RT	1G33-F042B(A)	Lmt/SMB-0	Yes	Yes
RT	1G33-F042B(V)	AD/4" G1b Vlv	Yes	Yes
RT	1G33-F044(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F044(V)	AD/G1b Vlv	Yes	Yes
RT	1G33-F046(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F046(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F053(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F053(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F054(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F054(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F100(A)	Lmt/SMB-000	Yes	Yes
RT	1G33-F100(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F101(A)	Lmt/SMB-000	Yes	Yes
RT	1G33-F101(V)	AD/3" Gt Vlv	Yes	Yes
RT	1G33-F102(A)	Lmt/SMB-1	Yes	Yes
RT	1G33-F102(V)	AD/6" G1b Vlv	Yes	Yes
RT	1G33-F103(V)	AD/3" G1b Vlv	Yes	Yes
RT	1G33-F104(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F104(V)	AD/4" G1b Vlv	Yes	Yes
RT	1G33-F106(A)	Lmt/SMB-000	Yes	Yes
RT	1G33-F106(V)	AD/4" Gt Vlv	Yes	Yes
RT	1G33-F107(A)	Lmt/SMB-00	Yes	Yes
RT	1G33-F107(V)	AD/4" G1b Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
LD	1G33-F312A	Valcor/.75" Sol Vlv	Yes	Yes
LD	1G33-F312B	Valcor/.75" Sol Vlv	Yes	Yes
LD	1G33-F314	Valcor/.75" Sol Vlv	Yes	Yes
LD	1G33-F316	Valcor/.75" Sol Vlv	Yes	Yes
RT	1G33-F325	Valcor/.75" Sol Vlv	Yes	Yes
RT	1G33-N004	Rsmt/Temp Elem W/Thermowel	Yes	Yes
RT	1G33-N006A	Rsmt/Temp Elem w/Thermowel	Yes	Yes
RT	1G33-N006B	Rsmt/Temp Elem w/Thermowel	Yes	Yes
RT	1G33-R550	ITTBrtn/277	Yes	Yes
RT	1G33-R551	ITTBrtn/277	Yes	Yes
RT	1G33-R552	ITTBrtn/277	Yes	Yes
RT	1G33-R553	ITTBrtn/277	Yes	Yes
PA	1H13-P601	GE/ReacCoreClingSysBOPCntrlPnl	Yes	Yes
PA	1H13-P632	GE/Pnl Div I-Lk Det Vert Bd	Yes	Yes
HS	1H13-P638	Harlo/Cont Pnl	Yes	Yes
HS	1H13-P639	Harlo/Cont Pnl	Yes	Yes
PA	1H13-P642	GE/Pnl Div I Lk Det Vert Bd	Yes	Yes
PA	1H13-P651	GE/PPD865E140	Yes	Yes
PA	1H13-P652	GE/PPD865E140	Yes	Yes
PA	1H13-P654	GE/MSIV Lkg Cnt Pnl/865E789	Yes	Yes
PA	1H13-P655	GE/MSIV Lkg Cnt Pnl/865E897	Yes	Yes
PA	1H13-P661	GE/Pnl Nuc Saf Prot Sys Cntrl	Yes	Yes
PA	1H13-P662	GE/Pnl Nuc Saf Prot Sys Cntrl	Yes	Yes
PA	1H13-P663	GE/Pnl Nuc Saf Prot Sys Cntrl	Yes	Yes
PA	1H13-P664	GE/Pnl Nuc Saf Prot Sys Cntrl	Yes	Yes
PA	1H13-P669	GE/Pnl	Yes	Yes
PA	1H13-P670	GE/Pnl	Yes	Yes
PA	1H13-P671	GE/Pnl	Yes	Yes
PA	1H13-P672	GE/Pnl	Yes	Yes
PA	1H13-P678	GE/Standby Infor Pnl/866E441	Yes	Yes
PA	1H13-P680	GE/Pnl Prim Plt Cnt Cons&H57	Yes	Yes
PA	1H13-P701	GE/PPD147D5777	Yes	Yes
PA	1H13-P702	GE/PPD147D5778	Yes	Yes
PA	1H13-P703	GE/PPD147D7579	Yes	Yes
PA	1H13-P704	GE/PPD147D7580	Yes	Yes
PA	1H13-P706	GE/PPD147D7581	Yes	Yes
PA	1H13-P707	GE/PPD147D7582	Yes	Yes
PA	1H13-P708	GE/PPD147D7583	Yes	Yes
PA	1H13-P709	GE/PPD147D7584	Yes	Yes
PA	1H13-P711	GE/PPD147D7585	Yes	Yes
PA	1H13-P714	GE/PPD147D7586	Yes	Yes
PA	1H13-P715	GE/PPD147D7587	Yes	Yes
PA	1H13-P717	GE/PPD147D7588	Yes	Yes
PA	1H13-P719	GE/PPD147D7589	Yes	Yes
PA	1H13-P730	GE/PPD147D7590	Yes	Yes
PA	1H13-P731	GE/PPD147D7591	Yes	Yes
PA	1H13-P732	GE/PPD147D7592	Yes	Yes
PA	1H13-P740	GE/PPD147D7593	Yes	Yes
PA	1H13-P741	GE/PPD147D7594	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PA	1H13-P742	GE/PPD147D7595	Yes	Yes
PA	1H13-P743	GE/PPD147D7596	Yes	Yes
PA	1H13-P744	GE/PPD147D7597	Yes	Yes
PA	1H13-P800	GE/Div1,2,3BOP Equip Cntrl Pnl CCP	Yes	Yes
PA	1H13-P800-65	Harlo/Cont Pnl	Yes	Yes
PA	1H13-P801	GE/Pnl	Yes	Yes
PA	1H13-P821	GE/Pnl Div II HVAC Cont	Yes	Yes
PA	1H13-P822	GE/Pnl Div II HVAC Cont	Yes	Yes
PA	1H13-P839	GE/PRD915E108	Yes	Yes
PA	1H13-P851	GE/Div 1&2 HVAC Cntrl Pnl	Yes	Yes
PA	1H13-P852	GE/Div 1&2 HVAC Cntrl Pnl	Yes	Yes
PA	1H13-P861	GE/Div 1&2 HVAC Cntrl Pnl	Yes	Yes
PA	1H13-P862	GE/Div 1&2 HVAC Cntrl Pnl	Yes	Yes
PA	1H13-P863	GE/Pnl Loose Part Monitor	Yes	Yes
PA	1H13-P864	Ebrln/Cabinet	Yes	Yes
PA	1H13-P865	TrTech/Panel	Yes	Yes
PA	1H13-P866	TEC/158 Control Pnl	Yes	Yes
HG	1H13-P867	Sntry/H2-0 Analyzing Pnl	Yes	Yes
HG	1H13-P868	Sntry/H2-0 Analyzing Pnl	Yes	Yes
PA	1H13-P870	GE/Div1,2&Non-DivBOP EquipPnl	Yes	Yes
PA	1H13-P877	GE/DG BOP Cntrl Pnl	Yes	Yes
PL	1H22-P001	GE/Custom Pnl	Yes	Yes
PL	1H22-P002	GE/Custom Pnl	Yes	Yes
PL	1H22-P004	GE/Custom Pnl	Yes	Yes
PL	1H22-P005	GE/Custom Pnl	Yes	Yes
PL	1H22-P006	GE/Custom Pnl	Yes	Yes
PL	1H22-P009	GE/Custom Pnl	Yes	Yes
PL	1H22-P010	GE/Custom Pnl	Yes	Yes
PL	1H22-P011	GE/Custom Pnl	Yes	Yes
PL	1H22-P015	GE/Custom Pnl	Yes	Yes
PL	1H22-P017	GE-Custom Pnl	Yes	Yes
PL	1H22-P018	GE/Custom Pnl	Yes	Yes
PL	1H22-P021	GE/Custom Pnl	Yes	Yes
LP	1H22-P022	GE/Custom Pnl	Yes	Yes
PL	1H22-P024	GE/Custom Pnl	Yes	Yes
PL	1H22-P025	GE/Custom Pnl	Yes	Yes
PL	1H22-P026	GE/Custom Pnl	Yes	Yes
PL	1H22-P027	GE/Custom Pnl	Yes	Yes
PL	1H22-P028	GE/HPCS D.G.-Prot Pnl&Inst	Yes	Yes
PL	1H22-P030	GE/SRM-IRM PreAmp Pnl	Yes	Yes
PL	1H22-P031	GE/SRM-IRM PreAmp Pnl	Yes	Yes
PL	1H22-P032	GE/SRM-IRM PreAmp Pnl	Yes	Yes
PL	1H22-P033	GE/SRM-IRM PreAmp Pnl	Yes	Yes
PL	1H22-P041	GE/Custom Pnl	Yes	Yes
PL	1H22-P042	GE/Custom Pnl	Yes	Yes
PL	1H22-P055	GE/Custom Pnl	Yes	Yes
PL	1H22-P073	GE/MSIV Lk Cont Div I Pnl	Yes	Yes
PL	1H22-P074	GE/MSIV Lk Cont Div II Pnl	Yes	Yes
CM	1HC-CM091	GoInc/PR-101113	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1HC-CM092	GoInc/PR-101113	Yes	Yes
CM	1HC-CM093	GoInc/PR-101113	Yes	Yes
CM	1HC-CM094	GoInc/PR-101113	Yes	Yes
CM	1HC-CM095	GoInc/PR-101113	Yes	Yes
CM	1HC-CM096	GoInc/PR-101113	Yes	Yes
HC	1HC23G	AM-Monorail/Crane	Yes	Yes
HC	1HC38G	AM-Monorail/Crane	Yes	Yes
HC	1HC39G	AM-Monorail/Crane	Yes	Yes
HC	1HC40G	AM-Monorail/Crane	Yes	Yes
HC	1HC41G	AM-Monorail/Crane	Yes	Yes
HC	1HC42G	AM-Monorail/Crane	Yes	Yes
HC	1HC44G	AM-Monorail/Crane	Yes	Yes
HC	1HC49G	AM-Monorail/Crane	Yes	Yes
HC	1HC64G	AM-Monorail/Crane	Yes	Yes
HC	1HC65G	AM-Monorail/Crane	Yes	Yes
HC	1HC74G	Am-Monorail/Crane	Yes	Yes
HG	1HG001(A)	Lmt/H1BC SMB-000	Yes	Yes
HG	1HG001(V)	PosiSl/2" 150# Btrfly Vlv	Yes	Yes
HG	1HG004(A)	Lmt/H1BC SMB-000	Yes	Yes
HG	1HG004(V)	PosiSl/2" 150# Btrfly Vlv	Yes	Yes
HG	1HG005(A)	Lmt/H1BC SMB-000	Yes	Yes
HG	1HG005(V)	PosiSl/2" 150# Btrfly Vlv	Yes	Yes
HG	1HG008(A)	Lmt/H1BC SMB-000	Yes	Yes
HG	1HG008(V)	PosiSl/2" 150# Btrfly Vlv	Yes	Yes
HG	1HG009A(A)	Lmt/H1BC SMB-000	Yes	Yes
HG	1HG009A(V)	AD/6" Gt Vlv	Yes	Yes
HG	1HG009B(A)	Lmt/H1BC SMB-000	Yes	Yes
RT	1HG009B(V)	AD/6" Gt Vlv	Yes	Yes
HG	1HG010A(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG010A(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG010B(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG010B(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG010C(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG010C(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG010D(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG010D(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG011A(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG011A(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG011B(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG011B(V)	GPE/10" Vac Rlf Vlv	Yes	Yes
HG	1HG011C(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG011C(V)	GPE/10" Vac Rel Vlv	Yes	Yes
HG	1HG011D(L)	Licon/Limit Sw 65-430189	Yes	Yes
HG	1HG011D(V)	GPE/10" Vac Rel Vlv	Yes	Yes
HG	1HG01SB	Rckwl/H2 Recomb	No	No
HG	1HG02CA	SpcrTurbn/G4515-H	Yes	Yes
HG	1HG02CA(M)	Rlnc/60HP 40STS	Yes	Yes
HG	1HG02CB	SpcrTurbn/G4515-H	Yes	Yes
HG	1HG02CB(M)	Rlnc/60HP 40STS	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
HG	1HG03EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG03EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG03EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG03ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG03EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG03EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG03JA	ITE/Series 5600 MCC	Yes	Yes
HG	1HG03JB	ITE/Series 5600 MCC	Yes	Yes
HG	1HG05EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG05EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG05ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG05EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG05EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG05EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG06ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG06EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG07ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG07EN	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG08ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EK	Morrison Knudsen/6043	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
HG	1HG08EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG08EN	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG09ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EP	Morrison Knudsen/6043	Yes	Yes
HG	1HG09EQ	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG10ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG10EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG11ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG11EN	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG12ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EH	Morrison Knudsen/6043	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM EQUIPMENT NUMBER		MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
=====				
HG	1HG12EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG12EN	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EA	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EB	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EC	Morrison Knudsen/6043	Yes	Yes
HG	1HG13ED	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EE	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EF	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EG	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EH	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EJ	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EK	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EL	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EM	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EN	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EP	Morrison Knudsen/6043	Yes	Yes
HG	1HG13EQ	Morrison Knudsen/6043	Yes	Yes
AP	1HS-AP208A	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP208B	GE/CR2940	Yes	Yes
AP	1HS-AP209A	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP209B	GE/CR2940	Yes	Yes
AP	1HS-AP210A	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP210B	GE/CR2940	Yes	Yes
AP	1HS-AP211A	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP211B	GE/CR2940	Yes	Yes
AP	1HS-AP427	GE/CR2940	Yes	Yes
AP	1HS-AP428	GE/CR2940	Yes	Yes
AP	1HS-AP760	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP769	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP777	GE/NAV	Yes	Yes
AP	1HS-AP784	GE/Nav	No	Yes
AP	1HS-AP787	GE/NAV	Yes	Yes
AP	1HS-AP789	GE/NAV	Yes	Yes
AP	1HS-AP952	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP953	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP954	ElctrSw/20K Hand Sw	Yes	Yes
AP	1HS-AP956	ElctrSw/20K Hand Sw	Yes	Yes
CC	1HS-CC007	GE/CR2940	Yes	Yes
CC	1HS-CC008	GE/CR2940	Yes	Yes
CC	1HS-CC009	GE/CR2940	Yes	Yes
CC	1HS-CC010	GE/CR2940	Yes	Yes
CC	1HS-CC011	GE/CR2940	Yes	Yes
CC	1HS-CC012	GE/CR2940	Yes	Yes
CC	1HS-CC013	GE/CR2940	Yes	Yes
CC	1HS-CC016	GE/CR2940	Yes	Yes
CC	1HS-CC017	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CC	1HS-CC018	GE/CR2940	Yes	Yes
CC	1HS-CC019	GE/CR2940	Yes	Yes
CC	1HS-CC020	GE/CR2940	Yes	Yes
CC	1HS-CC022	GE/CR2940	Yes	Yes
CC	1HS-CC023	GE/CR2940	Yes	Yes
CC	1HS-CC081	GE/CR2940	Yes	Yes
CC	1HS-CC082	GE/CR2940	Yes	Yes
CC	1HS-CC086	GE/CR2940	Yes	Yes
CC	1HS-CC087	GE/CR2940	Yes	Yes
CC	1HS-CC105	GE/CR2940	Yes	Yes
CC	1HS-CC108	GE/CR2940	Yes	Yes
CC	1HS-CC121	GE/CR2940	Yes	Yes
CC	1HS-CC122	GE/CR2940	Yes	Yes
CM	1HS-CM073	GE/CR2940	Yes	Yes
CM	1HS-CM074	GE/CR2940	Yes	Yes
CM	1HS-CM075	GE/CR2940	Yes	Yes
CM	1HS-CM076	GE/CR2940	Yes	Yes
CM	1HS-CM149	AllenBradley/800T-XA	Yes	Yes
CM	1HS-CM150	AllenBradley/800T-XA	Yes	Yes
CM	1HS-CM161	Larson/24-201B-B2	Yes	Yes
CM	1HS-CM162	Larson/24-201B-B2	Yes	Yes
CM	1HS-CM181	Larson/24-201B-B3	Yes	Yes
CM	1HS-CM182	Larson/24-201B-B3	Yes	Yes
CM	1HS-CM187	Larson/24-201B-B3	Yes	Yes
CM	1HS-CM188	Larson/24-201B-B3	Yes	Yes
CM	1HS-CM262	ElctrSw/Cont Sw	Yes	Yes
CM	1HS-CM263	ElctrSw/Cont Sw	Yes	Yes
CY	1HS-CY002	GE/CR2940	Yes	Yes
CY	1HS-CY003	GE/CR2940	Yes	Yes
CY	1HS-CY004	GE/CR2940	Yes	Yes
CY	1HS-CY005	GE/CR2940	Yes	Yes
CY	1HS-CY016	GE/CR2940	Yes	Yes
CY	1HS-CY017	GE/CR2940	Yes	Yes
CY	1HS-CY019	GE/CR2940	Yes	Yes
CY	1HS-CY020	GE/CR2940	Yes	Yes
DG	1HS-DG106	GE/CR2940	Yes	No
DG	1HS-DG107	GE/CR2940	Yes	No
DG	1HS-DG108	GE/CR2940	Yes	No
DG	1HS-DG109	GE/CR2940	Yes	No
DG	1HS-DG110	GE/SMB Sw	Yes	No
DG	1HS-DG111	GE/SMB Sw	Yes	No
DG	1HS-DG112	GE/CR2940	Yes	No
DG	1HS-DG113	GE/CR2940	Yes	No
DG	1HS-DG114	GE/SB1 Sw	Yes	No
DG	1HS-DG115	GE/SB1 Sw	Yes	No
DG	1HS-DG116	GE/CR2940	Yes	No
DG	1HS-DG117	GE/CR2940	Yes	No
DG	1HS-DG128	GE/SMB Sw	Yes	No
DG	1HS-DG129	GE/SMB Sw	Yes	No

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DG	1HS-DG130	GE/SMB Sw	Yes	No
DG	1HS-DG131	GE/SMB Sw	Yes	No
DG	1HS-DG132	GE/CR2940	Yes	No
DG	1HS-DG133	GE/CR2940	Yes	No
DG	1HS-DG134	GE/CR2940	Yes	No
DG	1HS-DG135	GE/CR2940	Yes	No
DG	1HS-DG214	GE/CR2940	Yes	Yes
DG	1HS-DG215	GE/CR2940	Yes	Yes
DG	1HS-DG216A	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG216B	GE/CR2940	Yes	Yes
DG	1HS-DG217A	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG217B	GE/CR2940	Yes	Yes
DG	1HS-DG801	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG805	GE/HS SBM	Yes	Yes
DG	1HS-DG807	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG811	GE/HD SMB	Yes	Yes
DG	1HS-DG823	GE/2940	Yes	Yes
DG	1HS-DG824	GE/2940	Yes	Yes
DG	1HS-DG825	GE/2940	Yes	Yes
DG	1HS-DG826	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG827	GE/CR2940	Yes	Yes
DG	1HS-DG828	GE/CR2940	Yes	Yes
DG	1HS-DG829	GE/CR2940	Yes	Yes
DG	1HS-DG830	GE/CR2940	Yes	Yes
DG	1HS-DG831	GE/CR2940	Yes	Yes
DG	1HS-DG832	ElctrSw/20K Hand Sw	Yes	Yes
DG	1HS-DG833	GE/CR2940	Yes	Yes
DG	1HS-DG834	GE/CR2940	Yes	Yes
DG	1HS-DG836	GE/CR2940	Yes	Yes
DG	1HS-DG838	GE/CR2940	Yes	Yes
DO	1HS-DO002	ElctrSw/20K Hand Sw	Yes	Yes
DO	1HS-DO005	ElctrSw/20K Hand Sw	Yes	Yes
DO	1HS-DO009	ElctrSw/20K Hand Sw	Yes	Yes
FC	1HS-FC090	GE/CR2940	Yes	Yes
FC	1HS-FC091	GE/CR2940	Yes	Yes
FC	1HS-FC092	GE/CR2940	Yes	Yes
FC	1HS-FC093	GE/CR2940	Yes	Yes
FC	1HS-FC096	GE/CR2940	Yes	Yes
FC	1HS-FC097	GE/CR2940	Yes	Yes
FC	1HS-FC098	GE/CR2940	Yes	Yes
FC	1HS-FC099	GE/CR2940	Yes	Yes
FC	1HS-FC100	GE/CR2940	Yes	Yes
FC	1HS-FC101	GE/CR2940	Yes	Yes
FC	1HS-FC102	GE/CR2940	Yes	Yes
FC	1HS-FC103	GE/CR2940	Yes	Yes
FC	1HS-FC104	GE/CR2940	Yes	Yes
FC	1HS-FC105	GE/CR2940	Yes	Yes
FC	1HS-FC106	ElctrSw/20K Hand Sw	Yes	Yes
FC	1HS-FC107	ElctrSw/20K Hand SW	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
FC	1HS-FC110	GE/CR2940	Yes	Yes
FC	1HS-FC111	GE/CR2940	Yes	Yes
FC	1HS-FC113	GE/CR2940	Yes	Yes
FC	1HS-FC114	GE/CR2940	Yes	Yes
FC	1HS-FC115	GE/CR2940	Yes	Yes
FC	1HS-FC116	GE/CR2940	Yes	Yes
FP	1HS-FP130	GE/CR2940	Yes	Yes
FP	1HS-FP139	GE/CR2940	Yes	Yes
FP	1HS-FP140	GE/CR2940	Yes	Yes
FP	1HS-FP141	GE/CR2940	Yes	Yes
FP	1HS-FP142	GE/CR2940	Yes	Yes
FP	1HS-FP143	GE/CR2940	Yes	Yes
FP	1HS-FP144	GE/CR2940	Yes	Yes
FP	1HS-FP145	GE/CR2940	Yes	Yes
FP	1HS-FP155	GE/CR2940	Yes	Yes
FP	1HS-FP156	GE/CR2940	Yes	Yes
FP	1HS-FP157	GE/CR2940	Yes	Yes
FP	1HS-FP158	GE/CR2940	Yes	Yes
HG	1HS-HG001	ElctrSw/20K Hand Sw	Yes	Yes
HG	1HS-HG004	ElctrSw/20K Hand Sw	Yes	Yes
HG	1HS-HG015A	GE/CR2940	Yes	Yes
HG	1HS-HG018A	GE/CR2940	Yes	Yes
HG	1HS-HG021A	ElctrSw/20K Hand Sw	Yes	Yes
HG	1HS-HG021B	GE/Stop Start Hd Sw-Type SBM	Yes	Yes
HG	1HS-HG021C	ITEImp/Mtr Strtr C1 8536,SCG-3	Yes	Yes
HG	1HS-HG021D	ITEImp/Mtr Strtr C1 8536,SCG-3	Yes	Yes
HG	1HS-HG021E	GE/CR2940	Yes	Yes
HG	1HS-HG022	ElctrSw/20K Hand Sw	Yes	Yes
HG	1HS-HG031	GE/CR2940	Yes	Yes
HG	1HS-HG032	GE/CR2940	Yes	Yes
HG	1HS-HG033	GE/CR2940	Yes	Yes
HG	1HS-HG034	GE/CR2940	Yes	Yes
HG	1HS-HG071	ElctrSw/20K Hand Sw	Yes	Yes
HG	1HS-HG072	ElctrSw/20K Hand Sw	Yes	Yes
IA	1HS-IA056	GE/CR2940	Yes	Yes
IA	1HS-IA057	GE/CR2940	Yes	Yes
IA	1HS-IA061	GE/CR2940	Yes	Yes
IA	1HS-IA064	GE/CR2940	Yes	Yes
IA	1HS-IA066	GE/CR2940	Yes	Yes
IA	1HS-IA067	GE/CR2940	Yes	Yes
IA	1HS-IA068	GE/CR2940	Yes	Yes
IA	1HS-IA069	GE/CR2940	Yes	Yes
RE	1HS-RE008	GE/CR2940	Yes	Yes
RE	1HS-RE009	GE/CR2940	Yes	Yes
RE	1HS-RE010	GE/CR2940	Yes	Yes
RE	1HS-RE011	GE/CR2940	Yes	Yes
RE	1HS-RE018	GE/CR2940	Yes	Yes
RE	1HS-RE019	GE/CR2940	Yes	Yes
RE	1HS-RF020	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RE	1HS-RF029	GE/CR2940	Yes	Yes
RE	1HS-RF030	GE/CR2940	Yes	Yes
RE	1HS-RF031	GE/CR2940	Yes	Yes
SA	1HS-SA020	GE/CR2940	Yes	Yes
SA	1HS-SA021	GE/CR2940	Yes	Yes
SA	1HS-SA071	GE/CR2940	Yes	Yes
SA	1HS-SA074	GE/CR2940	Yes	Yes
SF	1HS-SF001	GE/CR2940	Yes	Yes
SF	1HS-SF002	GE/CR2940	Yes	Yes
SF	1HS-SF004	GE/CR2940	Yes	Yes
SF	1HS-SF011	GE/CR2940	Yes	Yes
SF	1HS-SF012	GE/CR2940	Yes	Yes
SF	1HS-SF014	GE/CR2940	Yes	Yes
SF	1HS-SF015	GE/CR2940	Yes	Yes
SM	1HS-SM001	GE/CR2940	Yes	Yes
SM	1HS-SM002	GE/CR2940	Yes	Yes
SM	1HS-SM003	GE/CR2940	Yes	Yes
SM	1HS-SM004	GE/CR2940	Yes	Yes
SM	1HS-SM007	GE/CR2940	Yes	Yes
SM	1HS-SM008	GE/CR2940	Yes	Yes
SM	1HS-SM010	GE/CR2940	Yes	Yes
SM	1HS-SM011	GE/CR2940	Yes	Yes
SX	1HS-SX002	GE/CR2940	Yes	Yes
SX	1HS-SX004	GE/CR2940	Yes	Yes
SX	1HS-SX006	GE/CR2940	Yes	Yes
SX	1HS-SX007	ElctrSw/20K Hand Sw	Yes	Yes
SX	1HS-SX008	ElctrSw/20K Hand Sw	Yes	Yes
SX	1HS-SX009	ElctrSw/20K Hand Sw	Yes	Yes
SX	1HS-SX010	GE/CR2940	Yes	Yes
SX	1HS-SX011	GE/CR2940	Yes	Yes
SX	1HS-SX012	GE/CR2940	Yes	Yes
SX	1HS-SX013	GE/CR2940	Yes	Yes
SX	1HS-SX046	GE/CR2940	Yes	Yes
SX	1HS-SX047	GE/CR2940	Yes	Yes
SX	1HS-SX056	GE/CR2940	Yes	No
SX	1HS-SX057	GE/CR2940	Yes	No
SX	1HS-SX058	GE/CR2940	Yes	No
SX	1HS-SX062	GE/CR2940	Yes	Yes
SX	1HS-SX063	GE/CR2940	Yes	Yes
SX	1HS-SX064	GE/CR2940	Yes	Yes
SX	1HS-SX071	GE/CR2940	Yes	Yes
SX	1HS-SX072	GE/CR2940	Yes	Yes
SX	1HS-SX084	GE/CR2940	Yes	Yes
SX	1HS-SX086	GE/CR2940	Yes	Yes
SX	1HS-SX109	GE/CR2940	Yes	Yes
SX	1HS-SX110	GE/CR2940	Yes	Yes
SX	1HS-SX111	GE/CR2940	Yes	Yes
SX	1HS-SX161	GE/CR2940	Yes	Yes
SX	1HS-SX162	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
SX	1HS-SX163	GE/CR2940	Yes	Yes
SX	1HS-SX164	GE/CR2940	Yes	Yes
SX	1HS-SX165	GE/CR2940	Yes	Yes
SX	1HS-SX166	GE/CR2940	Yes	Yes
SX	1HS-SX175	GE/CR2940	Yes	Yes
SX	1HS-SX176	GE/CR2940	Yes	Yes
SX	1HS-SX177	GE/CR2940	Yes	Yes
SX	1HS-SX178	GE/CR2940	Yes	Yes
SX	1HS-SX180	GE/CR2940	Yes	Yes
SX	1HS-SX181	GE/CR2940	Yes	Yes
SX	1HS-SX182	GE/CR2940	Yes	Yes
SX	1HS-SX183	GE/CR2940	Yes	Yes
SX	1HS-SX184	GE/CR2940	Yes	Yes
SX	1HS-SX185	GE/CR2940	Yes	Yes
SX	1HS-SX186	GE/CR2940	Yes	Yes
SX	1HS-SX187	GE/CR2940	Yes	Yes
SX	1HS-SX188	GE/CR2940	Yes	Yes
SX	1HS-SX189	GE/CR2940	Yes	Yes
SX	1HS-SX190	GE/CR2940	Yes	Yes
SX	1HS-SX191	GE/CR2940	Yes	Yes
SX	1HS-SX201	GE/CR2940	Yes	Yes
SX	1HS-SX202	GE/CR2940	Yes	Yes
SX	1HS-SX203	GE/CR2940	Yes	Yes
SX	1HS-SX204	GE/CR2940	Yes	Yes
SX	1HS-SX205	GE/CR2940	Yes	Yes
SX	1HS-SX206	GE/CR2940	Yes	Yes
SX	1HS-SX207	GE/CR2940	Yes	Yes
SX	1HS-SX208	GE/CR2940	Yes	Yes
SX	1HS-SX209	GE/CR2940	Yes	Yes
SX	1HS-SX210	GE/CR2940	Yes	Yes
SX	1HS-SX211	GE/CR2940	Yes	Yes
SX	1HS-SX212	GE/CR2940	Yes	Yes
VA	1HS-VA001	GE/SBM	Yes	Yes
VD	1HS-VD001	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD002	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD003	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD010	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD011	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD012	ElctrSw/20K Hand Sw	Yes	Yes
VD	1HS-VD070	GE/ CR 2940 VB-203A	Yes	Yes
VD	1HS-VD071	GE/ CR 2940 VB-203A	Yes	Yes
VD	1HS-VD072	GE/ CR 2940 VB-203A	Yes	Yes
VD	1HS-VD101	GE/CR2940	Yes	Yes
VD	1HS-VD102	GE/CR2940	Yes	Yes
VD	1HS-VD103	GE/CR2940	Yes	Yes
VF	1HS-VF021	GE/CR2940	Yes	Yes
VF	1HS-VF023	GE/CR2940	Yes	Yes
VG	1HS-VG001	ElctrSw/20K Hand Sw	Yes	Yes
VG	1HS-VG002	ElctrSw/20K Hand Sw	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	1HS-VG005	GE/CR2940	Yes	Yes
VG	1HS-VG007	GE/CR2940	Yes	Yes
VG	1HS-VG101	ElctrSw/20K Hand Sw	Yes	Yes
VG	1HS-VG102	ElctrSw/20K Hand Sw	Yes	Yes
VG	1HS-VG105	GE/CR2940	Yes	Yes
VG	1HS-VG107	GE/CR2940	Yes	Yes
VH	1HS-VH001	GE/CR2940	Yes	Yes
VH	1HS-VH002	GE/CR2940	Yes	Yes
VH	1HS-VH003	GE/CR2940	Yes	Yes
VH	1HS-VH101	GE/CR2940	Yes	Yes
VH	1HS-VH102	GE/CR2940	Yes	Yes
VH	1HS-VH103	GE/CR2940	Yes	Yes
VP	1HS-VP001	ElctrSw/20K Hand Sw	Yes	Yes
VP	1HS-VP002	Elctrsw/20K Hand Sw	Yes	Yes
VP	1HS-VP003	Elctrsw/20K Hand Sw	Yes	Yes
VP	1HS-VP004	ElctrSw/20K Hand Sw	Yes	Yes
VP	1HS-VP005B	GE/CR2940	Yes	Yes
VP	1HS-VP006B	GE/CR2940	Yes	Yes
VP	1HS-VP007	ElctrSw/20K Hand Sw	Yes	Yes
VP	1HS-VP008	ElctrSw/20K Hand Sw	Yes	Yes
VP	1HS-VP041	GE/CR2940	Yes	Yes
VP	1HS-VP042	GE/CR2940	Yes	Yes
VP	1HS-VP043	GE/CR2940	Yes	Yes
VP	1HS-VP044	GE/CR2940	Yes	Yes
VP	1HS-VP061	GE/CR2940	Yes	Yes
VP	1HS-VP062	GE/CR2940	Yes	Yes
VP	1HS-VP071	GE/CR2940	Yes	Yes
VP	1HS-VP072	GE/CR2940	Yes	Yes
VQ	1HS-VQ006	GE/CR2940	Yes	Yes
VQ	1HS-VQ007	GE/CR2940	Yes	Yes
VQ	1HS-VQ022	GE/CR2940	Yes	Yes
VQ	1HS-VQ024	GE/CR2940	Yes	Yes
VQ	1HS-VQ026	GE/CR2940	Yes	Yes
VQ	1HS-VQ028	GE/CR2940	Yes	Yes
VQ	1HS-VQ030	GE/CR2940	Yes	Yes
VQ	1HS-VQ032	GE/CR2940	Yes	Yes
VQ	1HS-VQ094	GE/CR2940	Yes	Yes
VQ	1HS-VQ099	GE/CR2940	Yes	Yes
VQ	1HS-VQ111	GE/CR2940	Yes	Yes
VQ	1HS-VQ112	GE/CR2940	Yes	Yes
VQ	1HS-VQ121	GE/CR2940	Yes	Yes
VQ	1HS-VQ122	GE/CR2940	Yes	Yes
VR	1HS-VR008	GE/CR2940	Yes	Yes
VR	1HS-VR009	GE/CR2940	Yes	Yes
VR	1HS-VR010	GE/CR2940	Yes	Yes
VR	1HS-VR032	GE/CR2940	Yes	Yes
VR	1HS-VR045	GE/SBM	Yes	Yes
VR	1HS-VR046	GE/SBM	Yes	Yes
VR	1HS-VR108	GE/CR2940	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VR	1HS-VR109	GE/CR2940	Yes	Yes
VR	1HS-VR162	GE/CR2940	Yes	Yes
VR	1HS-VR163	GE/CR2940	Yes	Yes
VR	1HS-VR200	GE/CR2940	Yes	Yes
VR	1HS-VR201	GE/CR2940	Yes	Yes
VR	1HS-VR204	GE/CR2940	Yes	Yes
VR	1HS-VR205	GE/CR2940	Yes	Yes
VX	1HS-VX001	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX002	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX003	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX040	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX041	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX042	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX050	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX051	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX070	ElctrSw/20K Hand Sw	Yes	Yes
VX	1HS-VX071	ElctrSw/20K Hand SW	Yes	Yes
VX	1HS-VX081	GE/CR2940	Yes	Yes
VX	1HS-VX082	GE/CR2940	Yes	Yes
VX	1HS-VX083	GE/CR2940	Yes	Yes
VX	1HS-VX111A	GE/SMB	Yes	Yes
VX	1HS-VX111B	AlnBrdly/HandSw17FA999-1007-41	Yes	Yes
VX	1HS-VX111C	AlnBrdly/HandSw17FA444-1007-41	Yes	Yes
VX	1HS-VX113AX	GE/HS SMB	Yes	Yes
VX	1HS-VX113B	AlnBrdly/HandSw17FA999-1007-41	Yes	Yes
VX	1HS-VX113C	AlnBrdly/HandSw17FA444-1007-41	Yes	Yes
VX	1HS-VX115A	GE/SMB	Yes	Yes
VX	1HS-VX115B	AlnBrdly/HandSw17FA999-1007-41	Yes	Yes
VX	1HS-VX115C	AlnBrdly/HandSw17FA444-1007-41	Yes	Yes
VX	1HS-VX120	GE/SMB	Yes	Yes
VX	1HS-VX122	GE/SMB	Yes	Yes
VX	1HS-VX124	GE/SMB	Yes	Yes
VY	1HS-VY001	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY002	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY003	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY004	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY005	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY006	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY007	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY008	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY009	ElctrSw/20K Hand Sw	Yes	Yes
VY	1HS-VY101	GE/CR2940	Yes	Yes
VY	1HS-VY102	GE/CR2940	Yes	Yes
VY	1HS-VY103	GE/CR2940	Yes	Yes
VY	1HS-VY120	GE/SMB	Yes	Yes
VY	1HS-VY125	GE/SMB	Yes	Yes
WO	1HS-W0050	GE/CR2940	Yes	Yes
WO	1HS-W0051	GE/CR2940	Yes	Yes
WO	1HS-W0970	GE/Slctr Sw	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
WD	1HS-W0971	GE/Slectr Sw	Yes	Yes
WX	1HS-WX318	Cutler Hammer/E30	Yes	Yes
WX	1HS-WX319	Cutler Hammer/E30	Yes	Yes
FC	1HSV-FC110	Asco/2068323U	Yes	Yes
FC	1HSV-FC110(OS)	Conax/7F20-11001-03	Yes	Yes
FC	1HSV-FC111	Asco/2068323U	Yes	Yes
FC	1HSV-FC111(OS)	Conax/7F20-11001-03	Yes	Yes
HT	1HT-270E	Rachem/30HTT-FS	Yes	Yes
HT	1HT-271E	Rachem/30HTT-FS	Yes	Yes
HT	1HT-276E	Rachem/30HTT-FS	Yes	Yes
HT	1HT-277E	Rachem/30HTT-FS	Yes	Yes
IA	1IA005(L)	Namco/EA180	Yes	Yes
IA	1IA005(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1IA005(O)	Asco/2068323U	Yes	Yes
IA	1IA005(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1IA005(V)	Fshr/3" AO 6lb Vlv	Yes	Yes
IA	1IA006(L)	Namco/EA180	Yes	Yes
IA	1IA006(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1IA006(O)	Asco/2068323U	Yes	Yes
IA	1IA006(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1IA006(V)	Fshr/3" AO 6lb Vlv	Yes	Yes
IA	1IA007(L)	Namco/EA180	Yes	Yes
IA	1IA007(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1IA007(O)	Asco/2068323U	Yes	Yes
IA	1IA007(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1IA007(V)	Fshr/3" AO 6lb Vlv	Yes	Yes
IA	1IA008(L)	Namco/EA180	Yes	Yes
IA	1IA008(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1IA008(O)	Asco/2068323U	Yes	Yes
IA	1IA008(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1IA008(V)	Fshr/3" AO 6lb Vlv	Yes	Yes
IA	1IA012A(A)	Lmt/SMB-000	Yes	Yes
IA	1IA012A(V)	Yrwy/1" 6lb Vlv	Yes	No
IA	1IA012B(A)	Lmt/SMB-000	Yes	Yes
IA	1IA012B(V)	Yrwy/1" 6lb Vlv	Yes	No
IA	1IA013A(A)	Lmt/SMB-000	Yes	Yes
IA	1IA013A(V)	Yrwy/1" 6lb Vlv	Yes	No
IA	1IA013B(A)	Lmt/SMB-000	Yes	Yes
IA	1IA013B(V)	Yrwy/1" 6lb Vlv	Yes	No
IA	1IA044A	TrgtRck/Press Reg Vlv	Yes	Yes
IA	1IA044B	TrgtRck/Press Reg Vlv	Yes	Yes
IA	1IA128A	Dresser/1.5" SRV	Yes	Yes
IA	1IA128B	Dresser/1.5" SRV	Yes	Yes
AP	1II-AP707	GE/180 Vert Ind	Yes	Yes
AP	1II-AP784	GE/AB40	Yes	Yes
AP	1II-AP787	GE/AB40	Yes	Yes
AP	1II-AP788	GE/AB40	Yes	Yes
AB	1II-AP789	GE-AB40	Yes	Yes
AP	1II-AP837	GE/180 Vert Ind	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DC	111-DC006	GE/180 Vert Ind	Yes	Yes
DC	111-DC007	GE/180 Vert Ind	Yes	Yes
DC	111-DC008	GE/180 Vert Ind	Yes	Yes
DC	111-DC012	Yokogawa/Ammeter	Yes	No
DC	111-DC013	Yokogawa/Ammeter	Yes	No
DC	111-DC017	Yokogawa/Ammeter	Yes	No
DC	111-DC018	Yokogawa/Ammeter	Yes	No
DC	111-DC045	Yokogaw/Elect Ind	Yes	No
DC	111-DC046	Yokogaw/Elect Ind	Yes	No
DC	111-DC049	Wsths/Elect Ind KX241	Yes	No
DC	111-DC051	Wsths/Elect Ind KX241	Yes	No
DG	111-DG245	GE/Current Ind	Yes	Yes
DG	111-DG805A	GE/180 Vert Ind	Yes	Yes
DG	111-DG805B	GE/180 Vert Ind	Yes	Yes
DG	111-DG811B	GE/180 Vert Ind	Yes	Yes
DG	111-DG842	GE/Div3 Bat Distr Bus	Yes	Yes
DG	111-DG844	GE/Div3 Bat Chgr Cur	Yes	Yes
FC	111-FC119	GE/180 Vert Ind	Yes	Yes
FC	111-FC120	GE/180 Vert Ind	Yes	Yes
IP	111-RP001	GE/AB30	Yes	Yes
IP	111-RP003	GE/AB30	Yes	Yes
IP	111-RP005	GE/AB30	Yes	Yes
IP	111-RP007	GE/AB30	Yes	Yes
SX	111-SX114	GE/180 Vert Ind	Yes	Yes
SX	111-SX115	GE/180 Vert Ind	Yes	Yes
IP	11P78E	PwrCtyPrd/RTF 480-120-15	Yes	Yes
AP	11Y-AP703	Wsths/Current Xfmr V-4	Yes	Yes
AP	11Y-AP707	Wsths/Current Xfmr V-4	Yes	Yes
AP	11Y-AP765	Wsths/V-4	Yes	Yes
AP	11Y-AP772	Wsths/V-4	Yes	Yes
AP	11Y-AP779	GE/NAV 4722	Yes	Yes
AP	11Y-AP781	GE/NAV 4722	Yes	Yes
AP	11Y-AP789	GE/NAV 4722	Yes	No
AP	11Y-AP837	Wsths/Current Xtmr V-4	Yes	Yes
AP	11Y-AP841	GE/Current Xmtr 4722	Yes	Yes
DC	11Y-DC060	Xmation/SignConv 630T-07-64-65	Yes	Yes
CX	11Y-DC062	Xmation/SignConv 630T-07-64-65	Yes	Yes
CX	11Y-DC064	Xmation/SignConv 630T-07-64-65	Yes	Yes
DG	11Y-DG805	Wsths/V-4	Yes	Yes
DG	11Y-DG811	Wsths/V-4	Yes	Yes
FC	11Y-FC119	Wsths/Current Xtmr V-4	Yes	Yes
FC	11Y-FC120	Wsths/Current Xtmr V-4	Yes	Yes
SX	11Y-SX114	Wsths/Current Xtmr V-4	Yes	Yes
SX	11Y-SX115	Wsths/Current Xtmr V-4	Yes	Yes
VG	1JI-AP767	GE/DSW-63	Yes	Yes
AP	1JI-AP775	GE/DSW-63	Yes	Yes
AP	1JI-AP783	GE/DSW-63	Yes	Yes
DG	1JI-DG803	GE/DSW-63	Yes	Yes
VG	1JI-DG809	Wsths/V-4	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DG	1JI-DG810	GE/180 Vert Ind	Yes	Yes
AP	1JY-AP766	Wsths/V4	Yes	Yes
AP	1JY-AP768	Wsths/V4	Yes	Yes
AP	1JY-AP773	Wsths/V4	Yes	Yes
AP	1JY-AP774	Wsths/V4	Yes	Yes
AP	1JY-AP778	GE/NAV 4723	Yes	Yes
AP	1JY-AP780	GE/Nav 4723	Yes	Yes
DG	1JY-DG802	Wsths/V4 Transducer	Yes	Yes
DG	1JY-DG804	Wsths/V4	Yes	Yes
DG	1JY-DG808	Wsths/V4	Yes	Yes
DG	1JY-DG810	W/House/V-4	Yes	Yes
DG	1KI-DG248	Datcon/571-120V-DC	Yes	Yes
FG	1KY-FG041	Authenia/Time Delay Relay	No	Yes
FG	1KY-FG051	Authenia/Time Delay Relay	No	Yes
HG	1KY-HG041	AT&C/TmpAlrmDlyTmr305D010A10PX	Yes	Yes
HG	1KY-HG051	AT&C/TmpAlrm Dly Tmr 319B0001C	Yes	Yes
SX	1KY-SX059A	Eagle/Time Delay Relay	Yes	Yes
SX	1KY-SX059B	Eagle/Time Delay Relay	Yes	Yes
SX	1KY-SX060A	Eagle/Time Delay Relay	Yes	Yes
SX	1KY-SX060B	Eagle/Time Delay Relay	Yes	Yes
SX	1KY-SX061A	Eagle/Time Delay Relay	Yes	Yes
SX	1KY-SX061B	Eagle/Time Delay Relay	Yes	Yes
VD	1KY-VD080	EglCylk1Flex/HP57A601	Yes	Yes
VD	1KY-VD081	EglCylk1Flex/HP57A601	Yes	Yes
VD	1KY-VD082	EglCylk1Flex/HP57A601	Yes	Yes
VH	1KY-VH025	Agst/7014AD	Yes	Yes
VH	1KY-VH026	Agst/7014AD	Yes	Yes
VH	1KY-VH027	Agst/7014AD	Yes	Yes
VP	1KY-VP019	Agst/7014AD	Yes	Yes
VP	1KY-VP020	Agst/7014AD	Yes	Yes
VP	1KY-VP021	Agst/7014AD	Yes	Yes
VP	1KY-VP022	Agst/7014AD	Yes	Yes
VP	1KY-VP023	Agst/7014AD	Yes	Yes
VP	1KY-VP024	Agst/7014AD	Yes	Yes
VX	1KY-VX016	Agst/7014AD	Yes	Yes
VX	1KY-VX017	Agst/7014AD	Yes	Yes
VX	1KY-VX018	Agst/7014AD	Yes	Yes
VX	1KY-VX046	Agst/7014AD	Yes	No
VX	1KY-VX047	Agst/7014AD	Yes	No
VX	1KY-VX048	Agst/7014AD	Yes	No
VX	1KY-VX066	Agst/7014AD	Yes	Yes
VX	1KY-VX068	Agst/7014AD	Yes	Yes
VX	1KY-VX074	Agst/7014AD	Yes	Yes
VX	1KY-VX075	Agst/7014AD	Yes	Yes
VY	1KY-VY075	Agst/7014AD	Yes	Yes
VY	1KY-VY076	Agst/7014AD	Yes	Yes
VY	1KY-VY077	Agst/7014AD	Yes	Yes
VY	1KY-VY078	Agst/7014AD	Yes	Yes
VY	1KY-VY079	Agst/7014AD	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VY	1KY-VY080	Agst/7014AD	Yes	Yes
VY	1KY-VY081	Agst/7014AD	Yes	Yes
CM	1LI-CM260	GE/180 Vert Ind	Yes	Yes
CM	1LI-CM261	GE/180 Vert Ind	Yes	Yes
DO	1LI-DO011	GE/180 Vert Ind	Yes	Yes
DO	1LI-DO012	GE/180 Vert Ind	Yes	Yes
DO	1LI-DO013	GE/180 Vert Ind	Yes	Yes
DO	1LI-DO020	ITTBtrn/DP Sw (288A)	Yes	Yes
DO	1LI-DO021	ITTBtrn/DP Sw (288A)	Yes	Yes
DO	1LI-DO022	ITTBtrn/DP Sw (288A)	Yes	Yes
CM	1LR-CM030	L&N/PPD164C5067	Yes	Yes
CM	1LR-CM031	L&N/PPD164C5067	Yes	Yes
CM	1LR-CM240	TracorWestronics/D4V	Yes	Yes
CM	1LR-CM241	TracorWestronics/D4V	Yes	Yes
SM	1LR-SM014	TracorWestronics/T4N	Yes	Yes
CM	1LR-SM016	TracorWestronics/T4N	Yes	Yes
CM	1LS-CM278	Magnetrol/Lvl Sw	Yes	Yes
CM	1LS-CM279	Mgntrl/Level Swtch	Yes	Yes
CM	1LS-CM280	Magnetrol/Lvl Sw	Yes	Yes
CM	1LS-CM281	Magnetrol/Lvl Sw	Yes	Yes
CM	1LS-CM282	Magnetrol/Lvl Sw	Yes	Yes
CM	1LS-CM283	Magnetrol/Lvl Sw	Yes	Yes
CM	1LS-CM284	Magnetrol/Lvl Sw	Yes	Yes
DG	1LS-DG203	Murphy/3L-150K1	Yes	Yes
CM	1LT-CM030	Rsmt/1153	Yes	Yes
SM	1LT-CM030(S)	Conax/7F20-11006-01	Yes	Yes
CM	1LT-CM031	Rsmt/1153	Yes	Yes
SM	1LT-CM031(S)	Conax/7F20-11006-01	Yes	Yes
CM	1LT-CM260A	Rsmt/1153	Yes	Yes
CM	1LT-CM260A(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM260B	Rsmt/1153	Yes	Yes
CM	1LT-CM260B(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM260C	Rsmt/1153	Yes	Yes
CM	1LT-CM260C(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM260D	Rsmt/1153	Yes	Yes
CM	1LT-CM260D(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM260E	Rsmt/1153	Yes	Yes
CM	1LT-CM260E(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM260F	Rsmt/1153	Yes	Yes
CM	1LT-CM260F(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261A	Rsmt/1153	Yes	Yes
CM	1LT-CM261A(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261B	Rsmt/1153	Yes	Yes
CM	1LT-CM261B(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261C	Rsmt/1153	Yes	Yes
CM	1LT-CM261C(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261D	Rsmt/1153	Yes	Yes
CM	1LT-CM261D(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261E	Rsmt/1153	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1LT-CM261E(S)	Conax/7F20-11006-02	Yes	Yes
CM	1LT-CM261F	Rsmt/1153	Yes	Yes
CM	1LT-CM261F(S)	Conax/7F20-11006-02	Yes	Yes
DO	1LT-DO0001	Rsmt/1153	Yes	Yes
DO	1LT-DO0004	Rsmt/1153	Yes	Yes
DO	1LT-DO0008	Rsmt/1153	Yes	Yes
DO	1LT-DO0011	Rsmt/1153	Yes	Yes
DO	1LT-DO0012	Rsmt/1153	Yes	Yes
DO	1LT-DO0013	Rsmt/1153	Yes	Yes
FC	1LT-FC125	Rsmt/1153	Yes	Yes
SM	1LT-SM006	Rsmt/1153	Yes	Yes
SM	1LT-SM006(S)	Conax/7F20-11006-01	Yes	Yes
SM	1LT-SM013	Rsmt/1153	Yes	Yes
SM	1LT-SM013(S)	Conax/7F20-11006-01	Yes	Yes
SM	1LT-SM014	Rsmt/1153	Yes	Yes
SM	1LT-SM014(S)	Conax/7F20-11006-01	Yes	Yes
SM	1LT-SM015	Rsmt/1153	Yes	Yes
SM	1LT-SM015(S)	Conax/7F20-11006-01	Yes	Yes
SM	1LT-SM016	Rsmt/1153	Yes	Yes
SM	1LT-SM016(S)	Conax/7F20-11006-01	Yes	Yes
SM	1LT-SM017	Rsmt/1153	Yes	Yes
SM	1LT-SM017(S)	Conax/7F20-11006-01	Yes	Yes
CM	1LY-CM030	Rsmt/510 DU	Yes	Yes
CM	1LY-CM031	Rsmt/510 DU	Yes	Yes
DO	1LY-DO001A	Rsmt/510 DU	Yes	Yes
DO	1LY-DO001B	Rsmt/510 DU	Yes	Yes
DO	1LY-DO001C	Rsmt/510 DU	Yes	Yes
DO	1LY-DO004A	Rsmt/510 DU	Yes	Yes
DO	1LY-DO004B	Rsmt/510 DU	Yes	Yes
DO	1LY-DO004C	Rsmt/510 DU	Yes	Yes
DO	1LY-DO008A	Rsmt/510 DU	Yes	Yes
DO	1LY-DO008B	Rsmt/510 DU	Yes	Yes
DO	1LY-DO008C	Rsmt/510 DU	Yes	Yes
DO	1LY-DO0011	Rsmt/510 DU	Yes	Yes
DO	1LY-DO0012	Rsmt/510 DU	Yes	Yes
DO	1LY-DO0013	Rsmt/510 DU	Yes	Yes
SM	1LY-SM006	Rsmt/510 DU	Yes	Yes
SM	1LY-SM013	Rsmt/510 DU	Yes	Yes
CM	1M033(OS)	Conax/7F20-11007-01	Yes	Yes
VX	1PC-VX112	Hywl/Press Cont Sys 27335C	Yes	Yes
VX	1PC-VX114	Hywl/Press Cont Sys 27335C	Yes	Yes
VX	1PC-VX116	Hywl/Press Cont Sys 27335C	Yes	Yes
VY	1PCI-VY073	Dwyer/2000 DP Gage	Yes	Yes
HG	1PDI-HG052B	GE/180 Vert Ind	Yes	Yes
HG	1PDI-HG053B	GE/180 Vert Ind	Yes	Yes
VD	1PDI-VD040	Dwyer/2000 DP Gage	Yes	Yes
VD	1PDI-VD041	Dwyer/2000 DP Gage	Yes	Yes
VD	1PDI-VD042	Dwyer/2000 DP Gage	Yes	Yes
VD	1PDI-VD043	Dwyer/2000 DP Gage	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VD	1PDI-VD044	Dwyer/2000 DP Gage	Yes	Yes
VD	1PDI-VD045	Dwyer/2000 DP Gage	Yes	Yes
VF	1PDI-VF013	Dwyer/2000 DP Gage	Yes	Yes
VG	1PDI-VG149	Lv/Ind Mtr 54-8115-8114-8174	Yes	Yes
VG	1PDI-VG150	Lv/Ind Mtr 48-8115-8174	Yes	Yes
VG	1PDI-VG151	Lv/Ind Mtr 54-8115-8114-8174	Yes	Yes
VD	1PDI-VG152	Lv/Ind Mtr 48-8115-8174	Yes	Yes
VH	1PDI-VH022	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH023	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH024	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH041	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH042	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH043	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH044	Dwyer/2000 DP Gage	Yes	Yes
VH	1PDI-VH045	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX028	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX029	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX031	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX032	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX033	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX034	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX035	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX036	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX037	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX038	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX039	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX043	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX044	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX045	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX064	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX065	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX072	Dwyer/2000 DP Gage	Yes	Yes
VX	1PDI-VX073	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY066	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY067	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY068	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY069	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY070	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY072	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY074	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY101	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY102	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY103	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY104	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY105	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY106	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY107	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY108	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY109	Dwyer/2000 DP Gage	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VY	1PDI-VY110	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY111	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY112	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY113	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY114	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY115	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY116	Dwyer/2000 DP Gage	Yes	Yes
VY	1PDI-VY117	Dwyer/2000 DP Gage	Yes	Yes
DG	1PDS-DG185	SQ-D/9012-AEW-3	Yes	Yes
DG	1PDS-DG200	SQ-D/9012-AEW-1	Yes	Yes
SX	1PDS-SX022	ITTBrtn/DP Sw 580-0	Yes	Yes
SX	1PDS-SX024	ITTBrtn/DP Sw 580-0	Yes	Yes
SX	1PDS-SX026	ITTBrtn/DP Sw 580-0	Yes	Yes
VD	1PDS-VD027	Solon/7PSIIDPN	Yes	Yes
VD	1PDS-VD028	Solon/7PSIIDPN	Yes	Yes
VD	1PDS-VD029	Solon/7PSIIDPN	Yes	Yes
VD	1PDS-VD030	Solon/7PSIIDPN	Yes	Yes
VD	1PDS-VD031	Solon/7PSIIDPN	Yes	Yes
VD	1PDS-VD032	Solon/7PSIIDPN	Yes	Yes
VH	1PDS-VH025	Solon/7PSIIDPN	Yes	Yes
VH	1PDS-VH026	Solon/7PSIIDPW	Yes	Yes
VH	1PDS-VH027	Solon/7PSIIDPW	Yes	Yes
VX	1PDS-VX016	Solon/7PSIIDPW	Yes	Yes
VX	1PDS-VX017	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX018	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX046	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX047	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX048	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX066	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX067	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX068	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX069	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX074	Solon/7PSIIDW	Yes	Yes
VX	1PDS-VX075	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY075	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY076	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY077	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY078	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY079	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY080	Solon/7PSIIDW	Yes	Yes
VY	1PDS-VY081	Solon/7PSIIDW	Yes	Yes
HG	1PDT-HG052	Rsmr/1153	Yes	Yes
HG	1PDT-HG052(S)	Conax/7F20-11006-01	Yes	Yes
HG	1PDT-HG053	Rsmr/1153	Yes	Yes
HG	1PDT-HG053(S)	Conax/7F20-11006-01	Yes	Yes
VG	1PDT-VG149	Vldyn/DP Xmtr	Yes	Yes
VG	1PDT-VG150	Vldyn/DP Xmtr	Yes	Yes
VG	1PDT-VG151	Vldyn/DP Xmtr	Yes	Yes
VG	1PDT-VG152	Vldyn/DP Xmtr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1PI-CM085	Bendix/	Yes	Yes
CM	1PI-CM086	Bendix/	Yes	Yes
CM	1PI-CM087	Bendix/	Yes	Yes
CM	1PI-CM088	Bendix/	Yes	Yes
CM	1PI-CM089	Bendix/	Yes	Yes
CM	1PI-CM090	Bendix/	Yes	Yes
CM	1PI-CM097	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM098	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM099	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM100	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM101	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM102	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM103	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM104	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM105	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM106	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM107	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM108	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM109	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM110	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM111	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM112	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM113	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM114	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM115	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM116	Linde/UPE 3-100	Yes	Yes
CM	1PI-CM197	McDaniel/Press Ind Model LB	Yes	Yes
CM	1PI-CM198	McDaniel/Press Ind Model LB	Yes	Yes
DG	1PI-DG176	Marsh/Press Gage	Yes	Yes
DG	1PI-DG177	Marsh/Press Gage	Yes	Yes
DG	1PI-DG198	Marsh/Press Gage	Yes	Yes
DO	1PI-DO017	ITTBrtn/DP Sw (288A)	Yes	Yes
DO	1PI-DO018	ITTBrtn/DP Sw (288A)	Yes	Yes
DO	1PI-DO019	ITTBrtn/DP Sw (288A)	Yes	Yes
IA	1PI-IA078	GE/180 Vert Ind	Yes	Yes
IA	1PI-IA079	GE/180 Vert Ind	Yes	Yes
IA	1PI-IA080	GE/180 Vert Ind	Yes	Yes
IA	1PI-IA081	GE/180 Vert Ind	Yes	Yes
SX	1PI-SX028	GE/180 Vert Ind	Yes	Yes
SX	1PI-SX03	GE/180 Vert Ind	Yes	Yes
SX	1PI-SX030	GE/180 Vert Ind	Yes	Yes
SX	1PI-SX032	GE/180-Vert. Ind.	Yes	Yes
FC	1PIS-FC082	ITTBrtn/288A	Yes	Yes
FC	1PIS-FC083	ITTBrtn/288A	Yes	Yes
PL	1PL12JA	S&S/Trnsf Pnl	Yes	Yes
PL	1PL12JB	S&S/Trnsf Pnl	Yes	Yes
PL	1PL14J	MCCPwrs/HVAC CntPnl	Yes	Yes
PL	1PL43JA	MCCPwrs/Drywell Cool Pnl	Yes	Yes
PL	1PL43JB	Pwrs/Drywell Cool Pnl	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PL	1PL44J	MCCPwrs/HVAC CntPnl	Yes	Yes
PL	1PL48JA	Salmon/HPCV Swgr Cont Pnl	Yes	Yes
PL	1PL48JB	Salmon/HPCV Swgr Cont Pnl	Yes	Yes
PL	1PL48JC	Salmon/HPCV Swgr Cont Pnl	Yes	Yes
PL	1PL49J	E-Max/Opt Isol Cab	Yes	Yes
PL	1PL53JA	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL53JB	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL53JC	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL54JA	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL54JB	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL54JC	MCCPwrs/HVAC Cont JE Inst	Yes	Yes
PL	1PL56JA	E-Max/Opt Isol Cab	Yes	Yes
PL	1PL56JB	E-Max/Opt Isol Cab	Yes	Yes
PL	1PL57JA	E-Max/Opt Isol Cab	Yes	Yes
PL	1PL57JB	E-Max/Opt Isol Cab	Yes	Yes
PL	1PL61JA	Pwrs/RHR Pmp & Ht Exch Rm 1A	Yes	Yes
PL	1PL61JB	Pwrs/RHR Pmp & Ht Exch Rm 1B	Yes	Yes
PL	1PL61JC	Pwrs/RHR Pmp & Ht Exch Rm 1C	Yes	Yes
PL	1PL62J	Pwrs/RCIC Pmp Rm	Yes	Yes
PL	1PL63J	Pwrs/LPCS Pmp Rm	Yes	Yes
PL	1PL64J	Pwrs/HPCS Pmp Rm	Yes	Yes
PL	1PL65JA	MCCPwrs/HVAC Cont Pnl	Yes	Yes
PL	1PL65JB	MCCPwrs/Swgr Rm 1B	Yes	Yes
PL	1PL65JC	MCCPwrs/HVAC Contl Pnl	Yes	Yes
PL	1PL67J	MCCPwrs/MSIV Cus HVAC Pnl	Yes	Yes
PL	1PL68JA	MCCPwrs/HVAC Cont Pnl	Yes	Yes
PL	1PL91J	MCCPwrs/Cont Pnl 1PL91J	Yes	Yes
PL	1PL92JA	Hoffman/Pnl A-1412CM	Yes	Yes
PL	1PL92JB	Hoffman/Pnl A-1412CM	Yes	Yes
PL	1PL93JA	Hoffman/Pnl A-1412CM	Yes	Yes
CM	1PR-CM063	TracorWestronics/D4N	Yes	Yes
CM	1PR-CM064	TracorWestronics/D4N	Yes	Yes
CM	1PR-CM256	TracorWestronics/D4N	Yes	Yes
CM	1PR-CM257	TracorWestronics/D4N	Yes	Yes
CM	1PS-CM117	Bendix/Q006455-1	Yes	Yes
CM	1PS-CM118	Bendix/Q006455-1	Yes	Yes
DG	1PS-DG062B	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG062C	SQ-L Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG063B	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG063C	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG064B	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG064C	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG065B	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG065C	SQ-D/Press Sw 9012-ACW-21	Yes	Yes
DG	1PS-DG122	EMD/Press Sw 8475932	Yes	Yes
DG	1PS-DG123	EMD/Press Sw 8475932	Yes	Yes
DG	1PS-DG124	EMD/Press Sw 8475932	Yes	Yes
DG	1PS-DG125	EMD/Press Sw 8475932	Yes	Yes
DG	1PS-DG172	SQ-D/9012-ACW-2 Press Sw	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DG	1PS-DG173	SQ-D/9012-ACW-2 Press Sw	Yes	Yes
DG	1PS-DG174	SQ-D/9012-ACW-2 Press Sw	Yes	Yes
DG	1PS-DG175	SQ-D/9012-ACW-2 Press Sw	Yes	Yes
DG	1PS-DG178	SQ-D/9012-ACW-9	Yes	Yes
DG	1PS-DG179	SQ-D/9012-ACW-9	Yes	Yes
DG	1PS-DG180	SQ-D/9012-ACW-9	Yes	Yes
DG	1PS-DG188	SQ-D/9012-ACW-5	Yes	Yes
DG	1PS-DG192	SQ-D/9012-ACW-1	Yes	Yes
DG	1PS-DG193	SQ-D/9012-ACW-21	Yes	Yes
DG	1PS-DG194	SQ-D/9012-ACW-21	Yes	Yes
DG	1PS-DG197	SQ-D/9012-ACW-12	Yes	Yes
DG	1PS-DG199	SQ-D/9012-ACW-5	Yes	Yes
DG	1PS-DG289	SQ-D/9012-ACW-5	Yes	Yes
IA	1PS-IA084	ITTBrtn/288A	Yes	Yes
IA	1PS-IA085	ITTBrtn/288A	Yes	Yes
VX	1PS-VX112A	Vel/Press Sw J69-364	Yes	Yes
VX	1PS-VX112B	Vel/Press Sw J69-356	Yes	Yes
VX	1PS-VX112C	Vel/Press Sw P45PCA-4	Yes	Yes
VX	1PS-VX114A	Vel/Press Sw J69-364	Yes	Yes
VX	1PS-VX114B	Vel/Press Sw J69-356	Yes	Yes
VX	1PS-VX114C	Vel/Press Sw P45PCA-4	Yes	Yes
VX	1PS-VX116A	Vel/Press Sw	Yes	No
VX	1PS-VX116B	Vel/Press Sw	Yes	No
VX	1PS-VX116C	PwrCntrl/Press Sw	Yes	No
PS	1PS004	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS004(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS005	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS005(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS009	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS009(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS010	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS010(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS016	Valcor/.5 Sol Vlv	Yes	Yes
PS	1PS016(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS017	Valcor/.5" Sol Vlv	Yes	Yes
PS	1PS017(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS022	Valcor/.5" Sol Vlv	Yes	Yes
PS	1PS022(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS023	Valcor/.5" Sol Vlv	Yes	Yes
PS	1PS023(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS031	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS031(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS032	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS032(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS034	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS034(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS035	Valcor/.75" Sol Vlv	Yes	Yes
PS	1PS035(OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS037	Valcor/.75" Sol Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PS	1PS037 (OS)	Conax/7F20-11007-01	Yes	Yes
NB	1PS038	Valcor/.75" Sol Vlv	Yes	Yes
NB	1PS038 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS043A	Valcor/.75" Sol Vlv V526-5980-6	Yes	Yes
PS	1PS043A (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS043B	Valcor/.75" Sol Vlv V526-5980-6	Yes	Yes
PS	1PS043B (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS044A	Valcor/.75" Sol Vlv V526-5980-6	Yes	Yes
PS	1PS044A (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS044B	Valcor/.75" Sol Vlv V526-5980-6	Yes	Yes
PS	1PS044B (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS047	Valcor/.75" Sol Vlv V526-5940-3	Yes	Yes
PS	1PS047 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS048	Valcor/.75" Sol Vlv V526-5940-3	Yes	Yes
PS	1PS048 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS055	Valcor/.5" Sol Vlv V526-5940-7	Yes	Yes
PS	1PS055 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS056	Valcor/.5" Sol Vlv V526-5940-7	Yes	Yes
PS	1PS056 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS069	Valcor/.5" Sol Vlv V526-5940-10	Yes	Yes
PS	1PS069 (OS)	Conax/7F20-11007-01	Yes	Yes
PS	1PS070	Valcor/.5" Sol Vlv V526-5940-10	Yes	Yes
PS	1PS070 (OS)	Conax/7F20-11007-01	Yes	Yes
CM	1PSL-CM177	WhitmanGen/S117G-10H-K12,T-X	Yes	Yes
CM	1PSL-CM178	WhitmanGen/S117G-10H-K12,T-X	Yes	Yes
CM	1PSL-CM246	WhitmanGen/PS117G-10H-K12,TX	Yes	Yes
CM	1PSL-CM247	WhitmanGen/PS117G-10H-K12,TX	Yes	Yes
CM	1PT-CM034 (S)	Conax/7F20-11006-01	Yes	Yes
CM	1PT-CM034*	Rsmt/1153	Yes	Yes
CM	1PT-CM035	Rsmt/1153	Yes	Yes
CM	1PT-CM035 (S)	Conax/7F20-11006-01	Yes	Yes
CM	1PT-CM063 (S)	Conax/7F20-11006-02	Yes	Yes
CM	1PT-CM063*	Rsmt/1153	Yes	Yes
CM	1PT-CM064 (S)	Conax/7F20-11006-02	Yes	Yes
CM	1PT-CM064*	Rsmt/1153	Yes	Yes
CM	1PT-CM081	Rsmt/1153	Yes	Yes
CM	1PT-CM081 (S)	Conax/7F20-11006-02	Yes	Yes
CM	1PT-CM082	Rsmt/1153	Yes	Yes
CM	1PT-CM082 (S)	Conax/7F20-11006-02	Yes	Yes
CM	1PT-CM167	Validyne/AP10-46-1775	Yes	Yes
CM	1PT-CM168	Validyne/AP10-46-1775	Yes	Yes
CM	1PT-CM256	Rsmt/1153	Yes	Yes
IA	1PT-CM256 (S)	Conax/7F20-11006-02	Yes	Yes
CM	1PT-CM257	Rsmt/1153	Yes	Yes
IA	1PT-CM257 (S)	Conax/7F20-11006-02	Yes	Yes
IA	1PT-CM264	Rsmt/1153	Yes	Yes
IA	1PT-CM264 (S)	Conax/7F20-11006-02	Yes	Yes
IA	1PT-CM265	Rsmt/1153	Yes	Yes
IA	1PT-CM265 (S)	Conax/7F20-11006-02	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
FC	1PT-FC081	Rsmt/1153	Yes	Yes
SM	1PT-FC081(S)	Conax/7F20-11006-01	Yes	Yes
FC	1PT-FC109	Rsmt/1153	Yes	Yes
CM	1PT-FC109(S)	Conax/7F20-11006-01	Yes	Yes
IA	1PT-IA078	Rsmt/1153	Yes	Yes
IA	1PT-IA078(S)	Conax/7F20-11006-02	Yes	Yes
IA	1PT-IA079	Rsmt/1153	Yes	Yes
IA	1PT-IA079(S)	Conax/7F20-11006-02	Yes	Yes
IA	1PT-IA080	Rsmt/1153	Yes	Yes
IA	1PT-IA080(S)	Conax/7F20-11006-02	Yes	Yes
IA	1PT-IA081	Rsmt/1153	Yes	Yes
IA	1PT-IA081(S)	Conax/7F20-11006-02	Yes	Yes
SX	1PT-SX028	Rsmt/1153	Yes	Yes
SX	1PT-SX030	Rsmt/1153	Yes	Yes
SX	1PT-SX032	Rsmt/1153	Yes	Yes
CM	1PT-VG145	Rsmt/1153	Yes	Yes
CM	1PT-VG145(S)	Conax/7F20-11006-01	Yes	Yes
CM	1PT-VG147	Rsmt/1153	Yes	Yes
CM	1PT-VG147(S)	Conax/7F20-11006-01	Yes	Yes
VX	1PT-VX112	Rsmt/1153	Yes	Yes
VX	1PT-VX114	Rsmt/1153	Yes	Yes
VX	1PT-VX116	Rsmt/1153	Yes	Yes
FC	1PY-FC081	Rsmt/510 DU	Yes	Yes
FC	1PY-FC109	Rsmt/510 DU	Yes	Yes
SX	1PY-SX028	Rsmt/510 DU	Yes	Yes
SX	1PY-SX030	Rsmt/510 DU	Yes	Yes
SX	1PY-SX032	Rsmt/510 DU	Yes	Yes
VG	1PY-VG145	Lv/48-8115-8174 Xmtr	Yes	Yes
VG	1PY-VG147	Lv/48-8115-8174 Xmtr	Yes	Yes
RA	1RA016A	Dresser/1" SRV	Yes	Yes
RA	1RA016B	Dresser/1" SRV	Yes	Yes
RA	1RA017A	TrgtRck/Press Reg Vlv	Yes	Yes
RA	1RA017B	TrgtRck/Press Reg Vlv	Yes	Yes
CM	1RE-CM059*	Vctrn/Rad Det 877-1	Yes	Yes
CM	1RE-CM060*	Vctrn/Rad Det 877-1	Yes	Yes
CM	1RE-CM061*	Vctrn/Rad Det 877-1	Yes	Yes
CM	1RE-CM062*	Vctrn/Rad Det 877-1	Yes	Yes
PR	1RE-PR001A	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR001B	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR001C	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR001D	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR006A	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR006B	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR006C	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR006D	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR008A	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR008B	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR008C	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR008D	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PR	1RE-PR009A	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR009B	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR009C	Ebrln/Rad Elem SA-11/IB-4HT-CC	Yes	No
PR	1RE-PR009D	Ebrln/Rad Elem SQ-11/IB-4HT-CC	Yes	No
PR	1RE-PR042A	Ebrln/Inst SQ-11Q-IB-4A-HT	Yes	Yes
PR	1RE-PR042B	Ebrln/Inst SQ-11Q-IB-4A-HT	Yes	Yes
PR	1RE-PR042C	Ebrln/Inst SQ-11Q-IB-4A-HT	Yes	Yes
PR	1RE-PR042D	Ebrln/Inst SQ-11Q-IB-4A-HT	Yes	Yes
RE	1RE019(L)	Namco/EA180	Yes	Yes
RE	1RE019(LS)	Conax/7F10-11005-01	Yes	Yes
RE	1RE019(O)	Asco/2068323U	Yes	Yes
RE	1RE019(OS)	Conax/7F20-11001-02	Yes	Yes
RE	1RE019(V)	Fshr/3" AO G1b V1v	Yes	Yes
RE	1RE020(L)	Namco/EA180	Yes	Yes
RE	1RE020(LS)	Conax/7F20-11005-01	Yes	Yes
RE	1RE020(O)	Asco/2068323U	Yes	Yes
RE	1RE020(OS)	Conax/7F20-11001-02	Yes	Yes
RE	1RE020(V)	Fshr/3" AO G1b V1v	Yes	Yes
RE	1RE021(L)	Namco/EA180	Yes	Yes
RE	1RE021(LS)	Conax/7F20-11005-01	Yes	Yes
RE	1RE021(O)	Asco/2068323U	Yes	Yes
RE	1RE021(OS)	Conax/7F20-11001-02	Yes	Yes
RE	1RE021(V)	Fshr/3" AO G1b V1v	Yes	Yes
RE	1RE022(L)	Namco/EA180	Yes	Yes
RE	1RE022(LS)	Conax/7F20-11005-01	Yes	Yes
RE	1RE022(O)	Asco/2068323U	Yes	Yes
RE	1RE022(OS)	Conax/7F20-11001-02	Yes	Yes
RE	1RE022(V)	Fshr/3" AO G1b V1v	Yes	Yes
RF	1RF019(L)	Namco/EA180	Yes	Yes
RF	1RF019(LS)	Conax/7F20-11005-01	Yes	Yes
RF	1RF019(O)	Asco/2068323U	Yes	Yes
RF	1RF019(OS)	Conax/7F20-11001-02	Yes	Yes
RF	1RF019(V)	Fshr/3" AO G1b V1v	Yes	Yes
RF	1RF020(L)	Namco/EA180	Yes	Yes
RF	1RF020(LS)	Conax/7F20-11005-01	Yes	Yes
RF	1RF020(O)	Asco/2068323U	Yes	Yes
RF	1RF020(OS)	Conax/7F20-11001-02	Yes	Yes
RF	1RF020(V)	Fshr/3" AO G1b V1v	Yes	Yes
RF	1RF021(L)	Namco/EA180	Yes	Yes
RF	1RF021(LS)	Conax/7F20-11005-01	Yes	Yes
RF	1RF021(O)	Asco/2068323U	Yes	Yes
RF	1RF021(OS)	Conax/7F20-11001-02	Yes	Yes
RF	1RF021(V)	Fshr/3" AO G1b V1v	Yes	Yes
RF	1RF022(L)	Namco/EA180	Yes	Yes
RF	1RF022(LS)	Conax/7F20-11005-01	Yes	Yes
RF	1RF022(O)	Asco/2068323U	Yes	Yes
RF	1RF022(OS)	Conax/7F20-11001-02	Yes	Yes
RF	1RF022(V)	Fshr/3" AO G1b V1v	Yes	Yes
RG	1RG012MA	Alco/By V1v FA8-13H	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RG	1RG012MB	Alco/By Vlv FAB-13H	Yes	Yes
RG	1RG012MC	Alco/By Vlv FAB-12H	Yes	Yes
RG	1RG06MA	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MB	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MC	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MD	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06ME	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MF	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MG	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MH	Sporlan/Sol Vlv MB25S2	Yes	Yes
RG	1RG06MJ	Sporlan/Sol Vlv MB19S2	Yes	Yes
RG	1RG06MK	Sporlan/Sol Vlv MB19S2	Yes	Yes
CM	1RIX-CM059	Vctrn/RadMon(Rdout) Ind 876A-1	Yes	Yes
CM	1RIX-CM060	Vctrn/RadMon(Rdout) Ind 876A-1	Yes	Yes
CM	1RIX-CM061	Vctrn/RadMon(Rdout) Ind 876A-1	Yes	Yes
CM	1RIX-CM062	Vctrn/RadMon(Rdout) Ind 876A-1	Yes	Yes
PR	1RIX-PR001A	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR001B	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR001C	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR001D	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR006A	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR006B	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR006C	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR006D	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR008A	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR008B	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR008C	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR008D	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR009A	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR009B	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR009C	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR009D	Ebrln/DataAcquistnModle DAM-1	Yes	No
PR	1RIX-PR042A	Ebrln/Dam-1Q	Yes	Yes
PR	1RIX-PR042B	Ebrln/Dam-1Q	Yes	Yes
PR	1RIX-PR042C	Ebrln/Dam-1Q	Yes	Yes
PR	1RIX-PR042D	Ebrln/Dam-1Q	Yes	Yes
CM	1RQ-CM059	Vctrn/Sgnl Isol 879-1	Yes	Yes
CM	1RQ-CM060	Vctrn/Sgnl Isol 879-1	Yes	Yes
CM	1RQ-CM061	Vctrn/Sgnl Isol 879-1	Yes	Yes
CM	1RQ-CM062	Vctrn/Sgnl Isol 879-1	Yes	Yes
RP	1RP01E	PwrCnvPrd/RTF 480-120-15	Yes	Yes
RP	1RP02E	PwrCnvPrd/RTF 480-120-15	Yes	Yes
RR	1RP04E	PwrCnvPrd/RTF 480-120-15	Yes	Yes
RR	1RR01E	Wsths/6900V Swtg	Yes	Yes
RR	1RR01EA	Wsths/SwtgBusRR1A Bkr 75DHP500	Yes	Yes
RR	1RR01EB	Wsths/SwgrBusRR1A Bkr 75DHP500	Yes	Yes
RR	1RR02E	Wsths/6900V Swtg	Yes	Yes
RR	1RR02EA	Wsths/SwtgBusRR2A Bkr 75DHP500	Yes	Yes
RR	1RR02EB	Wsths/SwgrBusRR2A Bkr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
RR	1RR02EC	Wsths/Swgr BusRR2A Bkr	Yes	Yes
RR	1RR03EA	Gld/JL3-B250 Ckt Brk	Yes	Yes
RR	1RR03EB	Gld/JL3-B250 Cir Bkr Cab	Yes	Yes
RR	1RR91EC	Wsths/Swgr Bkr Bus RR1A	No	Yes
IA	1SA029(L)	Namco/EA180	Yes	Yes
IA	1SA029(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1SA029(O)	Asco/2068323U	Yes	Yes
IA	1SA029(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1SA029(V)	Fshr/3" AO G1b Vlv	Yes	Yes
IA	1SA030(L)	Namco/EA180	Yes	Yes
IA	1SA030(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1SA030(O)	Asco/2068323U	Yes	Yes
IA	1SA030(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1SA030(V)	Fshr/3" AO G1b Vlv	Yes	Yes
IA	1SA031(L)	Namco/EA180	Yes	Yes
IA	1SA031(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1SA031(O)	Asco/2068323U	Yes	Yes
IA	1SA031(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1SA031(V)	Fshr/3" AO G1b Vlv	Yes	Yes
IA	1SA032(L)	Namco/EA180	Yes	Yes
IA	1SA032(LS)	Conax/7F20-11005-01	Yes	Yes
IA	1SA032(O)	Asco/2068323U	Yes	Yes
IA	1SA032(OS)	Conax/7F20-11001-02	Yes	Yes
IA	1SA032(V)	Fshr/3" AO G1b Vlv	Yes	Yes
DG	1SE-DG262	S&S/Press Sw STC-4240	Yes	No
SF	1SF001(A)	Lmt/SMB-000-5	Yes	Yes
SF	1SF001(V)	AD/10" 150# Gt Vlv	Yes	Yes
SF	1SF002(A)	Lmt/SMB-000-5	Yes	Yes
SF	1SF002(V)	AD/10" 150# Gt Vlv	Yes	Yes
SF	1SF003(L)	Namco/EA-180	Yes	Yes
SF	1SF003(V)	AD/12" Gt Vlv	Yes	Yes
SF	1SF004(A)	Lmt/SMB-00-10	Yes	Yes
SF	1SF004(V)	AD/12" Gt Vlv	Yes	Yes
DG	1SI-DG146	GE/Speed Ind	Yes	Yes
DG	1SI-DG147	GE/Speed Ind	Yes	Yes
DG	1SI-DG252	GE/50-103111	Yes	Yes
DG	1SI-DG819	GE/180 Vert Rod	Yes	Yes
DG	1SI-DG821	GE/180 Vert Rod	Yes	Yes
IP	1SI-RP009	GE/Elec Ind	Yes	Yes
IP	1SI-RP010	Ge/Div 2 Invrtr Output	Yes	Yes
IP	1SI-RP011	GE/Div 3 Invrtr Output	Yes	Yes
IP	1SI-RP012	GE/Div 4 Invrtr Output	Yes	Yes
SM	1SM001A(A)	Lmt/H3BC-SMB-00/10	Yes	Yes
SM	1SM001A(V)	PosiS1/24" Btrfly Vlv	Yes	Yes
SM	1SM001B(A)	Lmt/H3BC-SMB-00/10	Yes	Yes
SM	1SM001B(V)	PosiS1/24" Btrfly Vlv	Yes	Yes
SM	1SM002A(A)	Lmt/H3BC-SMB-00/10	Yes	Yes
SM	1SM002A(V)	PosiS1/24" Btrfly Vlv	Yes	Yes
SM	1SM002B(A)	Lmt/H3BC-SMB-00/10	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SM	1SM002B(V)	PosiSl/24" Btrfly Vlv	Yes	Yes
SM	1SM003A	Dresser/.75" SRV	Yes	Yes
SM	1SM003B	Dresser/.75" SRV	Yes	Yes
00	1SS-1	Trnsc/Tphd Insul Supt Strct St	Yes	Yes
DG	1SS-DG118	EMD/Speed Sw 8422449	Yes	Yes
DG	1SS-DG119	EMD/Speed Sw 8422449	Yes	Yes
DG	1SS-DG120	EMD/Speed Sw 8422449	Yes	Yes
DG	1SS-DG121	EMD/Speed Sw 8422449	Yes	Yes
DG	1SS-DG254	GE/8422449 Sp Sw	Yes	Yes
SX	1SX003A(A)	Lmt/SMB-00-10/H3BC	Yes	Yes
SX	1SX003A(V)	PosiSl/30"Btrfly Vlv	Yes	Yes
SX	1SX003B(A)	LMT/SMB-00-10/H3BC	Yes	Yes
SX	1SX003B(V)	PosiSl/30"Btrfly Vlv	Yes	Yes
SX	1SX003C(A)	Lmt/SMB-000	Yes	Yes
SX	1SX003C(V)	PosiSl/10" 150# Vlv	Yes	Yes
SX	1SX004A(A)	Lmt/Mtr Oper H3BC SMB-00/10A	Yes	Yes
SX	1SX004A(V)	PosiSl/30" Btrfly Vlv	Yes	Yes
SX	1SX004B(A)	LMT/SMB-00-10/H3BC	Yes	Yes
SX	1SX004B(V)	PosiSl/30" Btrfly Vlv	Yes	Yes
SX	1SX004C(A)	Lmt/H1BC SMB-000	Yes	Yes
SX	1SX004C(V)	PosiSl/10" 150# Vlv	Yes	Yes
SX	1SX005A(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX005B(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX005C(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX006A(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX006B(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX006C(A)	Lmt/H1BC SMB-000	Yes	Yes
SX	1SX006C(V)	PosiSl/8" 150# Btrfly Vlv	Yes	Yes
SX	1SX008A(A)	Lmt/HB2C SMB-000	Yes	Yes
SX	1SX008A(V)	PosiSl/20" Vlv	Yes	Yes
SX	1SX008B(A)	Lmt/H2BC SMB-000	Yes	Yes
SX	1SX008B(V)	PosiSl/20" Vlv	Yes	Yes
SX	1SX008C(A)	Lmt/H1BC SMB-000	Yes	Yes
SX	1SX008C(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX010A(L)	Namco/EA180	Yes	Yes
SX	1SX010A(O)	Asco/206-832-3U	Yes	Yes
SX	1SX010A(V)	Fshr/2" AO G1b Vlv	Yes	Yes
SX	1SX010B(L)	Namco/EA180	Yes	Yes
SX	1SX010B(O)	Asco/206-832-3U	Yes	Yes
SX	1SX010B(V)	Fshr/2" AO G1b Vlv	Yes	Yes
SX	1SX010C(L)	Namco/EA180	Yes	Yes
SX	1SX010C(O)	Asco/206-832-3U	Yes	Yes
SX	1SX010C(V)	Fshr/1.5" AO G1b Vlv	Yes	Yes
SX	1SX011A(A)	Lmt/SMB-000/H1BC	Yes	Yes
SX	1SX011A(V)	PosiSl/16" Btrfly Vlv	Yes	Yes
SX	1SX011B(A)	Lmt/H1BC-SMB-000/2	Yes	Yes
SX	1SX011B(V)	PosiSl/16" Btrfly Vlv	Yes	Yes
SX	1SX012A(A)	Lmt/H1BC SMB-000/2	Yes	Yes
SX	1SX012A(V)	PosiSl/14" Btrfly Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1SX012B(A)	Lmt/H1BC SMB-000/2	Yes	Yes
SX	1SX012B(V)	PosiS1/14" Btrfly Vlv	Yes	Yes
SX	1SX013D(A)	Lmt/Mtr Oper HOBC SMB-000-2	Yes	Yes
SX	1SX013D(V)	Xomox/3"-150#	Yes	Yes
SX	1SX013E(A)	Lmt/SMB-000-2/HOBC	Yes	Yes
SX	1SX013E(V)	Xomox/3"-150#	Yes	Yes
SX	1SX013F(A)	Lmt/Mtr Oper SMB-000-2/HOBC	Yes	Yes
SX	1SX013F(V)	Xomox/2"-150#	Yes	Yes
SX	1SX014A(A)	Lmt/H2BC SMB-000	Yes	Yes
SX	1SX014A(V)	PosiS1/20" Btrfly Vlv	Yes	Yes
SX	1SX014B(A)	Lmt/H2BC SMB-000	Yes	Yes
SX	1SX014B(V)	PosiS1/20" 150# Btrfly Vlv	Yes	Yes
SX	1SX014C(A)	Lmt/H1BC SMB-000	Yes	Yes
SX	1SX014C(V)	PosiS1/8" 150# Btrfly Vlv	Yes	Yes
SX	1SX016A(A)	Lmt/1SMB-000-2	Yes	Yes
SX	1SX016A(V)	AD/2.5" Gt Vlv	Yes	Yes
SX	1SX016B(A)	Lmt/1SMB-000-2	Yes	Yes
SX	1SX016B(V)	AD/2.5" Gt Vlv	Yes	Yes
SX	1SX017A(A)	Lmt/SMB-000-2/H1BC	Yes	Yes
SX	1SX017A(V)	PosiS1/8" Btrfly Vlv	Yes	Yes
SX	1SX017B(A)	Lmt/SMB-000-2/h1bc	Yes	Yes
SX	1SX017B(V)	PosiS1/8" Btrfly Vlv	Yes	Yes
SX	1SX019A(A)	ITT/NH-91	Yes	Yes
SX	1SX019A(V)	Jmsbry/8026 EA Vlv	Yes	Yes
SX	1SX019B(A)	ITT/NH-91	Yes	Yes
SX	1SX019B(V)	Jmsbry/8026 EA Vlv	Yes	Yes
SX	1SX01FA(A)	Adms/LMT/30" Strnr	Yes	Yes
SX	1SX01FB(A)	Adms/LMT/30" Strnr	Yes	Yes
SX	1SX01FC	Adms/8" Strnr	Yes	Yes
SX	1SX01FC(C)	Adms/LMT/8" Strnr	Yes	Yes
SX	1SX01MA	PathBell/6" Exp Joint	Yes	Yes
SX	1SX01MB	PathBell/6" Exp Joint	Yes	Yes
SX	1SX01MC	PathBell/6" Exp Joint	Yes	Yes
SX	1SX01PA(M)	SmsAlls/ANVWS Mtr	Yes	Yes
SX	1SX01PA(P)	BorgWnr/37KXL Pmp	Yes	Yes
SX	1SX01PB(M)	SmsAlls/ANVWS Mtr	Yes	Yes
SX	1SX01PB(P)	BorgWnr/37KXL Pmp	Yes	Yes
SX	1SX01PC(M)	SmsAlls/RGV Mtr	Yes	Yes
SX	1SX01PC(P)	BnghmWlmt/8x14A Pmp	Yes	Yes
SX	1SX020A(A)	Lmt/H1BC SMB-00/2	Yes	Yes
SX	1SX020A(V)	PosiS1/12" Btrfly Vlv	Yes	Yes
SX	1SX020B(A)	Lmt/H1BC SMB-00/2	Yes	Yes
SX	1SX020B(V)	PosiS1/12" Btrfly Vlv	Yes	Yes
SX	1SX023A(L)	Namco/EA180	Yes	Yes
SX	1SX023A(O)	Asco/2068323U	Yes	Yes
SX	1SX023A(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX023A(V)	Fshr/2" AQ G1b Vlv	Yes	Yes
SX	1SX023B(L)	Namco/EA180	Yes	Yes
SX	1SX023B(O)	Asi 2068323U	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1SX023B(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX023B(V)	Fshr/2" AO G1b V1v	Yes	Yes
SX	1SX025A	GrvCrp/V1v Act	Yes	Yes
SX	1SX025A(A)	ITT/NH-91	Yes	Yes
SX	1SX025A(V)	Jmsbry/2" CU V1v	Yes	Yes
SX	1SX025B(A)	ITT/NH-91	Yes	Yes
SX	1SX025B(V)	Jmsbry/2" Ball V1v	Yes	Yes
SX	1SX025C(A)	ITT/NH-91	Yes	Yes
SX	1SX025C(V)	Jmsbry/BWS 2236 V1v	Yes	Yes
SX	1SX027A(L)	Namco/EA180	Yes	Yes
SX	1SX027A(O)	Asco/2068323U	Yes	Yes
SX	1SX027A(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX027A(V)	Fshr/2" AO G1b V1v	Yes	Yes
SX	1SX027B(L)	Namco/EA180	Yes	Yes
SX	1SX027B(O)	Asco/2068323U	Yes	Yes
SX	1SX027B(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX027B(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX027C(L)	Namco/EA180	Yes	Yes
SX	1SX027C(O)	Asco/2068323U	Yes	Yes
SX	1SX027C(OS)	Conax/7F20-11001-02	Yes	Yes
SX	1SX027C(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX029A(L)	Namco/EA180	Yes	Yes
SX	1SX029A(O)	Asco/2068323U	Yes	Yes
SX	1SX029A(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX029A(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX029B(L)	Namco/EA180	Yes	Yes
SX	1SX029B(O)	Asco/2068323U	Yes	Yes
SX	1SX029B(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX029B(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX029C(L)	Namco/EA180	Yes	Yes
SX	1SX029C(O)	Asco/2068323U	Yes	Yes
SX	1SX029C(OS)	Conax/7F20-11001-02	Yes	Yes
SX	1SX029C(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX02MA	PathBell/6" Exp Joint	Yes	Yes
SX	1SX02MB	PathBell/6" Exp Joint	Yes	Yes
SX	1SX02MC	PathBell/6" Exp Joint	Yes	Yes
SX	1SX033(L)	Namco/EA180	Yes	Yes
SX	1SX033(O)	Asco/2068323U	Yes	Yes
SX	1SX033(OS)	Conax/7F20-11001-02	Yes	Yes
SX	1SX033(V)	Fshr/2" AO G1b V1v	Yes	Yes
SX	1SX037(L)	Namco/EA180	Yes	Yes
SX	1SX037(O)	Asco/2068323U	Yes	Yes
SX	1SX037(OS)	Conax/7F20-11001-02	Yes	Yes
SX	1SX037(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX03MA	PathBell/6" Exp Joint	Yes	Yes
SX	1SX03MB	PathBell/6" Exp Joint	Yes	Yes
SX	1SX041A(L)	Namco/EA180	Yes	Yes
SX	1SX041A(O)	Asco/2068323U	Yes	Yes
SX	1SX041A(OS)	Conax/7F20-11001-03	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1SX041A(V)	Fshr/2" AQ G1b Vlv	Yes	Yes
SX	1SX041B(L)	Namco/EA1B0	Yes	Yes
SX	1SX041B(O)	Asco/2068323U	Yes	Yes
SX	1SX041B(OS)	Conax/7F20-11001-03	Yes	Yes
SX	1SX041B(V)	Fshr/2" AQ G1b Vlv	Yes	Yes
SX	1SX04MA	PathBell/6" Exp Joint	Yes	Yes
SX	1SX04MB	PathBell/6" Exp Joint	Yes	Yes
SX	1SX062A(A)	Lmt/H1BC SMB-000/2	Yes	Yes
SX	1SX062A(V)	PosiSl/14" 150# Btrfly Vlv	Yes	Yes
SX	1SX062B(A)	Lmt/H1BC SMB-000/2	Yes	Yes
SX	1SX062B(V)	PosiSl/14" Btrfly Vlv	Yes	Yes
SX	1SX063A(A)	Lmt/H1BC-SMC-04-3	Yes	Yes
SX	1SX063A(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX063B(A)	Lmt/H1BC-SMC-04-3	Yes	Yes
SX	1SX063B(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX064A(V)	PosiSl/8" Vlv	Yes	Yes
SX	1SX064B(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX065A(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX065B(V)	PosiSl/8" Btrfly Vlv	Yes	Yes
SX	1SX071A(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX071A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX071B(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX071B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX073A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX073A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX073B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX073B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX074A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX074A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX074B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX074B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX076A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX076A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX076B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX076B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX082A(A)	Lmt/SMB-000-0	Yes	Yes
SX	1SX082A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX082B(A)	Lmt/SMB-000-0	Yes	Yes
SX	1SX082B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX088A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX088A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX088B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX088B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX089A(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX089A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX089B(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX089B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX095A(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX095A(V)	AD/2.5" Gt Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1SX095B(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX095B(V)	AD/2.5" Gt Vlv	Yes	Yes
SX	1SX096A(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX096A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX096B(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX096B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX097A(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX097A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX097B(A)	Lmt/SMB-000-2	Yes	Yes
SX	1SX097B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX105A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX105A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX105B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX105B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX107A(A)	Lmt/SMB-000	Yes	Yes
SX	1SX107A(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX107B(A)	Lmt/SMB-000	Yes	Yes
SX	1SX107B(V)	AD/3" Gt Vlv	Yes	Yes
SX	1SX11J	RPAAdams/Inst Pnl	Yes	Yes
SX	1SX12J	RPAAdams/Inst Pnl	Yes	Yes
SX	1SX13J	RPAAdams/Inst Pnl	Yes	Yes
SX	1SX149	Dresser/.75" SRV	Yes	Yes
SX	1SX150	Dresser/.75" SRV	Yes	Yes
SX	1SX151A	Dresser/.75" SRV	Yes	Yes
SX	1SX151B	Dresser/.75" SRV	Yes	Yes
SX	1SX151C	Dresser/.75" SRV	Yes	Yes
SX	1SX152A	Dresser/.75" SRV	Yes	Yes
SX	1SX152B	Dresser/.75" SRV	Yes	Yes
SX	1SX153A	Dresser/.75" SRV	Yes	Yes
SX	1SX153B	Dresser/.75" SRV	Yes	Yes
SX	1SX154A	Dresser/.75" SRV	Yes	Yes
SX	1SX154B	Dresser/.75" SRV	Yes	Yes
SX	1SX154C	Dresser/.75" SRV	Yes	Yes
SX	1SX155A	Dresser/.75" SRV	Yes	Yes
SX	1SX155B	Dresser/.75" SRV	Yes	Yes
SX	1SX155C	Dresser/.75" SRV	Yes	Yes
SX	1SX156A	Dresser/.75" SRV	Yes	Yes
SX	1SX156B	Dresser/.75" SRV	Yes	Yes
SX	1SX157A	Dresser/.75" SRV	Yes	Yes
SX	1SX157B	Dresser/.75" SRV	Yes	Yes
SX	1SX169A	Dresser/.75" SRV	Yes	Yes
SX	1SX169B	Dresser/.75" SRV	Yes	Yes
SX	1SX169C	Dresser/.75" SRV	Yes	Yes
SX	1SX170A	Dresser/.75" SRV	Yes	Yes
SX	1SX170B	Dresser/.75" SRV	Yes	Yes
SX	1SX173A(A)	Lmt/SMB-000-5	Yes	Yes
SX	1SX173A(V)	AD/10" Gt Vlv	Yes	Yes
SX	1SX173B(A)	Lmt/SMB-000-5	Yes	Yes
SX	1SX173B(V)	AD/10" Gt Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1SX181A(L)	Namco/EA180	Yes	Yes
SX	1SX181A(O)	Asco/2068323U	Yes	Yes
SX	1SX181A(OS)	Conax/7F20-11001-03	Yes	Yes
SX	1SX181A(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX181B(L)	Namco/EA180	Yes	Yes
SX	1SX181B(O)	Asco/2068323U	Yes	Yes
SX	1SX181B(OS)	Conax/7F20-11001-03	Yes	Yes
SX	1SX181B(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX185A(L)	Namco/EA180	Yes	Yes
SX	1SX185A(O)	Asco/2068323U	Yes	Yes
SX	1SX185A(OS)	Conax/7F20-11001-03	Yes	Yes
SX	1SX185A(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX185B(L)	Namco/EA180	Yes	Yes
SX	1SX185B(O)	Asco/2068323U	Yes	Yes
SX	1SX185B(OS)	Conax/7F20-11001-03	Yes	Yes
SX	1SX185B(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX189(L)	Namco/EA180	Yes	Yes
SX	1SX189(O)	Asco/2068323U	Yes	Yes
SX	1SX189(V)	Fshr/2.5" AO G1b V1v	Yes	Yes
SX	1SX193A(L)	Namco/EA-180	Yes	No
SX	1SX193A(O)	Asco/2068323U	Yes	Yes
SX	1SX193A(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX193B(L)	Namco/EA-180	Yes	Yes
SX	1SX193B(O)	Asco/2068323U	Yes	Yes
SX	1SX193B(V)	Fshr/1.5" AO G1b V1v	Yes	Yes
SX	1SX197(L)	Namco/EA180	Yes	Yes
SX	1SX197(O)	Asco/2068323U	Yes	Yes
SX	1SX197(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX197(V)	Fshr/2" AO G1b V1v	Yes	Yes
SX	1SX200A	Dresser/.75" SRV	Yes	Yes
SX	1SX200B	Dresser/.75" SRV	Yes	Yes
SX	1SX201A	Dresser/.75" SRV	Yes	Yes
SX	1SX201B	Dresser/.75" SRV	Yes	Yes
SX	1SX202A	Dresser/.75" SRV	Yes	Yes
SX	1SX202B	Dresser/.75" SRV	Yes	Yes
SX	1SX203	Dresser/.75" SRV	Yes	Yes
SX	1SX204	Dresser/.75" SRV	Yes	Yes
SX	1SX207	Dresser/.75" SRV	Yes	Yes
SX	1SX208A	Dresser/4" SRV	Yes	Yes
SX	1SX208B	Dresser/4" SRV	Yes	Yes
SX	1SX209(L)	Namco/EA180	Yes	No
SX	1SX209(O)	Asco/2068323U	Yes	Yes
SX	1SX209(OS)	Conax/7F20-11001-01	Yes	Yes
SX	1SX209(V)	Fshr/1.5" G1b V1v	Yes	Yes
DG	1SY-DG100	Gld/Speed Xducers	Yes	No
DG	1SY-DG101	Gld/Speed Xducers	Yes	No
DG	1SY-DG819	Wsths/V-2	Yes	Yes
DG	1SY-DG821	Wsths/V-2	Yes	Yes
CM	1TA-CM141	Sentry/Airm Log Card 2-00057A	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM EQUIPMENT NUMBER		MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
=====				
CM	1TA-CM142	Sentry/Alrm Log Card	Yes	Yes
PR	1TA-PR051	Senty/2-00857B	Yes	Yes
CM	1TC-CM121	Bendix/3521265-001	Yes	Yes
CM	1TC-CM122	Bendix/Cntlr 3521265-001	Yes	Yes
CM	1TC-CM143	Sentry/2-00945A	Yes	Yes
CM	1TC-CM144	Sentry/2-00945A	Yes	Yes
CM	1TC-CM145	Sentry/2-00945A	Yes	Yes
CM	1TC-CM146	Sentry/2-00945A	Yes	Yes
CM	1TC-CM147	Sentry/2-00945A	Yes	Yes
CM	1TC-CM148	Sentry/1-00945A	Yes	Yes
CM	1TC-CM151	Sentry/2-00945A	Yes	Yes
CM	1TC-CM152	Sentry/2-00945A	Yes	Yes
CM	1TC-CM153	Sentry/2-00945A	Yes	Yes
CM	1TC-CM154	Sentry/2-00945A	Yes	Yes
CM	1TC-CM155	Sentry/2-00945A	Yes	Yes
CM	1TC-CM156	Sentry/2-00945A	Yes	Yes
CM	1TC-CM157	Sentry/2-00945A	Yes	Yes
CM	1TC-CM158	Sentry/2-00945A	Yes	Yes
CM	1TC-CM159	Sentry/2-00945A	Yes	Yes
CM	1TC-CM160	Sentry/2-00945A	Yes	Yes
CM	1TC-CM242	Sentry/2-00945A	Yes	Yes
CM	1TC-CM243	Sentry/2-00945A	Yes	Yes
CM	1TC-CM248	Sentry/2-00945A	Yes	Yes
CM	1TC-CM249	Sentry/2-00945A	Yes	Yes
PR	1TC-PR044	Sentry/2-00945A	Yes	Yes
PR	1TC-PR045	Sentry/2-00945A	Yes	Yes
PR	1TC-PR046	Sentry/2-00945A	Yes	Yes
PR	1TC-PR047	Sentry/2-00945A	Yes	Yes
CM	1TE-CM001	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM002*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM003	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM004	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM005*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM006*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM007	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM008	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM009*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM010*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM011	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM012	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM013*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM014*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM015*	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM016	Wd/TE-611-1BD-A-6-C-66-A2-0	Yes	Yes
CM	1TE-CM051*	Wd/RTD-611-1B-A-3-C-3015-A2-0	Yes	Yes
CM	1TE-CM052*	Wd/RTD-611-1B-A-3-C-3015-A2-0	Yes	Yes
CM	1TE-CM053*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM054*	Wd/RTD-611-1B-A-3-C-3015-A2-0	Yes	Yes
CM	1TE-CM065*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1TE-CM066*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM067*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM068*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM069*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM070*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM071*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	Yes
CM	1TE-CM072*	Wd/RTD-611D-1B-A-3-C-3015-A20	Yes	No
CM	1TE-CM119	Bendix/	Yes	Yes
CM	1TE-CM120	Bendix/	Yes	Yes
CM	1TE-CM129	Bendix/	Yes	Yes
CM	1TE-CM130	Bendix/	Yes	Yes
CM	1TE-CM143	CGS/8E4S4-6UT-5ES20KK-48	Yes	Yes
CM	1TE-CM144	CGS/8E4S4-6UT-5ES20KK-48	Yes	Yes
CM	1TE-CM145	CGS/8E4S4-6UT-5ES20KK-48	Yes	Yes
CM	1TE-CM146	CGS/8E4S4-6UT-5ES20KK-48	Yes	Yes
CM	1TE-CM147	CGS/8E4S4-6UT-5ES20KK-48	Yes	Yes
CM	1TE-CM148	CGS/8E4S4-6UT-53S20KK-48	Yes	Yes
CM	1TE-CM151	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM152	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM153	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM154	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM155	Wd/TC-N9010D-E-U-48	Yes	No
CM	1TE-CM156	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM157	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM158	Wd/TC-N9010D-E-U-48	Yes	Yes
CM	1TE-CM159	Nanmac/AB-9X3-E	Yes	Yes
CM	1TE-CM160	Nanmac/AB-9X3-E	Yes	Yes
CM	1TE-CM242	CGS/8E454-6UT-SE520KK-48	Yes	Yes
CM	1TE-CM243	CGS/8E454-6UT-SE520KK-48	Yes	Yes
CM	1TE-CM248	Namco/AB-9X3-E	No	No
CM	1TE-CM249	Namco/AB-9X3-E	No	No
CM	1TE-CM266	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM267	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM268	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM269	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM270	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM271	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM272	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM273	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM285	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM287	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM288	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM289	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM290	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM291	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM292	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM293	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM294	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM295	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1TE-CM296	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM297	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM298	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM298	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM299	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM300	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM301	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM302	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM304	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM305	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM306	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM307	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM308	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM309	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM310	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM311	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM312	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM313	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM314	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM315	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM316	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM317	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM318	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM319	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM320	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM321	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM322	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM323	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM324	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM325	Wd/RTD-611D-1B-A-6-C-2-A2-0	Yes	Yes
CM	1TE-CM328*	Wd/RTD-611-1B-A-3-C-346.8-A2-0	Yes	Yes
CM	1TE-CM329*	Wd/RTD-611-1B-A-3-C-346.8-A2-0	Yes	Yes
CM	1TE-CM330*	Wd/RTD-611-1B-A-3-C-346.8-A2-0	Yes	Yes
CM	1TE-CM331*	Wd/RTD-611-1B-A-3-C-346.8-A2-0	Yes	Yes
HG	1TE-HG041	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG042A	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG042B	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG043A	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG043B	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG044A	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG044B	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG045A	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG045B	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG046A	Semco/Temp Elem Type K	Yes	Yes
HG	1TE-HG046B	Semco/Temp Elem Type K	Yes	Yes
PR	1TE-PR044	Wd/Thermocpl	Yes	Yes
PR	1TE-PR045	Wd/Thermocpl	Yes	Yes
PR	1TE-PR046	Wd/Thermocpl	Yes	Yes
PR	1TE-PR047	Wd/Thermocpl	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VD	1TE-VD001	Minco/S8804Z10	Yes	Yes
VD	1TE-VD002	Minco/S8894Z10	No	Yes
VD	1TE-VD003	Minco/S8804Z10	Yes	Yes
VD	1TE-VD007	MCCPwrs/379-1668 RTD	Yes	Yes
VD	1TE-VD008	MCCPwrs/379-1668 RTD	Yes	Yes
VD	1TE-VD009	MCCPwrs/379-1668 RTD	Yes	Yes
VH	1TE-VH001	MCCPwrs/379-1668 RTD	Yes	Yes
VH	1TE-VH002	MCCPwrs/379-1668 RTD	Yes	Yes
VH	1TE-VH003	MCCPwrs/379-1668 RTD	Yes	Yes
VX	1TE-VX001	MCCPwrs/379-1668 RTD	Yes	Yes
VX	1TE-VX002	MCCPwrs/379-1668 RTD	Yes	Yes
VX	1TE-VX003	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY001	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY002	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY003	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY004	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY005	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY006	MCCPwrs/379-1668 RTD	Yes	Yes
VY	1TE-VY007	MCCPwrs/379-1668 RTD	Yes	Yes
CM	1TEW-CM320	Weed/Thermowell	Yes	Yes
CM	1TEW-CM329	weed/Thermowell	Yes	Yes
CM	1TEW-CM331	Weed/Thermowell	Yes	Yes
CM	1TEW-CM338	Weed/Thermowell	Yes	Yes
CM	1TI-CM083	Ashcroft/20CI60R040	Yes	Yes
CM	1TI-CM084	Ashcroft/20CI60R040	Yes	Yes
CM	1TI-CM244	Ashcroft/20CI60R040	Yes	Yes
CM	1TI-CM245	Ashcroft/20CI60R040	Yes	Yes
DG	1TI-DG181	Marsh/DC 1C Fuel Temp	Yes	No
VR	1TI-VR040	GE/180 Vert Ind	Yes	Yes
HG	1TIC-HG044	Authena Cont/Temp Ind Sw	Yes	Yes
VD	1TIC-VD001	Lv/54-838-8134,39,73,74,87	Yes	Yes
VD	1TIC-VD002	Lv/54-838-8134,39,73,74,87	Yes	Yes
VD	1TIC-VD003	Lv/54-838-8134,39,73,74,87	Yes	Yes
AP	1TIS-AP270	Q1trl/WndTmpInd 104-041-01-277	Yes	Yes
AP	1TIS-AP271	Q1trl/WndTmpInd 104-041-01-277	Yes	Yes
AP	1TIS-AP272	Q1trl/WndTmpInd 104-041-01-277	Yes	Yes
AP	1TIS-AP273	Q1trl/WndTmpInd 104-041-01-277	Yes	Yes
AP	1TIS-AP290	Q1trl/104-041-10	No	No
AP	1TIS-AP291	Q1trl/104-041-10	No	No
AP	1TIS-AP293	Q1trl/104-041-10	No	No
AP	1TIS-AP294	Q1trl/104-041-10	No	No
HG	1TIS-HG043	Authena Cont/Temp Ind Sw	Yes	Yes
HG	1TIS-HG045	Moore Ind/Temp Sw Typ 111	Yes	Yes
HG	1TIS-HG046	Authena Cont/Temp Ind Sw	Yes	Yes
VX	1TIS-VX120	UntdElec/802PE-7BS	Yes	Yes
VX	1TIS-VX122	UntdElec/802PE-7BS	Yes	Yes
VX	1TIS-VX124	UntdElec/802PE-7BS	Yes	Yes
VD	1TIT-VD007	Lv/54-838-8114,39,74	Yes	Yes
VD	1TIT-VD008	Lv/4-838-8114,39,74	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
VD	1TIT-VD009	Lv/54-838-8114,39.74	Yes	Yes
VH	1TIT-VH001	Lv/54838-8139,14,74	Yes	Yes
VH	1TIT-VH002	Lv/54838-8139,14,74	Yes	Yes
VH	1TIT-VH003	Lv/54838-8139,14,74	Yes	Yes
VX	1TIT-VX001	Lv/54838-8139,14,74	Yes	Yes
VX	1TIT-VX002	Lv/54-838-8114-8139-8174	Yes	Yes
VX	1TIT-VX003	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY001	Lv/54-836-8114-8139-8174	Yes	Yes
VY	1TIT-VY002	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY003	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY004	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY005	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY006	Lv/54-838-8114-8139-8174	Yes	Yes
VY	1TIT-VY007	Lv/54-838-8114-8139-8174	Yes	Yes
CM	1TR-CM017	TrWstr/M11E	Yes	Yes
CM	1TR-CM018	TrWstr/M11E	Yes	Yes
CM	1TR-CM326	Wstrncs/M11E Temp Rec	Yes	Yes
CM	1TR-CM327	Wstrncs/M11E Temp Rec	Yes	Yes
CM	1TR-CM334*	TracorWestronics/S4N	Yes	Yes
CM	1TR-CM335*	TracorWestronics/S4N	Yes	Yes
DG	1TS-DG011A	SQ-D/Temp Sw 9025-BCW-42	Yes	Yes
DG	1TS-DG012A	SQ-D/Temp Sw 9025-BCW-42	Yes	Yes
DG	1TS-DG013A	SQ-D/Temp Sw 9025-BCW-42	Yes	Yes
DG	1TS-DG014A	SQ-D/Temp Sw 9025-BCW-42	Yes	Yes
DG	1TS-DG195	EMD/8447100	Yes	Yes
DG	1TS-DG196	SQ-D/902W-BCW-35	Yes	Yes
DG	1TS-DG255	EMD/8398627	Yes	Yes
HG	1TS-HG041	Moore Ind/Temp Sw Typ 111	Yes	Yes
HG	1TS-HG042	Moore Ind/Temp Sw Typ 112	Yes	Yes
VA	1TS-VA001	UE/Temp Sw C302-103-152	Yes	Yes
VH	1TS-VH004	UntdElec/C302DG-103	Yes	Yes
VH	1TS-VH005	UntdElec/C302DG-103	Yes	Yes
VH	1TS-VH006	UntdElec/C302DG-103	Yes	Yes
VY	1TS-VY010	UE/Temp Sw C302DG-103	Yes	Yes
VY	1TS-VY011	UE/Temp Sw C302DG-103	Yes	Yes
VY	1TS-VY012	UE/Temp Sw	Yes	Yes
VY	1TS-VY013	UE/Temp Sw	Yes	Yes
VY	1TS-VY014	UE/Temp Sw	Yes	Yes
VY	1TS-VY015	UE/Temp Sw	Yes	Yes
VY	1TS-VY016	UE/Temp Sw	Yes	Yes
VY	1TS-VY017	UE/Temp Sw	Yes	Yes
HG	1TSL-HG044	Moore Ind/Temp Sw Typ 112	Yes	Yes
CM	1TY-CM001	Weed/4000R	Yes	Yes
CM	1TY-CM002	Weed/4000R	Yes	Yes
CM	1TY-CM003	Weed/4000R	Yes	Yes
CM	1TY-CM004	Weed/4000R	Yes	Yes
CM	1TY-CM005	Weed/4000R	Yes	Yes
CM	1TY-CM006	Weed/4000R	Yes	Yes
CM	1TY-CM007	Weed/4000R	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1TY-CM008	Weed/4000R	Yes	Yes
CM	1TY-CM009	Weed/4000R	Yes	Yes
CM	1TY-CM010	Weed/4000R	Yes	Yes
CM	1TY-CM011	Weed/4000R	Yes	Yes
CM	1TY-CM012	Weed/4000R	Yes	Yes
CM	1TY-CM013	Weed/4000R	Yes	Yes
CM	1TY-CM014	Weed/4000R	Yes	Yes
CM	1TY-CM015	Weed/4000R	Yes	Yes
CM	1TY-CM016	Weed/4000R	Yes	Yes
CM	1TY-CM051	Wd/Sig Conv 4000R	Yes	Yes
CM	1TY-CM052	Wd/Sig Conv 4000R	Yes	Yes
CM	1TY-CM053	Wd/Sig Conv 4000R	Yes	Yes
CM	1TY-CM054	Wd/Sig Conv 4000R	Yes	Yes
CM	1TY-CM252	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM253	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM254	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM255	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM258	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM259	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM332*	Trnsmtn/650T-64-65	Yes	Yes
CM	1TY-CM333*	Trnsmtn/650T-64-65	Yes	Yes
VD	1TY-VD007A	Trnsmtn/W221A-20-243-247	Yes	Yes
VD	1TY-VD007B	Trnsmtn/W221A-20-243-247	Yes	Yes
VD	1TY-VD008A	Trnsmtn/W221A-20-243-247	Yes	Yes
VD	1TY-VD008B	Trnsmtn/W221A-20-243-247	Yes	Yes
VD	1TY-VD009A	Trnsmtn/W221A-20-243-247	Yes	Yes
VD	1TY-VD009B	Trnsmtn/W221A-20-243-247	Yes	Yes
VH	1TY-VH001	Trnsmtn/W221A-20-243	Yes	Yes
VH	1TY-VH002	Trnsmtn/W221A-20-243	Yes	Yes
VH	1TY-VH003	Trnsmtn/W221A-20-243	Yes	Yes
VX	1TY-VX001	Trnsmtn/W221A-20-243	Yes	Yes
VX	1TY-VX002	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VX	1TY-VX003	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY001	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY002	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY003	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY004	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY005	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY006	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VY	1TY-VY007	Xmtn/W221A-20-243 Temp Al Rly	Yes	Yes
VD	1TZ-VD001A	ITT/NH-91 Act	Yes	Yes
VD	1TZ-VD001B	ITT/NH-91 Act	Yes	Yes
VD	1TZ-VD001C	ITT/NH-95 Act	Yes	Yes
VD	1TZ-VD002A	ITT/NH-95 Act	Yes	Yes
VD	1TZ-VD002B	ITT/NH-95 Act	Yes	Yes
VD	1TZ-VD002C	ITT/NH-95 Act	Yes	Yes
VD	1TZ-VD003A	ITT/NH-91 Act	Yes	Yes
VD	1TZ-VD003B	ITT/NH-91 Act	Yes	Yes
VD	1TZ-VD003C	ITT/NH-95 Act	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
AP	1UAY-AP567A	Agst/GPIC 750	Yes	Yes
AP	1UAY-AP567B	Agst/GPIC 750	Yes	Yes
CA	1UAY-CA501A	Agst/Aux Rly	Yes	Yes
CC	1UAY-CC516A	GE/HFA Rly	Yes	No
CC	1UAY-CC516B	GE/HFA Rly	Yes	No
CC	1UAY-CC516C	GE/HFA Rly	Yes	No
CC	1UAY-CC516E	GE/HFA Rly	Yes	No
CC	1UAY-CC516F	GE/HFA Rly	Yes	No
CC	1UAY-CC516G	GE/HFA Rly	Yes	No
CC	1UAY-CC516H	GE/HFA Rly	Yes	No
CC	1UAY-CC516H1	Agst/GPI750	No	Yes
CC	1UAY-CC516J	GE/HFA Rly	Yes	No
CC	1UAY-CC516J1	Agst/GPI1750	No	Yes
CY	1UAY-CY505A	GE/HFA Rly	Yes	No
CY	1UAY-CY505B	GE/HFA Rly	Yes	No
CY	1UAY-CY505D	Agst/GPI750	Yes	Yes
FC	1UAY-FC501A	Agst/7014E	Yes	Yes
FC	1UAY-FC502A	Agst/7014E	Yes	Yes
FC	1UAY-FC513A	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513B	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513C	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513D	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513E	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513F	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513G	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513H	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513J	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513K	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513L	Agst/GPIC750	Yes	Yes
FC	1UAY-FC513M	Agst/GPIC750	Yes	Yes
IA	1UAY-IA505A	Agst/GPIC750	Yes	Yes
IA	1UAY-IA505B	Agst/GPIC750	Yes	Yes
IA	1UAY-IA505C	Agst/GPIC750	Yes	Yes
IA	1UAY-IA505D	Agst/GPIC750	Yes	Yes
LD	1UAY-LD506A	Agst/GPIC750	Yes	Yes
LD	1UAY-LD506B	Agst/GPIC750	Yes	Yes
LD	1UAY-LD506C	Agst/GPIC750	Yes	Yes
RE	1UAY-RE505C	GE/HFA Rly	Yes	No
RE	1UAY-RE506C	GE/HFA Rly	Yes	No
RF	1UAY-RF508C	GE/HFA Rly	Yes	No
RF	1UAY-RF508F	GE/HFA Rly	Yes	No
RF	1UAY-RF509C	GE/HFA Rly	Yes	No
SA	1UAY-SA508A	Agst/GPIC750	Yes	Yes
SA	1UAY-SA508B	Agst/GPIC750	Yes	Yes
SM	1UAY-SM505	Agst/7014AH	No	No
SX	1UAY-SX501A	GE/HFA Rly	Yes	No
SX	1UAY-SX501B	GE/HFA Rly	Yes	No
SX	1UAY-SX502A	GE/HFA Rly	Yes	No
SX	1UAY-SX502B	GE/HFA Rly	Yes	No

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
SX	1UAY-SX503A	GE/HFA R1y	Yes	No
SX	1UAY-SX528A	GE/HFA R1y	Yes	No
SX	1UAY-SX528B	GE/HFA R1y	Yes	No
SX	1UAY-SX528C	GE/HFA R1y	Yes	No
SX	1UAY-SX528D	GE/HFA R1y	Yes	No
SX	1UAY-SX529A	GE/HFA R1y	Yes	No
SX	1UAY-SX529B	GE/HFA R1y	Yes	No
SX	1UAY-SX529C	GE/HFA R1y	Yes	No
SX	1UAY-SX529D	GE/HFA R1y	Yes	No
SX	1UAY-SX530A	GE/HFA R1y	Yes	No
D	1UAY-VD507A	Agst/GPIC750	Yes	Yes
VD	1UAY-VD507B	Agst/GPIC750	Yes	Yes
VD	1UAY-VD507C	Agst/GPIC750	Yes	Yes
VD	1UAY-VD507D	Agst/GPIC750	Yes	Yes
VD	1UAY-VD507E	Agst/7014E	Yes	Yes
VD	1UAY-VD507F	Agst/7014E	Yes	Yes
VD	1UAY-VD507K	Agst/GPIC750	Yes	Yes
VD	1UAY-VD507L	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508A	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508B	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508C	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508D	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508E	Agst/7014AE	Yes	Yes
VD	1UAY-VD508F	Agst/7014AE	Yes	Yes
VD	1UAY-VD508G	Agst/GPIC750	Yes	Yes
VD	1UAY-VD508H	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509A	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509B	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509C	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509D	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509E	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509F	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509G	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509H	Agst/GPIC750	Yes	Yes
VD	1UAY-VD509J	Agst/GPIC750	Yes	Yes
VF	1UAY-VF503A	Agst/GPIC750	Yes	Yes
VF	1UAY-VF503B	Agst/GPIC750	Yes	Yes
VF	1UAY-VF503C	Agst/GPIC750	Yes	Yes
VF	1UAY-VF503D	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507A	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507B	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507C	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507D	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507E	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507F	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507G	Agst/GPIC750	Yes	Yes
VF	1UAY-VG507H	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508B	Agst/GPIC750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	1UAY-VG508C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508E	Agst/7024AE	Yes	Yes
VG	1UAY-VG508F	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508G	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508H	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508J	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508K	Agst/GPIC750	Yes	Yes
VG	1UAY-VG508L	Agst/GPIC750	Yes	Yes
VG	1UAY-VG509A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG509B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG509C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG509D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG509E	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510E	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510F	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510G	Agst/GPIC750	Yes	Yes
VG	1UAY-VG510H	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511E	Agst/7014AE	Yes	Yes
VG	1UAY-VG511F	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511G	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511H	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511J	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511K	Agst/GPIC750	Yes	Yes
VG	1UAY-VG511L	Agst/GPIC750	Yes	Yes
VG	1UAY-VG512A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG512B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG512C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG512D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG512E	Agst/GPIC750	Yes	Yes
VG	1UAY-VG514A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG514B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG514C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG514D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG514E	Agst/GPIC750	Yes	Yes
VG	1UAY-VG515A	Agst/GPIC750	Yes	Yes
VG	1UAY-VG515B	Agst/GPIC750	Yes	Yes
VG	1UAY-VG515C	Agst/GPIC750	Yes	Yes
VG	1UAY-VG515D	Agst/GPIC750	Yes	Yes
VG	1UAY-VG515E	Agst/GPIC750	Yes	Yes
VP	1UAY-VP511A	Agst/GPIC750	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VP	1UAY-VP511B	Agst/GP1C750	Yes	Yes
VP	1UAY-VP511C	Agst/GP1C750	Yes	Yes
VP	1UAY-VP511D	Agst/GP1C750	Yes	Yes
VP	1UAY-VP511E	Agst/GP1C750	Yes	Yes
VP	1UAY-VP511F	Agst/GP1C750	Yes	Yes
VP	1UAY-VP511G	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512A	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512B	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512C	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512D	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512E	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512F	Agst/GP1C750	Yes	Yes
VP	1UAY-VP512G	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503A	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503B	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503C	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503D	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503E	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503G	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503H	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503J	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ503K	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505A	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505B	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505C	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505D	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505E	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505F	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505G	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505H	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505I	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505J	Agst/GP1C750	Yes	Yes
VQ	1UAY-VQ505K	Agst/GP1C750	Yes	Yes
VR	1UAY-VR507A	Agst/GP1C750	Yes	Yes
VR	1UAY-VR507B	Agst/GP1C750	Yes	Yes
VX	1UAY-VX507A	Agst/GP1C750	Yes	Yes
VX	1UAY-VX508A	Agst/GP1C750	Yes	Yes
VX	1UAY-VX509A	Agst/GP1C750	Yes	Yes
AP	1UO-AP509A	GE/Opt Isol	Yes	Yes
AP	1UO-AP509B	GE/Opt Isol	Yes	Yes
AP	1UO-AP509C	GE/Opt Isol	Yes	Yes
AP	1UO-AP509D	GE/Opt Isol	Yes	Yes
AP	1UO-AP509E	GE/Opt Isol	Yes	Yes
AP	1UO-AP510A	GE/Opt Isol	Yes	Yes
AP	1UO-AP510B	GE/Opt Isol	Yes	Yes
AP	1UO-AP510C	GE/Opt Isol	Yes	Yes
AP	1UO-AP511A	GE/Opt Isol	Yes	Yes
AP	1UO-AP511B	GE/Opt Isol	Yes	Yes
AP	1UO-AP511C	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFICATION	
=====				
AP	1U0-AP511D	GE/Opt Isol	Yes	Yes
AP	1U0-AP511E	GE/Opt Isol	Yes	Yes
AP	1U0-AP512A	GE/Opt Isol	Yes	Yes
AP	1U0-AP512B	GE/Opt Isol	Yes	Yes
AP	1U0-AP512C	GE/Opt Isol	Yes	Yes
AP	1U0-AP513A	GE/Opt Isol	Yes	Yes
AP	1U0-AP513B	GE/Opt Isol	Yes	Yes
AP	1U0-AP513C	GE/Opt Isol	Yes	Yes
AP	1U0-AP514A	GE/Opt Isol	Yes	Yes
AP	1U0-AP514B	GE/Opt Isol	Yes	Yes
AP	1U0-AP514C	GE/Opt Isol	Yes	Yes
AP	1U0-AP523A	GE/Opt Isol	Yes	Yes
AP	1U0-AP523B	GE/Opt Isol	Yes	Yes
AP	1U0-AP524A	GE/Opt Isol	Yes	Yes
AP	1U0-AP524B	GE/Opt Isol	Yes	Yes
AP	1U0-AP541A	GE/Opt Isol	Yes	Yes
AP	1U0-AP541B	GE/Opt Isol	Yes	Yes
AP	1U0-AP541C	GE/Opt Isol	Yes	Yes
AP	1U0-AP541D	GE/Opt Isol	Yes	Yes
AP	1U0-AP541E	GE/Opt Isol	Yes	Yes
AP	1U0-AP541F	GE/Opt Isol	Yes	Yes
AP	1U0-AP542A	GE/Opt Isol	Yes	Yes
AP	1U0-AP542B	GE/Opt Isol	Yes	Yes
AP	1U0-AP542C	GE/Opt Isol	Yes	Yes
AP	1U0-AP542D	GE/Opt Isol	Yes	Yes
AP	1U0-AP542E	GE/Opt Isol	Yes	Yes
AP	1U0-AP542F	GE/Opt Isol	Yes	Yes
AP	1U0-AP596A	GE/Opt Isol	No	Yes
AP	1U0-AP596B	GE/Opt Isol	No	Yes
AP	1U0-AP596C	GE/Opt Isol	No	Yes
AP	1U0-AP596D	GE/Opt Isol	No	Yes
AP	1U0-AP596E	GE/Opt Isol	No	Yes
AP	1U0-AP596F	GE/Opt Isol	No	Yes
AP	1U0-AP611A	GE/Opt Isol	Yes	Yes
AP	1U0-AP611B	GE/Opt Isol	Yes	Yes
AP	1U0-AP611C	GE/Opt Isol	Yes	Yes
AP	1U0-AP612A	GE/Opt Isol	Yes	Yes
AP	1U0-AP612B	GE/Opt Isol	Yes	Yes
AP	1U0-AP613A	GE/Opt Isol	Yes	Yes
AP	1U0-AP613B	GE/Opt Isol	Yes	Yes
AP	1U0-AP613C	GE/Opt Isol	Yes	Yes
AP	1U0-AP614A	GE/Opt Isol	Yes	Yes
AP	1U0-AP614B	GE/Opt Isol	Yes	Yes
AP	1U0-AP616C	GE/Opt Isol	Yes	Yes
AP	1U0-AP619A	GE/Opt Isol	Yes	Yes
AP	1U0-AP619B	GE/Opt Isol	Yes	Yes
AP	1U0-AP619C	GE/Opt Isol	Yes	Yes
AP	1U0-AP619D	GE/Opt Isol	Yes	Yes
AP	1U0-AP620A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
AP	1U0-AP620B	GE/Opt Isol	Yes	Yes
AP	1U0-AP620C	GE/Opt Isol	Yes	Yes
AP	1U0-AP620D	GE/Opt Isol	Yes	Yes
AP	1U0-AP622A	GE/Opt Isol	Yes	Yes
AP	1U0-AP622B	GE/Opt Isol	Yes	Yes
AP	1U0-AP622C	GE/Opt Isol	Yes	Yes
AP	1U0-AP622D	GE/Opt Isol	Yes	Yes
CA	1U0-CA501A	GE/Opt Isol	Yes	No
CC	1U0-CC514A	GE/Opt Isol	Yes	Yes
CC	1U0-CC515A	GE/Opt Isol	Yes	Yes
CC	1U0-CC516A	GE/Opt Isol	Yes	No
CC	1U0-CC516B	GE/Opt Isol	Yes	No
CM	1U0-CM503A	GE/Opt Isol	Yes	Yes
CM	1U0-CM503B	GE/Opt Isol	Yes	Yes
CY	1U0-CY503A	GE/Opt Isol	Yes	Yes
CY	1U0-CY503B	GE/Opt Isol	Yes	Yes
CY	1U0-CY505A	GE/Opt Isol	No	Yes
DC	1U0-DC501A	GE/Opt Isol	Yes	Yes
DC	1U0-DC501B	GE/Opt Isol	Yes	Yes
DC	1U0-DC501C	GE/Opt Isol	Yes	Yes
DC	1U0-DC501D	GE/Opt Isol	Yes	Yes
DC	1U0-DC501E	GE/Opt Isol	Yes	Yes
DC	1U0-DC501F	GE/Opt Isol	Yes	Yes
DC	1U0-DC501G	GE/Opt Isol	Yes	Yes
DC	1U0-DC501H	GE/Opt Isol	Yes	Yes
DC	1U0-DC501J	GE/Opt Isol	Yes	Yes
DC	1U0-DC501K	GE/Opt Isol	Yes	Yes
DC	1U0-DC501L	GE/Opt Isol	Yes	Yes
DC	1U0-DC502A	GE/Opt Isol	Yes	Yes
DC	1U0-DC502B	GE/Opt Isol	Yes	Yes
DC	1U0-DC502C	GE/Opt Isol	Yes	Yes
DC	1U0-DC502D	GE/Opt Isol	Yes	Yes
DC	1U0-DC502E	GE/Opt Isol	Yes	Yes
DC	1U0-DC502F	GE/Opt Isol	Yes	Yes
DC	1U0-DC502G	GE/Opt Isol	Yes	Yes
DC	1U0-DC502H	GE/Opt Isol	Yes	Yes
DC	1U0-DC502J	GE/Opt Isol	Yes	Yes
DC	1U0-DC502K	GE/Opt Isol	Yes	Yes
DC	1U0-DC502L	GE/Opt Isol	Yes	Yes
DC	1U0-DC503A	GE/Opt Isol	Yes	No
DC	1U0-DC503B	GE/Opt Isol	Yes	No
DC	1U0-DC503C	GE/Opt Isol	Yes	No
DC	1U0-DC503D	GE/Opt Isol	Yes	No
DC	1U0-DC503E	GE/Opt Isol	Yes	No
DC	1U0-DC503F	GE/Opt Isol	Yes	No
DC	1U0-DC503G	GE/Opt Isol	Yes	No
DC	1U0-DC503H	GE/Opt Isol	Yes	No
DC	1U0-DC503I	GE/Opt Isol	Yes	No
DC	1U0-DC503J	GE/Opt Isol	Yes	No

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
DC	1U0-DC503K	GE/Opt Isol	Yes	No
DO	1U0-DO501A	GE/Opt Isol	Yes	Yes
DO	1U0-DO501B	GE/Opt Isol	Yes	Yes
DO	1U0-DO501C	GE/Opt Isol	Yes	Yes
DO	1U0-DO501D	GE/Opt Isol	Yes	Yes
DO	1U0-DO501E	GE/Opt Isol	Yes	Yes
DO	1U0-DO501F	GE/Opt Isol	Yes	Yes
DO	1U0-DO502A	GE/Opt Isol	Yes	Yes
DO	1U0-DO502B	GE/Opt Isol	Yes	Yes
DO	1U0-DO502C	GE/Opt Isol	Yes	Yes
DO	1U0-DO502D	GE/Opt Isol	Yes	Yes
DO	1U0-DO502E	GE/Opt Isol	Yes	Yes
DO	1U0-DO502F	GE/Opt Isol	Yes	Yes
DO	1U0-DO503A	GE/Opt Isol	Yes	Yes
DO	1U0-DO503B	GE/Opt Isol	Yes	Yes
DO	1U0-DO503C	GE/Opt Isol	Yes	Yes
DO	1U0-DO503D	GE/Opt Isol	Yes	Yes
DO	1U0-DO503E	GE/Opt Isol	Yes	Yes
DO	1U0-DO503F	GE/Opt Isol	Yes	Yes
FC	1U0-FC501A	GE/Opt Isol	Yes	Yes
FC	1U0-FC501B	GE/Opt Isol	Yes	Yes
FC	1U0-FC501C	GE/Opt Isol	Yes	Yes
FC	1U0-FC502A	GE/Opt Isol	Yes	Yes
FC	1U0-FC502B	GE/Opt Isol	Yes	Yes
FC	1U0-FC502C	GE/Opt Isol	Yes	Yes
FC	1U0-FC510C	GE/Opt Isol	No	Yes
FC	1U0-FC514A	GE/Opt Isol	Yes	Yes
FC	1U0-FC514B	GE/Opt Isol	Yes	Yes
FC	1U0-FC514C	GE/Opt Isol	Yes	Yes
FC	1U0-FC514D	GE/Opt Isol	Yes	Yes
FC	1U0-FC515A	GE/Opt Isol	Yes	Yes
FC	1U0-FC516A	GE/Opt Isol	Yes	Yes
HG	1U0-HG501A	GE/Opt Isol	Yes	Yes
HG	1U0-HG501B	GE/Opt Isol	Yes	Yes
HG	1U0-HG511A	GE/Opt Isol	Yes	Yes
HG	1U0-HG511B	GE/Opt Isol	Yes	Yes
HG	1U0-HG511C	GE/Opt Isol	Yes	Yes
HG	1U0-HG511D	GE/Opt Isol	Yes	Yes
HG	1U0-HG512A	GE/Opt Isol	Yes	Yes
HG	1U0-HG512B	GE/Opt Isol	Yes	Yes
HG	1U0-HG512C	GE/Opt Isol	Yes	Yes
HG	1U0-HG513A	GE/Opt Isol	Yes	Yes
HG	1U0-HG513B	GE/Opt Isol	Yes	Yes
HG	1U0-HG513C	GE/Opt Isol	Yes	Yes
IA	1U0-IA501A	GE/Opt Isol	Yes	Yes
IA	1U0-IA502A	GE/Opt Isol	Yes	Yes
LD	1U0-LD506A	GE/Opt Isol	Yes	Yes
LD	1U0-LD506B	GE/Opt Isol	Yes	Yes
LD	1U0-LD506C	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
LD	1U0-LD506D	GE/Opt Isol	Yes	No
MC	1U0-MC505A	GE/Opt Isol	Yes	Yes
MC	1U0-MC505B	GE/Opt Isol	Yes	Yes
RE	1U0-RE505A	GE/Opt Isol	Yes	Yes
RE	1U0-RE505B	GE/Opt Isol	Yes	Yes
RE	1U0-RE505C	GE/Opt Isol	Yes	Yes
RE	1U0-RE506A	GE/Opt Isol	Yes	Yes
RE	1U0-RE506B	GE/Opt Isol	Yes	Yes
RE	1U0-RE506C	GE/Opt Isol	Yes	Yes
RF	1U0-RF508A	GE/Opt Isol	Yes	Yes
RF	1U0-RF508B	GE/Opt Isol	Yes	Yes
RF	1U0-RF509A	GE/Opt Isol	Yes	Yes
RF	1U0-RF509B	GE/Opt Isol	Yes	Yes
RF	1U0-RF509C	GE/Opt Isol	Yes	Yes
RF	1U0-RF509D	GE/Opt Isol	Yes	No
SA	1U0-SA508A	GE/Opt Isol	Yes	Yes
SA	1U0-SA508B	GE/Opt Isol	Yes	Yes
SF	1U0-SF505A	GE/Opt Isol	Yes	Yes
SF	1U0-SF505B	GE/Opt Isol	Yes	No
SF	1U0-SF505C	GE/Opt Isol	Yes	Yes
SF	1U0-SF505D	GE/Opt Isol	Yes	No
SM	1U0-SM504A	GE/Opt Isol	Yes	Yes
SM	1U0-SM504B	GE/Opt Isol	Yes	Yes
SX	1U0-SX501A	GE/Opt Isol	Yes	Yes
SX	1U0-SX501B	GE/Opt Isol	Yes	Yes
SX	1U0-SX501C	GE/Opt Isol	Yes	Yes
SX	1U0-SX502A	GE/Opt Isol	Yes	Yes
SX	1U0-SX502B	GE/Opt Isol	Yes	Yes
SX	1U0-SX502C	GE/Opt Isol	Yes	Yes
SX	1U0-SX503A	GE/Opt Isol	Yes	Yes
SX	1U0-SX503B	GE/Opt Isol	Yes	Yes
SX	1U0-SX503C	GE/Opt Isol	Yes	Yes
SX	1U0-SX504A	GE/Opt Isol	Yes	Yes
SX	1U0-SX504B	GE/Opt Isol	Yes	Yes
SX	1U0-SX505A	GE/Opt Isol	Yes	Yes
SX	1U0-SX505B	GE/Opt Isol	Yes	Yes
SX	1U0-SX506A	GE/Opt Isol	Yes	Yes
SX	1U0-SX506B	GE/Opt Isol	Yes	Yes
SX	1U0-SX528A	GE/Opt Isol	Yes	Yes
SX	1U0-SX529A	GE/Opt Isol	Yes	No
SX	1U0-SX530A	GE/Opt Isol	Yes	Yes
VC	1U0-VC537A	GE/Opt Isol	Yes	Yes
VD	1U0-VD501A	GE/Opt Isol	Yes	Yes
VD	1U0-VD501B	GE/Opt Isol	Yes	Yes
VD	1U0-VD501C	GE/Opt Isol	Yes	Yes
VD	1U0-VD502A	GE/Opt Isol	Yes	Yes
VD	1U0-VD502B	GE/Opt Isol	Yes	Yes
VD	1U0-VD502C	GE/Opt Isol	Yes	Yes
VD	1U0-VD503A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VD	1U0-VD503B	GE/Opt Isol	Yes	Yes
VD	1U0-VD503C	GE/Opt Isol	Yes	Yes
VD	1U0-VD503D	GE/Opt Isol	Yes	Yes
VD	1U0-VD503E	GE/Opt Isol	Yes	Yes
VD	1U0-VD504A	GE/Opt Isol	Yes	Yes
VD	1U0-VD504B	GE/Opt Isol	Yes	Yes
VD	1U0-VD505A	GE/Opt Isol	Yes	Yes
VD	1U0-VD505B	GE/Opt Isol	Yes	Yes
VD	1U0-VD507D	GE/Opt Isol	Yes	Yes
VD	1U0-VD507E	GE/Opt Isol	Yes	No
VD	1U0-VD508A	GE/Opt Isol	Yes	Yes
VD	1U0-VD508B	GE/Opt Isol	Yes	Yes
VD	1U0-VD509A	GE/Opt Isol	Yes	Yes
VD	1U0-VD509B	GE/Opt Isol	Yes	Yes
VD	1U0-VD510A	GE/Opt Isol	Yes	Yes
VD	1U0-VD511A	GE/Opt Isol	Yes	Yes
VD	1U0-VD512A	GE/Opt Isol	Yes	Yes
VD	1U0-VD515A	GE/Opt Isol	Yes	Yes
VD	1U0-VD515B	GE/Opt Isol	Yes	Yes
VD	1U0-VD515C	GE/Opt Isol	Yes	Yes
VD	1U0-VD515D	GE/Opt Isol	Yes	Yes
VD	1U0-VD515E	GE/Opt Isol	Yes	Yes
VD	1U0-VD515F	GE/Opt Isol	Yes	Yes
VD	1U0-VD515G	GE/Opt Isol	Yes	Yes
VD	1U0-VD515H	GE/Opt Isol	Yes	Yes
VD	1U0-VD515J	GE/Opt Isol	Yes	Yes
VF	1U0-VF503A	GE/Opt Isol	Yes	Yes
VF	1U0-VF503B	GE/Opt Isol	Yes	Yes
VF	1U0-VF503C	GE/Opt Isol	Yes	Yes
VF	1U0-VF503D	GE/Opt Isol	Yes	Yes
VG	1U0-VG501A	GE/Opt Isol	Yes	Yes
VG	1U0-VG508A	GE/Opt Isol	Yes	Yes
VG	1U0-VG508B	GE/Opt Isol	Yes	Yes
VG	1U0-VG508C	GE/Opt Isol	Yes	Yes
VG	1U0-VG508D	GE/Opt Isol	Yes	Yes
VG	1U0-VG508E	GE/Opt Isol	Yes	Yes
VG	1U0-VG508F	GE/Opt Isol	Yes	Yes
VG	1U0-VG508G	GE/Opt Isol	Yes	Yes
VG	1U0-VG508H	GE/Opt Isol	Yes	Yes
VG	1U0-VG511A	GE/Opt Isol	Yes	Yes
VG	1U0-VG511B	GE/Opt Isol	Yes	Yes
VG	1U0-VG511C	GE/Opt Isol	Yes	Yes
VG	1U0-VG511D	GE/Opt Isol	Yes	Yes
VG	1U0-VG511E	GE/Opt Isol	Yes	Yes
VG	1U0-VG511F	GE/Opt Isol	Yes	Yes
VG	1U0-VG511G	GE/Opt Isol	Yes	Yes
VG	1U0-VG511H	GE/Opt Isol	Yes	Yes
VH	1U0-VH501A	GE/Opt Isol	Yes	Yes
VH	1U0-VH501B	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VH	1U0-VH502A	GE/Opt Isol	Yes	Yes
VH	1U0-VH502B	GE/Opt Isol	Yes	Yes
VH	1U0-VH503A	GE/Opt Isol	Yes	Yes
VH	1U0-VH503B	GE/Opt Isol	Yes	Yes
VH	1U0-VH504A	GE/Opt Isol	Yes	Yes
VH	1U0-VH504B	GE/Opt Isol	Yes	Yes
VH	1U0-VH504C	GE/Opt Isol	Yes	Yes
VH	1U0-VH504D	GE/Opt Isol	Yes	Yes
VH	1U0-VH504E	GE/Opt Isol	Yes	Yes
VH	1U0-VH504F	GE/Opt Isol	Yes	Yes
VH	1U0-VH504G	GE/Opt Isol	Yes	Yes
VH	1U0-VH504H	GE/Opt Isol	Yes	Yes
VH	1U0-VH504J	GE/Opt Isol	Yes	Yes
VH	1U0-VH505A	GE/Opt Isol	Yes	Yes
VH	1U0-VH505B	GE/Opt Isol	Yes	Yes
VH	1U0-VH505C	GE/Opt Isol	Yes	Yes
VP	1U0-VP501A	GE/Opt Isol	Yes	Yes
VP	1U0-VP501B	GE/Opt Isol	Yes	Yes
VP	1U0-VP501C	GE/Opt Isol	Yes	Yes
VP	1U0-VP501D	GE/Opt Isol	Yes	Yes
VP	1U0-VP502A	GE/Opt Isol	Yes	Yes
VP	1U0-VP502B	GE/Opt Isol	Yes	Yes
VP	1U0-VP502C	GE/Opt Isol	Yes	Yes
VP	1U0-VP502D	GE/Opt Isol	Yes	Yes
VP	1U0-VP503A	GE/Opt Isol	Yes	Yes
VP	1U0-VP504A	GE/Opt Isol	Yes	Yes
VP	1U0-VP505A	GE/Opt Isol	Yes	Yes
VP	1U0-VP505B	GE/Opt Isol	Yes	Yes
VP	1U0-VP506A	GE/Opt Isol	Yes	Yes
VP	1U0-VP506B	GE/Opt Isol	Yes	Yes
VP	1U0-VP511A	GE/Opt Isol	Yes	Yes
VP	1U0-VP511B	GE/Opt Isol	Yes	Yes
VP	1U0-VP511C	GE/Opt Isol	Yes	Yes
VP	1U0-VP512A	GE/Opt Isol	Yes	Yes
VP	1U0-VP512B	GE/Opt Isol	Yes	Yes
VP	1U0-VP512C	GE/Opt Isol	Yes	Yes
VP	1U0-VP516A	GE/Opt Isol	Yes	Yes
VP	1U0-VP516B	GE/Opt Isol	Yes	Yes
VP	1U0-VP516C	GE/Opt Isol	Yes	Yes
VP	1U0-VP516D	GE/Opt Isol	Yes	Yes
VP	1U0-VP516E	GE/Opt Isol	Yes	Yes
VP	1U0-VP516F	GE/Opt Isol	Yes	Yes
VP	1U0-VP516G	GE/Opt Isol	Yes	Yes
VP	1U0-VP516H	GE/Opt Isol	Yes	Yes
VP	1U0-VP516J	GE/Opt Isol	Yes	Yes
VP	1U0-VP516K	GE/Opt Isol	Yes	Yes
VQ	1U0-VQ503A	GE/Opt Isol	Yes	Yes
VQ	1U0-VQ503B	GE/Opt Isol	Yes	Yes
VQ	1U0-VQ505A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VQ	1U0-VQ505B	GE/Opt Isol	Yes	Yes
VQ	1U0-VQ509A	GE/Opt Isol	Yes	Yes
VQ	1U0-VQ509B	GE/Opt Isol	Yes	Yes
VR	1U0-VR507A	GE/Opt Isol	Yes	Yes
VR	1U0-VR507B	GE/Opt Isol	Yes	Yes
VX	1U0-VX504A	GE/Opt Isol	Yes	Yes
VX	1U0-VX504B	GE/Opt Isol	Yes	Yes
VX	1U0-VX504C	GE/Opt Isol	Yes	Yes
VX	1U0-VX504D	GE/Opt Isol	Yes	Yes
VX	1U0-VX504E	GE/Opt Isol	Yes	Yes
VX	1U0-VX504F	GE/Opt Isol	Yes	Yes
VX	1U0-VX504G	GE/Opt Isol	Yes	Yes
VX	1U0-VX505A	GE/Opt Isol	Yes	Yes
VX	1U0-VX505B	GE/Opt Isol	Yes	Yes
VX	1U0-VX505C	GE/Opt Isol	Yes	Yes
VX	1U0-VX505D	GE/Opt Isol	Yes	Yes
VX	1U0-VX505E	GE/Opt Isol	Yes	Yes
VX	1U0-VX505F	GE/Opt Isol	Yes	Yes
VX	1U0-VX505G	GE/Opt Isol	Yes	Yes
VX	1U0-VX506A	GE/Opt Isol	Yes	Yes
VX	1U0-VX506B	GE/Opt Isol	Yes	Yes
VX	1U0-VX506C	GE/Opt Isol	Yes	Yes
VX	1U0-VX506D	GE/Opt Isol	Yes	Yes
VX	1U0-VX506E	GE/Opt Isol	Yes	Yes
VX	1U0-VX506F	GE/Opt Isol	Yes	Yes
VX	1U0-VX506G	GE/Opt Isol	Yes	Yes
VX	1U0-VX507A	GE/Opt Isol	Yes	Yes
VX	1U0-VX507B	GE/Opt Isol	Yes	Yes
VX	1U0-VX507C	GE/Opt Isol	Yes	Yes
VX	1U0-VX508A	GE/Opt Isol	Yes	Yes
VX	1U0-VX508B	GE/Opt Isol	Yes	Yes
VX	1U0-VX508C	GE/Opt Isol	Yes	Yes
VX	1U0-VX509A	GE/Opt Isol	Yes	Yes
VX	1U0-VX509B	GE/Opt Isol	Yes	Yes
VX	1U0-VX509C	GE/Opt Isol	Yes	Yes
VX	1U0-VX510A	GE/Opt Isol	Yes	Yes
VX	1U0-VX510B	GE/Opt Isol	Yes	Yes
VX	1U0-VX510C	GE/Opt Isol	Yes	Yes
VX	1U0-VX510D	GE/Opt Isol	Yes	Yes
VX	1U0-VX510E	GE/Opt Isol	Yes	Yes
VX	1U0-VX510F	GE/Opt Isol	Yes	Yes
VX	1U0-VX511A	GE/Opt Isol	Yes	Yes
VX	1U0-VX511B	GE/Opt Isol	Yes	Yes
VX	1U0-VX511C	GE/Opt Isol	Yes	Yes
VX	1U0-VX512A	GE/Opt Isol	Yes	Yes
VX	1U0-VX512B	GE/Opt Isol	Yes	Yes
VX	1U0-VX513A	GE/Opt Isol	Yes	Yes
VX	1U0-VX513B	GE/Opt Isol	Yes	Yes
VX	1U0-VX514A	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====				
VX	1U0-VX514B	GE/Opt Isol	Yes	Yes
VX	1U0-VX514C	GE/Opt Isol	Yes	Yes
VX	1U0-VX515A	GE/Opt Isol	Yes	Yes
VX	1U0-VX515B	GE/Opt Isol	Yes	Yes
VX	1U0-VX515C	GE/Opt Isol	Yes	Yes
VX	1U0-VX516A	GE/Opt Isol	Yes	Yes
VX	1U0-VX517A	GE/Opt Isol	Yes	Yes
VX	1U0-VX518A	GE/Opt Isol	Yes	Yes
VX	1U0-VX518B	GE/Opt Isol	Yes	Yes
VX	1U0-VX518C	GE/Opt Isol	Yes	Yes
VX	1U0-VX519D	GE/Opt Isol	Yes	Yes
VX	1U0-VX518E	GE/Opt Isol	Yes	Yes
VX	1U0-VX518F	GE/Opt Isol	Yes	Yes
VX	1U0-VX524A	GE/Opt Isol	Yes	Yes
VX	1U0-VX525A	GE/Opt Isol	Yes	Yes
VX	1U0-VX526A	GE/Opt Isol	Yes	Yes
VY	1U0-VY501A	GE/Opt Isol	Yes	Yes
VY	1U0-VY501B	GE/Opt Isol	Yes	Yes
VY	1U0-VY501C	GE/Opt Isol	Yes	Yes
VY	1U0-VY501D	GE/Opt Isol	Yes	Yes
VY	1U0-VY502A	GE/Opt Isol	Yes	Yes
VY	1U0-VY502B	GE/Opt Isol	Yes	Yes
VY	1U0-VY503A	GE/Opt Isol	Yes	Yes
VY	1U0-VY503B	GE/Opt Isol	Yes	Yes
VY	1U0-VY504A	GE/Opt Isol	Yes	Yes
VY	1U0-VY504B	GE/Opt Isol	Yes	Yes
VY	1U0-VY505A	GE/Opt Isol	Yes	Yes
VY	1U0-VY505B	GE/Opt Isol	Yes	Yes
VY	1U0-VY505C	GE/Opt Isol	Yes	Yes
VY	1U0-VY505D	GE/Opt Isol	Yes	Yes
VY	1U0-VY506A	GE/Opt Isol	Yes	Yes
VY	1U0-VY506B	GE/Opt Isol	Yes	Yes
VY	1U0-VY506C	GE/Opt Isol	Yes	Yes
VY	1U0-VY506D	GE/Opt Isol	Yes	Yes
VY	1U0-VY507A	GE/Opt Isol	Yes	Yes
VY	1U0-VY507B	GE/Opt Isol	Yes	Yes
VY	1U0-VY507C	GE/Opt Isol	Yes	Yes
VY	1U0-VY507D	GE/Opt Isol	Yes	Yes
VY	1U0-VY507E	GE/Opt Isol	Yes	Yes
VY	1U0-VY507F	GE/Opt Isol	Yes	Yes
VY	1U0-VY507G	GE/Opt Isol	Yes	Yes
VY	1U0-VY507H	GE/Opt Isol	Yes	Yes
VY	1U0-VY507J	GE/Opt Isol	Yes	Yes
VY	1U0-VY507K	GE/Opt Isol	Yes	Yes
VY	1U0-VY507L	GE/Opt Isol	Yes	Yes
VY	1U0-VY507M	GE/Opt Isol	Yes	Yes
VY	1U0-VY507N	GE/Opt Isol	Yes	Yes
VY	1U0-VY507P	GE/Opt Isol	Yes	Yes
VY	1U0-VY507Q	GE/Opt Isol	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VY	1U0-VY507R	GE/Opt Isol	Yes	Yes
VY	1U0-VY508A	GE/Opt Isol	Yes	Yes
VY	1U0-VY508B	GE/Opt Isol	Yes	Yes
VY	1U0-VY508C	GE/Opt Isol	Yes	Yes
VY	1U0-VY508D	GE/Opt Isol	Yes	Yes
VY	1U0-VY508E	GE/Opt Isol	Yes	Yes
VY	1U0-VY508F	GE/Opt Isol	Yes	Yes
VY	1U0-VY508G	GE/Opt Isol	Yes	Yes
VY	1U0-VY508H	GE/Opt Isol	Yes	Yes
VY	1U0-VY508J	GE/Opt Isol	Yes	Yes
VY	1U0-VY509A	GE/Opt Isol	Yes	Yes
VY	1U0-VY509B	GE/Opt Isol	Yes	Yes
VY	1U0-VY509C	GE/Opt Isol	Yes	Yes
VY	1U0-VY510A	GE/Opt Isol	Yes	Yes
VY	1U0-VY511A	GE/Opt Isol	Yes	Yes
WX	1U0-WX501A	GE/Opt Isol	Yes	Yes
WX	1U0-WX501B	GE/Opt Isol	Yes	Yes
WX	1U0-WX501D	GE/Opt Isol	Yes	Yes
WX	1U0-WX501E	GE/Opt Isol	Yes	Yes
AP	1US-AP945	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
AP	1US-AP946	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
AP	1US-AP947	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
AP	1US-AP949	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
AP	1US-AP950	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
AP	1US-AP951	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
DG	1US-DG820	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
DG	1US-DG822	GE/HVAC Cnt Pnl Tst Sw FT-1	Yes	Yes
PR	1UT-PR001AA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001AB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001BA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001BB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001CA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001CB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001DA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR001DB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006AA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006AB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006BA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006BB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006CA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006CB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006DA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR006DB	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR008AA	Ebrln/CLI-1 Line Sol	Yes	No
PR	1UT-PR008AB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR008BA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR008BB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR008CA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR008CB	Ebrln/Line Isolators CLI-1	Yes	No

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
PR	1UT-PR008DA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR008DB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009AA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009AB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009BA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009BB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009CA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009CB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009DA	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR009DB	Ebrln/Line Isolators CLI-1	Yes	No
PR	1UT-PR042AA	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042AB	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042BA	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042BB	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042CA	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042CB	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042DA	Ebrln/CLI-1Q	Yes	Yes
PR	1UT-PR042DB	Ebrln/CLI-1Q	Yes	Yes
UU	1UU-LV821	Sola/9T66Y	Yes	Yes
UU	1UU-LV851A	Sola/9T66Y	Yes	Yes
UU	1UU-LV861	Sola/9T66Y	Yes	Yes
DC	1UX-DC074	TEC/Isol 156	Yes	Yes
DC	1UX-DC075	TEC/Isol 156	Yes	Yes
VA	1VA100Y	Papco/HVAC Dmpr	Yes	Yes
VA	1VA103Y	Ruskin/Fire Dmpr	Yes	Yes
VA	1VA55Y	Ruskin/Balancing Dmpr	Yes	Yes
VA	1VA56Y	Ruskin/Balancing Dmpr	Yes	Yes
VC	1VC133Y	PlmnCnst/FD-100V	No	Yes
VD	1VD01CA(F)	BF/54D5 HVAC Fan	Yes	Yes
VD	1VD01CA(M)	Wsths/444TCZ Fan Mtr TBAM	Yes	Yes
VD	1VD01CB(F)	BF/54D5 HVAC Fan	Yes	Yes
VD	1VD01CB(M)	Wsths/444TCZ Fan Mtr TBAM	Yes	Yes
VD	1VD01CC(F)	BF/HVAC Fan AX43C9	Yes	Yes
VD	1VD01CC(M)	BF-Wsths/365TCE	Yes	Yes
VD	1VD01YA	Papco/E101 ML Dmpr	Yes	Yes
VD	1VD01YB	Papco/E111 ML Dmpr	Yes	Yes
VD	1VD01YC	Papco/E111 ML Dmpr	Yes	Yes
VD	1VD02CA(F)	BF/SWGR Heat Rem Fan	Yes	Yes
VD	1VD02CA(M)	Wsths/DG VntOilRmExhFnMtr TEFC	Yes	Yes
VD	1VD02CB(F)	BF/SWGR Heat Rem Fan	Yes	Yes
VD	1VD02CB(M)	Wsths/DG VntOilRmExhFnMtr TEFC	Yes	Yes
VD	1VD02CC(F)	BF/SWGR Heat Rem Fan	Yes	Yes
VD	1VD02CC(M)	Wsths/DG VetOilRmExhFnMtr TEFC	Yes	Yes
VD	1VD02YA	Papco/E154 ML Dmpr	Yes	Yes
VD	1VD02YB	Papco/E101 ML Dmpr	Yes	Yes
VD	1VD02YC	Papco/E101 ML Dmpr	Yes	Yes
VD	1VD03YA	Papco/E365 ML Dmpr	Yes	Yes
VD	1VD03YB	Papco/E365 ML Dmpr	Yes	Yes
VD	1VD03YC	Papco/E365 MI Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM EQUIPMENT NUMBER		MANUFACTURER/MODEL NUMBER	INSTALLED QUALIFIED	
VD	1VD04YB	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD05YA	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD06YA	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD07YA	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD07YB	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD07YC	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD08YB	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD11YA	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD11YB	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD11YC	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD12YA	Papco/HVAC Dmpr	Yes	Yes
VD	1VD12YB	Papco/HVAC Dmpr	Yes	Yes
VD	1VD12YC	Papco/HVAC Dmpr	Yes	Yes
VD	1VD13YA	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD13YB	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD13YC	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD14YA	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD14YB	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD14YC	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD16YA	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD16YB	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD16YC	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD17YA	Papco/LP Backdraft Dmpr	Yes	Yes
VD	1VD17YB	Papco/LP Backdraft Dmpr	Yes	Yes
VD	1VD17YC	Papco/LP Backdraft Dmpr	Yes	Yes
VD	1VD18Y	Papco/HVAC Dmpr	Yes	Yes
VD	1VD20Y	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD21Y	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD22Y	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD23Y	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VD24Y	Ruskin/Fire Dmpr	Yes	Yes
VD	1VD25YA	Papco/Parallel Dmpr	Yes	Yes
VD	1VD25YB	Papco/Parallel Dmpr	Yes	Yes
VD	1VD27YA	Papco/HP Backdraft Dmpr	Yes	Yes
VD	1VD27YB	Papco/LP Backdraft Dmpr	Yes	Yes
VD	1VD27YC	Papco/HP Backdraft Dmpr	Yes	Yes
VD	1VD28Y	PlmnCnst/FD-200V	No	Yes
VD	1VD29YA	PlmnCnst/FD-400V	No	Yes
VD	1VD29YB	PlmnCnst/FD-400V	No	Yes
VD	1VD29YC	PlmnCnst/FD-200V	No	Yes
VD	1VD30YA	PlmnCnst/FD-400V	No	Yes
VD	1VD30YB	PlmnCnst/FD-400V	No	Yes
VD	1VD30YC	PlmnCnst/FD-200V	No	Yes
LM	1VE-LM001	Rockwell/Accel & Cable	Yes	Yes
LM	1VE-LM002	Rockwell/Accel & Cable	Yes	Yes
LM	1VE-LM003	Rockwell/Accel & Cable	Yes	Yes
LM	1VE-LM004	Rockwell/Accel & Cable	Yes	Yes
LM	1VE-LM005	Rockwell/Accel & Cable	Yes	Yes
LM	1VE-LM006	Rockwell/Accel & Cable	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VF	1VF01Y	Papco/Parallel Dmpr	Yes	Yes
VF	1VF02YA	Papco/Parallel Dmpr	Yes	Yes
VF	1VF02YB	Papco/Parallel Dmpr	Yes	Yes
VF	1VF03Y	Papco/Opposed Dmpr	Yes	Yes
VF	1VF04Y	Papco/Btrfly Dmpr P457	Yes	Yes
VF	1VF04Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF05Y	Ruskin/Fire Dmpr	Yes	Yes
VF	1VF06Y	Papco/SL100R HVAC Dmpr	Yes	Yes
VF	1VF07Y	Papco/SL100R HVAC Dmpr	Yes	Yes
VF	1VF08Y	Ruskin/Fire Dmpr	Yes	Yes
VF	1VF09Y	Papco/Btrfly Dmpr P463	Yes	Yes
VF	1VF10Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF11YA	Papco/Parallel Dmpr	Yes	Yes
VF	1VF11YB	Papco/Parallel Dmpr	Yes	Yes
VF	1VF12Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF13Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF17Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF18Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF20Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF21Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF22Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF25Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF27Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF28Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF29Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF30Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF31Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF32Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF33Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF34Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF35Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF37Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF38Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF39Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF40Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF41Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF42Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF43Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF44Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF45Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF46Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF47Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF48Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF50Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF50Y	Papco/LP Backdraft Dmpr	Yes	Yes
VF	1VF51Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF52Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF53Y	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VF54Y	Ruskin/Balancing Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VF	1VF59Y	Ruskin/Balancing Dmpr	Yes	Yes
VD	1VF64Y	PlmnCnst/FD-400V	No	Yes
VF	1VF65YA	PlmnCnst/FD-200V	Yes	Yes
VF	1VF65YB	PlmnCnst/FD-200V	Yes	Yes
VG	1VG01YA	PacAirPr/Dmp	Yes	Yes
VG	1VG01YB	PacAir/Dmp	Yes	Yes
VG	1VG02YA	PacAir/Dmp	Yes	Yes
VG	1VG02YB	PacAir/Dmp	Yes	Yes
VG	1VG04YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG04YA	ITT/NH-95	Yes	Yes
VG	1VG04YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG04YB	ITT/NH-95	Yes	Yes
VF	1VG05YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG05YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG06YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG06YA(A)	ITT/NH-95	Yes	Yes
VG	1VG06YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VG	1VG07YA	Ruskin/Balancing Dmpr	Yes	Yes
VG	1VG07YB	Ruskin/Balancing Dmpr	Yes	Yes
VG	1VG09YA	Ruskin/Balancing Dmpr	Yes	Yes
VG	1VG09YB	Ruskin/Balancing Dmpr	Yes	Yes
VF	1VG16YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VF	1VG16YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VF	1VG17YA	PacAir/SL100R HVAC Dmpr	Yes	Yes
VF	1VG17YB	PacAir/SL100R HVAC Dmpr	Yes	Yes
VH	1VH01CA(F)	BF/AX 48C9 Fan	Yes	Yes
VH	1VH01CA(M)	Wsths/TBAM 15 HP Mtr	Yes	Yes
VH	1VH01CB(F)	BF/AX 48C9 Fan	Yes	Yes
VH	1VH01CB(M)	Wsths/TBAM 15 HP Mtr	Yes	Yes
VH	1VH01CC(F)	BF/TypS/22A7AdjSSWPMP RMSupFn	Yes	Yes
VH	1VH01CC(M)	Wsths/TBAM Mtr	Yes	Yes
VH	1VH05Y	Ruskin/Fire Dmpr	Yes	Yes
VH	1VH07SA	AAF/Coil Cab	Yes	Yes
VH	1VH07SB	AAF/Coil Cab	Yes	Yes
VH	1VH07SC	AAF/Coil Cab	Yes	Yes
VH	1VH07Y	Ruskin/Fire Dmpr	Yes	Yes
VH	1VH10Y	Ruskin/Balancing Impr	Yes	Yes
VH	1VH11Y	Ruskin/Balancing Dmpr	Yes	Yes
VH	1VH12Y	Ruskin/Balancing Dmpr	Yes	Yes
VH	1VH13Y	Ruskin/Balancing Dmpr	Yes	Yes
VH	1VH16Y	Ruskin/Fire Dmpr	Yes	Yes
VH	1VH17Y	Ruskin/Fire Dmpr	Yes	Yes
VH	1VH18Y	Ruskin/Fire Dmpr	Yes	Yes
VP	1VP004A(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP004A(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP004B(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP004B(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP005A(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP005A(V)	AD/10" Gt VLV	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VP	1VP005B(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP005B(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP014A(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP014A(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP014B(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP014B(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP015A(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP015A(V)	AD/10" Gt VLV	Yes	Yes
VP	1VP015B(A)	Lmt/SMB-000-5	Yes	Yes
VP	1VP015B(V)	AD/10"-GT VLV	Yes	Yes
VP	1VP01CA(F)	BF-Wsths/Fan	Yes	Yes
VP	1VP01CA(M)	Wsths/FR:284 TCZ	Yes	Yes
VP	1VP01CB(F)	BF-Wsths/Fan	Yes	Yes
VP	1VP01CB(M)	BF-Wsths/Fan Mtr	Yes	Yes
VP	1VP01CC(F)	BF-Wsths/Fan	Yes	Yes
VP	1VP01CC(M)	Wsths/FR:324 TCZ 30 HP	Yes	Yes
VP	1VP01CD(F)	BF-Wsths/Fan	Yes	Yes
VP	1VP01CD(M)	Wsths/FR:324 TCZ 30 HP	Yes	Yes
VP	1VP01CE(F)	BF/25A9 Adjstx Fan	Yes	Yes
VP	1VP01CE(M)	Wsths/Mtr FR:215 TCZ	Yes	Yes
VP	1VP01CF(F)	BF/25A9 Adjstx Fan	Yes	Yes
VP	1VP01CF(M)	Wsths/Mtr FR:215 TCZ	Yes	Yes
VP	1VP01CG(F)	BF/25A9 Adjstx Fan	Yes	Yes
VP	1VP01CG(M)	Wsths/Mtr FR:215 TCZ	Yes	Yes
VP	1VP01CH(F)	BF/25A9 Adjstx Fan	Yes	Yes
VP	1VP01CH(M)	Wsths/Mtr FR:215 TCZ	Yes	Yes
VP	1VP01YA	Papco/HP Backdraft Dmpr	Yes	Yes
VP	1VP01YB	Papco/HVAC Dmpr	Yes	Yes
VP	1VP01YC	Papco/LP Backdraft Dmpr	Yes	Yes
VP	1VP01YD	Papco/LP Backdraft Dmpr	Yes	Yes
VP	1VP023A	Dresser/.75" SRV	Yes	Yes
VP	1VP023B	Dresser/.75" SRV	Yes	Yes
VP	1VP027A	Dresser/.75" SRV	Yes	Yes
VP	1VP027B	Dresser/.75" SRV	Yes	Yes
VP	1VP02AA	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AB	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AC	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AD	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AE	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AF	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AG	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02AH	AAF/Cubicle Cooler	Yes	Yes
VP	1VP02SA	AAF/Coil Cab	Yes	Yes
VP	1VP02SB	AAF/Coil Cab	Yes	Yes
VP	1VP02SC	AAF/Cab	Yes	Yes
VP	1VP02SD	AAF/Coil Cab	Yes	Yes
VP	1VP02SE	AAF/Coil Cab	Yes	Yes
VP	1VP02SF	AAF/Coil Cab	Yes	Yes
VP	1VP02SG	AAF/Coil Cab	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VP	1VP02SH	AAF/Coil Cab	Yes	Yes
VP	1VP02Y	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP03Y	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP05Y	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP06YA	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP06YB	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP07YA	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP07YB	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP07YC	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP07YD	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP08YA	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP08YB	Ruskin/Balancing Dmpr	Yes	Yes
VP	1VP10Y	Papco/Parallel Dmpr	Yes	Yes
VP	1VP12Y	Papco/Parallel Dmpr	Yes	Yes
VQ	1VQ001A(A)	GreerHyd/330825R80	Yes	Yes
VQ	1VQ001A(V)	PosiSl/24" Btrfly Vlv	Yes	Yes
VQ	1VQ001B(A)	GreerHyd/330825R80	Yes	Yes
VQ	1VQ001B(V)	PosiSl/24" Btrfly Vlv	Yes	Yes
VQ	1VQ002(A)	GreerHyd/330825R80	Yes	Yes
VQ	1VQ002(V)	PosiSl/24" Btrfly Vlv	Yes	Yes
VQ	1VQ003(A)	GreerHyd/451025R80	Yes	Yes
VQ	1VQ003(V)	PosiSl/36" Btrfly Vlv	Yes	Yes
VQ	1VQ004A(A)	GreerHyd/451025R80	Yes	Yes
VQ	1VQ004A(V)	PosiSl/36" Btrfly Vlv	Yes	Yes
VQ	1VQ004B(A)	GreerHyd/451025R80	Yes	Yes
VQ	1VQ004B(V)	PosiSl/36" Btrfly Vlv	Yes	Yes
VQ	1VQ005(A)	GreerHyd/260625R80	Yes	Yes
VQ	1VQ005(V)	PosiSl/10" Btrfly Vlv	Yes	Yes
VQ	1VQ006A(A)	Lmt/SMB-000	Yes	Yes
VQ	1VQ006A(V)	AD/4" Glb Vlv	Yes	Yes
VQ	1VQ006B(A)	Lmt/SMB-000	Yes	Yes
VQ	1VQ006B(V)	AD/4" Glb Vlv	Yes	Yes
VQ	1VQ01M	SL/Debris Scrn	Yes	Yes
VQ	1VQ01Y	PacAir/SL100R HVAC Dmpr	Yes	Yes
VQ	1VQ02M	SL/Debris Scrn	Yes	Yes
VQ	1VQ02Y	PacAir/SL100R HVAC Dmpr	Yes	Yes
VQ	1VQ03M	SL/Debris Scrn	Yes	Yes
VQ	1VQ03Y	PacAir/SL100R HVAC Dmpr	Yes	Yes
VQ	1VQ03Y(A)	ITT/NH-95	Yes	Yes
VQ	1VQ20Y	Papco/HVAC Dmpr	Yes	Yes
VQ	1VQ22Y	Ruskin/Fire Dmpr	Yes	Yes
VQ	1VQ23Y	Ruskin/Fire Dmpr	Yes	Yes
VR	1VR001A(A)	GreerHyd/451025R80	Yes	Yes
VQ	1VR001A(V)	PosiSl/36" Btrfly Vlv	Yes	Yes
VR	1VR001B(A)	GreerHyd/451025R80	Yes	Yes
VQ	1VR001B(V)	PosiSl/36" Btrfly Vlv	Yes	Yes
VR	1VR001Y	Papco/Parallel Dmpr	Yes	Yes
VR	1VR002A(A)	Lmt/SMB-000	Yes	Yes
VR	1VR002A(V)	AD/4" Glb Vlv	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VR	1VR002B(A)	Lmt/SMB-000-5	Yes	Yes
VR	1VR002B(V)	AD/4" G1b Vlv	Yes	Yes
VR	1VR002YA	Papco/Butrfly Dmpr	Yes	Yes
VR	1VR002YB	Papco/Butrfly Dmpr	Yes	Yes
VR	1VR003Y	Papco/Opposed Dmpr	Yes	Yes
VR	1VR004Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR006A(V)	Clw/12" Wafer Vlv	Yes	Yes
VR	1VR006B(V)*	Clw/12" Wafer Vlv	Yes	Yes
VR	1VR006Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR007A(V)	Clw/12" Wafer Vlv	Yes	Yes
VR	1VR007B(V)*	Clw/12" Wafer Vlv	Yes	Yes
VR	1VR008YA	Papco/Btrfly Dmpr	Yes	Yes
VR	1VR008YB	Papco/Btrfly Dmpr	Yes	Yes
VR	1VR009Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR010Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR011Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR012Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR015Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR016Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR020Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR021Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR022Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR023Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR024Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR025Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR027Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR028Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR029Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR02M	SL/Debris Scrn	Yes	Yes
VR	1VR031Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR032Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR033Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR034Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR035	Valcor/.75"SolVlvV526-5940-133	Yes	Yes
VR	1VR035(OS)	Conax/7F20-11002-03	Yes	Yes
VR	1VR035Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR036	Valcor/.75"SolVlvV526-5940-133	Yes	Yes
VR	1VR036(OS)	Conax/7F20-11002-03	Yes	Yes
VR	1VR036Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR039Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR03M	SL/Debris Scrn	Yes	Yes
VR	1VR040	Valcor/.75"SolVlvV526-5940-133	Yes	Yes
VR	1VR040(OS)	Conax/7F20-11002-03	Yes	Yes
VR	1VR041	Valcor/.75"SolVlvV526-5940-133	Yes	Yes
VR	1VR041(OS)	Conax/7F20-11002-03	Yes	Yes
VR	1VR041Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR043Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR047Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR049Y	Ruskin/Balancing Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VR	1VR04M	SL/Debris Scrn	Yes	Yes
VR	1VR04Y	Papco/Opposed Dmpr	Yes	Yes
VR	1VR050Y	Papco/HP Backdraft Dmpr	Yes	Yes
VR	1VR056Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR057Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR058Y	Papco/LP Backdraft Dmpr	Yes	Yes
VR	1VR059Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR05M	SL/Debris Scrn	Yes	Yes
VR	1VR064Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR065Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR066Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR067Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR068Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR069Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR06M	SL/Debris Scrn	Yes	Yes
VR	1VR070Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR071Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR072Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR073Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR074Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR075Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR076Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR077Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR078Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR079Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR080Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR081Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR085Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR086Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR087Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR088Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR089Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR08C(F)	BF/Cent 365 BL CL1	Yes	Yes
VR	1VR08C(M)	Wsths/3HP Mtr TEFC	Yes	Yes
VR	1VR090Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR091Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR093Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR094Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR095Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR096Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR097Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR098Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR099Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR09S	AAF/Coil Cab	Yes	Yes
VR	1VR100Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR101Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR102Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR103Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR104Y	Ruskin/Balancing Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VR	1VR105Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR106Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR107Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR108Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR109Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR110Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR111Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR112Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR113Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR11C(F)	BF/Cent 365 BL CL1	Yes	Yes
VR	1VR11C(M)	Wsths/Mtr TEFC Fr:184T	Yes	Yes
VR	1VR120Y	Papco/HP Backdraft Dmpr	Yes	Yes
VR	1VR121Y	Ruskin/Balancing Dmpr	Yes	Yes
VR	1VR12S	AAF/Coil Cab	Yes	Yes
VR	1VR132YA	PlmnCnst/FD-200V	Yes	Yes
VR	1VR132YB	PlmnCnst/FD-400V	No	Yes
VR	1VR133YA	PlmnCnst/FD-100V	Yes	Yes
VR	1VR133YB	PlmnCnst/FD-200V	No	Yes
VR	1VR133YC	PlmnCnst/FD-200V	No	Yes
VR	1VR133YD	PlmnCnst/FD-400V	Yes	Yes
VR	1VR17S	AAF/Coil Cab	No	Yes
VR	1VR17Y	Papco/Parallel Dmpr	Yes	Yes
VR	1VR18Y	Papco/Parallel Dmpr	Yes	Yes
VR	1VR55Y	Papco/Parallel Dmpr	Yes	Yes
EM	1VRC-EM007	TrTech/DCA-300	Yes	Yes
EM	1VS-EM014	TrTech/SP-215	Yes	Yes
EM	1VT-EM001	TrTech/DSA-302	Yes	Yes
EM	1VT-EM002	TrTech/SSA-302	Yes	Yes
EM	1VT-EM003	TrTech/SSA-302	Yes	Yes
EM	1VT-EM004	TrTech/SSA-302	Yes	Yes
EM	1VT-EM005	TrTech/SSA-302	Yes	Yes
VT	1VT004Y	Ruskin/Balancing Dmpr	Yes	Yes
VT	1VT005YA	Papco/Btrfly Dmpr	Yes	Yes
VT	1VT005YB	Papco/Btrfly Dmpr	Yes	Yes
VT	1VT007Y	Ruskin/Fire Dmpr	Yes	No
VT	1VT073Y	Ruskin/Fire Dmpr	Yes	Yes
VT	1VT077Y	Ruskin/Fire Dmpr 12X15	Yes	Yes
VT	1VT105Y	Ruskin/Fire Dmpr	Yes	Yes
VT	1VT117Y	Ruskin/Fire Dmpr	Yes	Yes
EM	1VX-EM009(M)	TrTech/RSA-50	Yes	Yes
VX	1VX01SA	AAF/Coil Cab	Yes	Yes
VX	1VX01SB	AAF/Coil Cab	Yes	Yes
VX	1VX01SC	AAF/Coil Cab	Yes	Yes
VX	1VX01YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX01YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX01YC	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX02SA	AAF/Coil Cab	Yes	Yes
VX	1VX02SB	AAF/Coil Cab	Yes	Yes
VX	1VX02SC	AAF/Coil Cab	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1VX02YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX02YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX02YC	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX03CA(F)	BF/Cent 730 BL	Yes	Yes
VX	1VX03CA(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX03CB(F)	BF/Cent 730 BL	Yes	Yes
VX	1VX03CB(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX03CC(F)	BF/Fan 400 BLS	Yes	Yes
VX	1VX03CC(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX03YA	Papco/SL100ML HVAC Dmpr	Yes	Yes
VX	1VX03YB	Papco/SL100ML HVAC Dmpr	Yes	Yes
VX	1VX03YC	Papco/ML HVAC Dmpr	Yes	Yes
VX	1VX04CA(F)	BF/805 BL Fan	Yes	Yes
VX	1VX04CA(M)	Wsths/Swgr Heat Rem Fan Mtr	Yes	Yes
VX	1VX04CB(F)	BF-Wsths/Mtr	Yes	Yes
VX	1VX04CB(M)	Wsths/FR:364T	Yes	Yes
VX	1VX04CC(F)	BF/Swgr Heat Rem Fan	Yes	Yes
VX	1VX04CC(M)	Wsths/Swgr Ht Rem Fn Mtr TEFC	Yes	Yes
VX	1VX04YA	Papco/SL100ML HVAC Dmpr	Yes	Yes
VX	1VX04YB	Papco/SL100ML HVAC Dmpr	Yes	Yes
VX	1VX04YC	Papco/ML HVAC Dmpr	Yes	Yes
VX	1VX05CA(F)	BF/245 BLS-Bat Rm Exh Fn	Yes	Yes
VX	1VX05CA(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX05CB(F)	BF/245 BLS-Bat Rm Exh Fn	Yes	Yes
VX	1VX05CB(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX05CC(F)	BF/245 BLS-Bat Rm Exh Fn	Yes	Yes
VX	1VX05CC(M)	Wsths/TEFC Mtr	Yes	Yes
VX	1VX05YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX05YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX05YC	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX06CA	Carrier/Cond Unit 05H60	Yes	Yes
VX	1VX06CA(M)	Rlnc/Elec Mtrs	Yes	Yes
VX	1VX06CB	Carrier/Cond Unit 05H60	Yes	Yes
VX	1VX06CB(M)	Rlnc/Elect Mtrs	Yes	Yes
VX	1VX06CC	Carrier/Cond Unit 05H60	Yes	Yes
VX	1VX06CC(M)	Reli/Elec Mtrs	Yes	Yes
VX	1VX06YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX06YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX07SA	AAF/Coil Cab	No	Yes
VX	1VX07YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX07YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX07YC	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX08YA	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX10YA	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX10YB	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX10YC	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX11CA(F)	BF/Batt Rm Exh Fan	Yes	Yes
VX	1VX11CA(M)	Wsths/TEFC	Yes	Yes
VX	1VX11CB(F)	BF/Batt Rm Exh Fan	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1VX11CB(M)	Wsths/TEFC	Yes	Yes
VX	1VX11YA	Papco/HP Backdraft Dmpr	Yes	Yes
VX	1VX11YB	Papco/HP Backdraft Dmpr	Yes	Yes
VX	1VX11YC	Papco/LP Backdraft Dmpr	Yes	Yes
VX	1VX12CA(F)	BF/SWGR Heat Rem Fan	Yes	Yes
VX	1VX12CA(M)	Wsths/Swgr HtRemRetFnMtr TEFC	Yes	Yes
VX	1VX12CB(F)	BF/SWGR Heat Rem Fan	Yes	Yes
VX	1VX12CB(M)	Wsths/Swgr HtRemRetFnMtr TEFC	Yes	Yes
VX	1VX12YC	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX13CA(F)	BF/25AW Cub Cool Fan	Yes	Yes
VX	1VX13CA(M)	Wsths/Clr Fan Mtr TBFC	Yes	Yes
VX	1VX13CB(F)	BF/25AW Cub Cool Fan	Yes	Yes
VX	1VX13CB(M)	Wsths/DivI&II Cub Clr Fan Mtr	Yes	Yes
VX	1VX13SA	AAF/Coil Cab	Yes	Yes
VX	1VX13SB	AAF/Coil Cab	Yes	Yes
VX	1VX14C(F)	BF/29A9 Adjustax Fan	Yes	Yes
VX	1VX14C(M)	Wsths/Fan Mtr TBAM 3 HP	Yes	Yes
VX	1VX14S	AAF/Coil Cab	Yes	Yes
VX	1VX14Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX15Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX19Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX23Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX25Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX26Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX31Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX35Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX36Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX38Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX39Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX42Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX45Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX51Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX52Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX54Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX55Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX56Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX57Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX58Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX59YA	Papco/Dmpr	Yes	Yes
VX	1VX59YB	Papco/Dmpr	Yes	Yes
VX	1VX60Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX63Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX64Y	Ruskin/Balancing Dmpr	Yes	Yes
VX	1VX70Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX71Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX72Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX77Y	Papco/LP Backdraft Dmpr	Yes	Yes
VX	1VX78Y	Papco/LP Backdraft Dmpr	Yes	Yes
VX	1VX79Y	Papco/LP Backdraft Dmpr	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1VX80Y	Papco/LP Backdraft Dmpr	Yes	Yes
VX	1VX81Y	Papco/LP Backdraft Dmpr	Yes	Yes
VX	1VX90Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX92Y	Ruskin/Fire Dmpr	Yes	Yes
VX	1VX93Y	Papco/LP Backdraft Dmpr	Yes	Yes
EM	1VY-EM008	TrTech/SMR-102	Yes	Yes
VY	1VY01C(F)	BF/AX 29A9 Fan	Yes	Yes
VY	1VY01C(M)	Wsths/7.5HP Mtr TBAM FR:215TCZ	Yes	Yes
VY	1VY01S	AAF/Coil Cab	Yes	Yes
VY	1VY01Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY02C(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY02C(M)	Wsths/5HP Mtr Type T FR:215TCZ	Yes	Yes
VY	1VY02S	AAF/Coil Cab	Yes	Yes
VY	1VY02Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY03C(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY03C(M)	Wsths/5HP Mtr Type T FR:215TCZ	Yes	Yes
VY	1VY03S	AAF/Coil Cab	Yes	Yes
VY	1VY03Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY04C(F)	BF/AX 18A10-LDC	Yes	Yes
VY	1VY04C(M)	Wsths/Mtr 2HP FR:184TCZ	Yes	Yes
VY	1VY04S	AAF/Coil Cab	Yes	Yes
VY	1VY04Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY05C(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY05C(M)	Wsths/5HP Mtr Type T FR:213TCZ	Yes	Yes
VY	1VY05S	AAF/Coil Cab	Yes	Yes
VY	1VY06C(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY06C(M)	Wsths/5HP Mtr Type T FR:213TCZ	Yes	Yes
VY	1VY06S	AAF/Coil Cab	Yes	Yes
VY	1VY06Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY07C(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY07C(M)	Wsths/5HP Mtr Type T FR:213TCZ	Yes	Yes
VY	1VY07S	AAF/Coil Cab	Yes	Yes
VY	1VY07Y	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY08CA(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY08CA(M)	Wsths/5HP Mtr Type T FR:213TCZ	Yes	Yes
VY	1VY08CB(F)	BF/AX 25A9 Fan	Yes	Yes
VY	1VY08CB(M)	Wsths/5HP Mtr Type T FR:213TCZ	Yes	Yes
VY	1VY08SA	AAF/Coil Cab	Yes	Yes
VY	1VY08SB	AAF/Coil Cab	Yes	Yes
VY	1VY08YB	Ruskin/Balancing Dmpr	Yes	Yes
VY	1VY09C(F)	BF-Wsths/AX 22A9 Fan	Yes	Yes
VY	1VY09C(M)	Wsths/.5 HP TEFC Fan Mtr	Yes	Yes
VY	1VY09S	AAF/Coil Cab	Yes	Yes
VY	1VY10A	AAF/Coil Cab	Yes	Yes
VY	1VY10C(F)	BF/AX 270BL Fan	Yes	Yes
VY	1VY10C(M)	Wsths/.5HP Mtr TEFC	Yes	Yes
WO	1W0001A(A)	Lmt/SMB-000	Yes	Yes
WO	1W0001A(V)	AD/6" 150# Gt Vlv	Yes	Yes
WO	1W0001B(A)	Lmt/SMB-000	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
WD	1W0001B(V)	AD/6" 150# Gt Vlv	Yes	Yes
WD	1W0002A(A)	Lmt/SMB-000	Yes	Yes
WD	1W0002A(V)	AD/6" 150# Gt Vlv	Yes	Yes
WD	1W0002B(A)	Lmt/SMB-000	Yes	Yes
WD	1W0002B(V)	AD/6" 150# Gt Vlv	Yes	Yes
WD	1W0551A(A)	Lmt/SMB-000	Yes	Yes
WD	1W0551A(V)	4" Gt Vlv M.O.	Yes	Yes
WD	1W0551B(A)	Lmt/SMB-000	Yes	Yes
WD	1W0551B(V)	4" Gt Vlv M.O.	Yes	Yes
WD	1W0552A(A)	Lmt/SMB-000	Yes	Yes
WD	1W0552A(V)	AD/4" Gt Vlv	Yes	Yes
WD	1W0552B(A)	Lmt/SMB-000	Yes	Yes
WD	1W0552B(V)	AD/4" Gt Vlv	Yes	Yes
WD	1W0570A	Dresser/.75" SRV	Yes	Yes
WD	1W0570B	Dresser/.75" SRV	Yes	Yes
WX	1WX019(L)	Namco/EA180-31302	Yes	Yes
WX	1WX019(LS)	Conax/7F20-11002-02	Yes	Yes
WX	1WX019(O)	Asco/NP8321A6E	Yes	Yes
WX	1WX019(OS)	Conax/7F20-11004-01	Yes	Yes
WX	1WX019(V)	Tuflin/Plug Vlv 2"	Yes	Yes
WX	1WX020(L)	Namco/EA180-31302	Yes	Yes
WX	1WX020(LS)	Conax/7F20-11002-02	Yes	Yes
WX	1WX020(O)	Asco/NP8321A6E	Yes	Yes
WX	1WX020(OS)	Conax/7F20-11004-01	Yes	Yes
WX	1WX020(V)	Tuflin/Plug Vlv 2"	Yes	Yes
CM	1XX-CM123	Bendix/3521265-001	Yes	Yes
CM	1XX-CM124	Bendix/3521209-1	Yes	No
CM	1XX-CM125	Bendix/3521180-2	Yes	Yes
CM	1XX-CM126	Bendix/352116.	Yes	Yes
CM	1XX-CM127	Bendix/5512284-2	Yes	Yes
CM	1XX-CM128	Bendix/55122 -2	Yes	Yes
CM	1XX-CM131	Bendix/9000	Yes	Yes
CM	1XX-CM132	Bendix/Gas Chrom Grip	Yes	Yes
CM	1XX-CM139	TI/Printer 743KSR	Yes	No
CM	1XX-CM140	TI/Printer 743KSR	Yes	No
CM	1XX-CM163	Sentry/2-01255A	Yes	Yes
CM	1XX-CM164	Sentry/2-01255A	Yes	Yes
CM	1XX-CM165	Validyne/PS-17102	Yes	Yes
CM	1XX-CM166	Validyne/PS-17102	Yes	Yes
CM	1XX-CM169	Validyne/CD-17302	Yes	Yes
CM	1XX-CM170	Validyne/CD-17302	Yes	Yes
CM	1XX-CM171	Sentry/6-00438A	Yes	Yes
CM	1XX-CM172	Sentry/6-00438A	Yes	Yes
CM	1ZL-CM133	MstrSplts/90HA1C2F4J(X)LINI	Yes	Yes
CM	1ZL-CM134	MstrSplts/90HA1C2F4J(S)LINI	Yes	Yes
CM	1ZL-CM135	MstrSplts/90HA1C2F4J(X)LINI	Yes	Yes
CM	1ZL-CM136	MstrSplts/90HA1C2F4J(X)LINI	Yes	Yes
CM	1ZL-CM137	MstrSplts/90HAK2I4J1(S)LINI	Yes	Yes
CM	1ZL-CM138	MstrSplts/90HA1C2F4J(X)LINI	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
CM	1ZL-CM183	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM184	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM185	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM189	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM190	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM193	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM194	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM195	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM196	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM215	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM216	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM217	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM218	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM219	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM220	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM221	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM222	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM223	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM224	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM225	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM226	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM227	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM228	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM229	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM230	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM231	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM232	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM233	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM234	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM235	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM236	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM237	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
CM	1ZL-CM238	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
PR	1ZL-PR050	MstrSpclts/90HA1C2F4J1(X)LINI	Yes	Yes
SX	1ZL-SX065A	Position Light	Yes	No
SX	1ZL-SX065B	Position Light	Yes	No
SX	1ZL-SX066A	Position Light	Yes	No
SX	1ZL-SX066B	Position Light	Yes	No
SX	1ZL-SX067A	Position Light	Yes	No
SX	1ZL-SX067B	Position Light	Yes	No
VA	1ZL-VA001	GE/ET-16#127B8177G9	Yes	Yes
VA	1ZL-VA002	GE/ET-16#127B8177G9	Yes	Yes
VF	1ZL-VF021B	GE/ET-16#127B8177G9	Yes	Yes
VF	1ZL-VF022B	GE/ET-16#127B8177G9	Yes	Yes
VF	1ZL-VF023B	GE/ET-16#127B8177G9	Yes	Yes
VF	1ZL-VF024B	GE/ET-16#127B8177G9	Yes	Yes
VG	1ZL-VG155	GE/ET-16#127B8177G9	Yes	No
VQ	1ZL-VQ125	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX010	GE/ET-16#127B8177G9	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1ZL-VX011	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX012	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX013	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX014	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX015	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX054	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX055	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX105A	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX107A	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX109A	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX111	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX113	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX115	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX120	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX122	GE/ET-16#127B8177G9	Yes	Yes
VX	1ZL-VX124	GE/ET-16#127B8177G9	Yes	Yes
VA	1ZS-VA002A	Namco/EA170	Yes	Yes
VA	1ZS-VA002B	Namco/EA170	Yes	Yes
VF	1ZS-VF021A	Namco/EA170	Yes	Yes
VF	1ZS-VF021B	Namco/EA170	Yes	Yes
VF	1ZS-VF022A	Namco/EA170	Yes	Yes
VF	1ZS-VF022B	Namco/EA170	Yes	Yes
VF	1ZS-VF023A(L)	Namco/EA180	Yes	Yes
VF	1ZS-VF023A(LS)	Conax/7F20-11002-03	Yes	Yes
VF	1ZS-VF023B(L)	Namco/EA180	Yes	Yes
VF	1ZS-VF023B(LS)	Conax/7F20-11002-03	Yes	Yes
VF	1ZS-VF024A(L)	Namco/EA180	Yes	Yes
VF	1ZS-VF024A(LS)	Conax/7F20-11002-03	Yes	Yes
VF	1ZS-VF024B(L)	Namco/EA180	Yes	Yes
VF	1ZS-VF024B(LS)	Conax/7F20-11002-03	Yes	Yes
VG	1ZS-VG008AA	Namco/EA170	Yes	Yes
VG	1ZS-VG008AB	Namco/EA170	Yes	Yes
VG	1ZS-VG008BA	Namco/EA170	Yes	Yes
VG	1ZS-VG008BB	Namco/EA170	Yes	Yes
VG	1ZS-VG008DA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008DB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008EA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008EA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG008EB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008EB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG008FA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008FA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG008FB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG008FB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG009AA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG009AA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG009AB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG009AB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG009BA(L)	Namco/EA180	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VG	1ZS-VG0098A(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG0098B(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG0098B(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108AA	Namco/EA170	Yes	Yes
VG	1ZS-VG108AB	Namco/EA170	Yes	Yes
VG	1ZS-VG108BA	Namco/EA170	Yes	Yes
VG	1ZS-VG108BB	Namco/EA170	Yes	Yes
VG	1ZS-VG108DA(L)	Namco/EA170	Yes	Yes
VG	1ZS-VG108DA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108DB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG108DB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108EA(L)*	Namco/EA180	Yes	Yes
VG	1ZS-VG108EA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108EB(L)*	Namco/EA180	Yes	Yes
VG	1ZS-VG108EB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108FA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG108FA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG108FB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG108FB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG109AA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG109AA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG109AB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG109AB(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG109BA(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG109BA(LS)	Conax/7F20-11008-01	Yes	Yes
VG	1ZS-VG109BB(L)	Namco/EA180	Yes	Yes
VG	1ZS-VG109BB(LS)	Conax/7F20-11008-01	Yes	Yes
VQ	1ZS-VQ023A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ023A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ023B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ023B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ025A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ025A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ025B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ025B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ027A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ027A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ027B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ027B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ029A	Namco/EA740	Yes	Yes
VQ	1ZS-VQ029A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ029B	Namco/EA740	Yes	Yes
VQ	1ZS-VQ029B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ031A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ031A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ031B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ031B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ033A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ033A(LS)	Conax/7F20-11000-02	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
=====	=====	=====	=====	=====
VQ	1ZS-VQ033B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ033B(LS)	Conax/7F20-11002-03	Yes	Yes
VQ	1ZS-VQ095A	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ095A(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ095B	Namco/EA740-50100	Yes	Yes
VQ	1ZS-VQ095B(LS)	Conax/7F20-11000-01	Yes	Yes
VQ	1ZS-VQ099A(L)	Namco/EA180-31302	Yes	Yes
VQ	1ZS-VQ099A(LS)	Conax/7F20-11008-01	Yes	Yes
VQ	1ZS-VQ099B(L)	Namco/EA180-32302	Yes	Yes
VQ	1ZS-VQ099B(LS)	Conax/7F20-11008-01	Yes	Yes
VQ	1ZS-VQ125A	Namco/EA170	Yes	No
VQ	1ZS-VQ125B	Namco/EA170	Yes	No
VR	1ZS-VR008A	Namco/EA740	Yes	Yes
VR	1ZS-VR008A(LS)	Conax/7F20-11004-01	Yes	Yes
VR	1ZS-VR008B	Namco/EA740	Yes	Yes
VR	1ZS-VR008B(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR009A	Namco/EA740	Yes	Yes
VQ	1ZS-VR009A(LS)	Conax/7F20-11004-01	Yes	Yes
VR	1ZS-VR009B	Namco/EA740	Yes	Yes
VQ	1ZS-VR009B(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR108A	Namco/EA180	Yes	Yes
VR	1ZS-VR108A(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR108B	Namco/EA180	Yes	Yes
VR	1ZS-VR108B(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR109A	Namco/EA180	Yes	Yes
VR	1ZS-VR109A(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR109B	Namco/EA180	Yes	Yes
VR	1ZS-VR109B(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR162A	Namco/EA180	Yes	Yes
VR	1ZS-VR162A(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR162B	Namco/EA180	Yes	Yes
VR	1ZS-VR162B(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR163A	Namco/EA180	Yes	Yes
VR	1ZS-VR163A(LS)	Conax/7F20-11002-03	Yes	Yes
VR	1ZS-VR163B	Namco/EA180	Yes	Yes
VR	1ZS-VR163B(LS)	Conax/7F20-11002-03	Yes	Yes
VX	1ZS-VX010A	Namco/EA170	Yes	Yes
VX	1ZS-VX010B	Namco/EA170	Yes	Yes
VX	1ZS-VX011A	Namco/EA170	Yes	Yes
VX	1ZS-VX011B	Namco/EA170	Yes	Yes
VX	1ZS-VX012A	Namco/EA170	Yes	Yes
VX	1ZS-VX012B	Namco/EA170	Yes	Yes
VX	1ZS-VX013A	Namco/EA170	Yes	Yes
VX	1ZS-VX013B	Namco/EA170	Yes	Yes
VX	1ZS-VX014A	Namco/EA170	Yes	Yes
VX	1ZS-VX014A(LS)	Conax/7F20-11002-03	Yes	Yes
VX	1ZS-VX014B	Namco/EA170	Yes	Yes
VX	1ZS-VX014B(LS)	Conax/7F20-11002-03	Yes	Yes
VX	1ZS-VX015A	Namco/EA170	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
VX	1ZS-VX015B	Namco/EA170	Yes	Yes
VX	1ZS-VX054A	Namco/EA170	Yes	Yes
VX	1ZS-VX054B	Namco/EA170	Yes	Yes
VX	1ZS-VX055A	Namco/EA170	Yes	Yes
VX	1ZS-VX055B	Namco/EA170	Yes	Yes
SX	2SX017A(A)	LMT/SMB-000-2/H1BC	Yes	Yes
SX	2SX017A(V)	PosiSl/8" 150# Btrfly Vlv	Yes	Yes
SX	2SX017B(A)	LMT/SMB-000-2/H1BC	Yes	Yes
SX	2SX017B(V)	PosiSl/8" 150# Btrfly Vlv	Yes	Yes
SX	2SX073A(A)	Lmt/SMB-000	Yes	Yes
SX	2SX073A(V)	AD/3" 150# Gt Vlv	Yes	No
SX	2SX073B(A)	Lmt/SMB-000	Yes	Yes
SX	2SX073B(V)	AD/3" 150# Gt Vlv	Yes	No
SX	2SX076A	AD/3" 150# Gt Vlv	Yes	No
SX	2SX076A(A)	Lmt/SMB-000	Yes	Yes
SX	2SX076B	AD/3" 150# Gt Vlv	Yes	No
SX	2SX076B(A)	Lmt/SMB-000	Yes	Yes
SX	2SX107A	AD/3" 150# Gt Vlv	Yes	No
SX	2SX107A(A)	Lmt/SMB-000	Yes	Yes
SX	2SX107B(A)	Lmt/SMB-000	Yes	Yes
SX	2SX107B(V)	AD/3" 150# Gt Vlv	Yes	No
NB	DW21-F379A	GPE/2" Vac Rel Vlv	Yes	Yes
FS	N/A	GE/Def Fuel St Rack	Yes	No
00	N/A	NelsonElec/MCT 1970-1	Yes	Yes
00	N/A	NelsonElec/MCT 1970-2	Yes	Yes
00	N/A	NelsonElec/MCT 1970-3	Yes	Yes
00	N/A	NelsonElec/MCT 1970-4	Yes	Yes
00	N/A	NelsonElec/MCT 1970-5	Yes	Yes
00	N/A	NelsonElec/MCT 1970-6	Yes	Yes
00	N/A	NelsonElec/MCT 1970-7	Yes	Yes
00	N/A	NelsonElec/MCT 1970-8	Yes	Yes
00	N/A	NelsonElec/MCT 1970-9	Yes	Yes
00	N/A	NelsonElec/MCT 1970-10	Yes	Yes
00	N/A	NelsonElec/MCT 1970-11	Yes	Yes
00	N/A	NelsonElec/MCT 1970-12	Yes	Yes
00	N/A	NelsonElec/MCT 1970-13	Yes	Yes
00	N/A	NelsonElec/MCT 1970-14	Yes	Yes
-	N/A	Zack/ExhPlnm PL-1EnFn1VR04CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-2EnFn1VT06CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-3EnFn0VJ02CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-4EnFn0VW04CA,B	Yes	Yes
-	N/A	Zack/SupPlnm PL-5EnFn0VL01CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-13EnFn0VA05CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-14EnFn1VF04CA,B	Yes	Yes
-	N/A	Zack/SupPlnm PL-15EnFn1VF03CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-16EnFn0VA06CA,B	Yes	Yes
-	N/A	Zack/SupPlnm PL-17EnFn0VL02CA,B	Yes	Yes
-	N/A	Zack/ExhPlnm PL-18EnFn0VL18CA,B	Yes	Yes
-	N/A	Zack/RecPlnm PL-19EnFn0VC04CA,B	Yes	Yes

ILLINOIS POWER COMPANY
CLINTON POWER STATION,
DOCKET NUMBER 50-461

QUALIFICATION/INSTALLATION STATUS BY EQUIPMENT NUMBER
=====

SYSTEM	EQUIPMENT NUMBER	MANUFACTURER/MODEL NUMBER	INSTALLED	QUALIFIED
-	N/A	Zack/ExhPlnmPL-20EnFn1VD03CA,B	Yes	Yes
-	N/A 6	Zack/SupPlnm PL-6EnFn1VR03CA,B	Yes	Yes
-	N/A 7	Zack/SupPlnm PL-7EnFn0VA04CA,B	Yes	Yes