

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

January 28, 1986

Mr. Harold R. Denton, Director
Office of Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: B.J. Youngblood, Director ✓
PWR Project Directorate No. 4

Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370
Technical Specification Amendment,
Containment Integrated Leak Rate


Dear Mr. Denton:

By letter dated August 20, 1985, Duke Power requested a change to Technical Specification 3.6.1.2 concerning the allowed containment leakage rate. The proposed change affected 3.6.1.2a.1 and 3.6.1.2a.2 for allowed L_a and L_t , respectively, increasing each value by 50%. Since the justification and safety analysis in support of the proposed change addressed only the full pressure testing and leakage, Duke Power requests that the proposed change to Specification 3.6.1.2a.2 concerning reduced pressure testing be disregarded as indicated on the attached page and only 3.6.1.2a.1 concerning full pressure testing be pursued. As McGuire has not conducted a reduced pressure test, has no data on such a test, and no plans to conduct a reduced pressure test, there is no basis for this changing the specification as it relates to reduced pressure testing.

As this request supplements an earlier submittal, no fees are required.

Please feel free to contact us if you require additional information.

Very truly yours,



Hal B. Tucker

JBD/jgm

8602070024 860128
PDR ADOCK 05000369
P PDR

Attachment

xc: Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

W.T. Orders
NRC Resident Inspector - MNS

Mr. Darl Hood
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

AD - J. KNIGHT (ltr only)
EB (BALLARD)
EICSB (ROSA)
PSB (GAMMILL)
RSB (BERLINGER)
FOB (BENAROYA)

A017
1/1
Add: