

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2										DOCKET NUMBER (2) 0 5 0 0 0 3 6 1				PAGE (3) 1 OF 0 1		
TITLE (4) DELINQUENT SURVEILLANCE OF CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
10	25	85	85	054	00	11	25	85					0 5 0 0 0 0 0 0			
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)														
1		20.402(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)		
POWER LEVEL (10)		20.405(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)		
0 9 3		20.405(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20.405(a)(1)(iii)				X 50.73(a)(2)(i)				50.73(a)(2)(viii)(A)						
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)						
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(x)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME H. E. MORGAN, STATION MANAGER										TELEPHONE NUMBER AREA CODE 7 1 4 3 6 8 - 6 2 4 1						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC						
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR
YES (If yes, complete EXPECTED SUBMISSION DATE)												X NO				

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

On 10/25/85, it was determined that the 60 month surveillance interval contained in Technical Specification Surveillance Requirement 4.8.4.1.b had been exceeded on Containment Penetration Conductor Overcurrent Protective Devices 2BF08 and 2BF09 (EIIIS Component Code BKR). A discrepancy had been identified on 09/19/85 during a routine Quality Assurance Audit when it was determined that four circuit breakers listed in Table 3.8-1 of the Technical Specifications were not inspected during May/June 1983 when maintenance associated with procedure S023-I-2.47, Revision 3, was performed. Our investigation revealed that two of the circuit breakers, 2BF08 and 2BF09, were last surveilled on July 6, 1978, and May 12, 1978, respectively, and thus the maximum surveillance interval had been exceeded. The remaining two breakers had not exceeded the surveillance interval. This surveillance requirement, which involves inspection and preventative maintenance in accordance with the manufacturer's recommendations, was properly performed on all four breakers on 09/23/85.

The breakers were not tested at the expected time because they were inadvertently omitted from the Maintenance Data Record Form (MDRF) when the procedure was revised. This was corrected in a subsequent annual procedure review, resulting in Revision 4 to the procedure.

Although the surveillance interval was exceeded for two of the breakers, they subsequently passed their surveillance indicating that they were capable of performing their safety function throughout this period. For this reason, this condition is not considered to have any safety significance.



*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

TELEPHONE  
(714) 368-6241

November 25, 1985

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Docket No. 50-361  
30-Day Report  
Licensee Event Report No. 85-054  
San Onofre Nuclear Generating Station, Unit 2

Pursuant to 10 CFR 50.73(a)(2)(i)(B), this submittal provides the required 30-day written Licensee Event Report (LER) involving delinquent surveillance of components in the Electrical Power System. Neither the health and safety of plant personnel nor the health and safety of the public was affected by this event.

If you require any additional information, please so advise.

Sincerely,

Enclosure: LER No. 85-054

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

J. B. Martin (Regional Administrator, USNRC Region V)

Institute of Nuclear Power Operations (INPO)

IE22  
11