

CONTAINMENT SYSTEMSCONTAINMENT LEAKAGELIMITING CONDITION FOR OPERATION

3.6.1.2 Containment leakage rates shall be limited to:

- a. An overall integrated leakage rate of:
  - 1) Less than or equal to  $L_a$ , 0.30% by weight of the containment air per 24 hours at  $P_a$ , 14.8 psig, or
  - 2) Less than or equal to  $L_t$ , 0.14% by weight of the containment air per 24 hours at a reduced pressure of  $P_t$ , 7.4 psig.
- b. A combined leakage rate of less than  $0.60 L_a$  for all penetrations and valves subject to Type B and C tests, when pressurized to  $P_a$ , and
- c. A combined bypass leakage rate of less than  $0.07 L_a$  for all penetrations identified in Table 3.6-1 as secondary containment bypass leakage paths when pressurized to  $P_a$ .

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With (a) the measured overall integrated containment leakage rate exceeding  $0.75 L_a$  or  $0.75 L_t$ , as applicable, or (b) the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding  $0.60 L_a$ , or (c) the combined bypass leakage rate exceeding  $0.07 L_a$ , restore the overall integrated leakage rate to less than  $0.75 L_a$  or less than or equal to  $0.75 L_t$ , as applicable, and the combined leakage rate for all penetrations and valves subject to Type B and C tests to less than  $0.60 L_a$ , and the combined bypass leakage rate to less than  $0.07 L_a$  prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4-1972 or the mass-plot method:

B602070027 B6012B  
PDR ADDCK 05000369  
P PDR