

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-86-9A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility: GPU Nuclear Corporation  
Three Mile Island Unit 1  
Docket No. 50-289  
Middletown, PA

Licensee Emergency Classification:  
\_\_\_\_ Notification of Unusual Event  
\_\_\_\_ Alert  
\_\_\_\_ Site Area Emergency  
\_\_\_\_ General Emergency  
X Not Applicable

Subject: (UPDATE) PLANT OUTAGE -- RESTART

The plant was restarted on February 4, 1986, and is currently at 88 percent power. The startup went smoothly and the licensee plans to raise the plant to full power later today. During the outage which began January 27, 1986, the licensee replaced six turbine extraction steam bellows inside the main condenser.

The resident inspectors are following events on-site. The PN update is for information only and is current as of 9:00 a.m., February 5. The Commonwealth of Pennsylvania has been notified.

CONTACT: Allen Blough  
488-1146

Harry Kister  
488-1233

DISTRIBUTION:

H. St.	MNBB	Phillips	E/W	Willste	Mail: ADM:DMB
Chairman Palladino	EDO	NRR	IE	NMSS	DOT:Trans only
Comm. Zech	PA		OIA	RES	
Comm. Bernthal	ELD		AEOD		
Comm. Roberts					
Comm. Asselstine					
ACRS	Air Rights		INPO----		
SECY	SP		NSAC----		
CA					
PDR	Regional Offices				

TMI Resident Section \_\_\_\_\_  
RI Resident Office \_\_\_\_\_

Licensee: \_\_\_\_\_  
(Reactor Licensees)

Region I Form 83  
(Rev. July, 1984)

B602070055 B60205  
PDR I&E  
PNO-I-86-009A PDR

d/ IC-34