

Docket No. 50-285

November 19, 1985

DCR
OK

Mr. R. L. Andrews
Division Manager - Nuclear Production
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Andrews:

The Commission has completed the review of your November 4, 1983 responses to Generic Letter 83-28 Items 3.1.1 and 3.1.2, Post-Maintenance Testing (Reactor Trip System Components). Item 3.1.1 deals with review of test and maintenance procedures and Technical Specifications. Item 3.1.2 deals with a review of vendor and engineering recommendations. In regard to Item 3.1.1, you stated that plant maintenance procedures contain provisions to test that portion of the reactor trip system on which the maintenance was performed prior to returning it to service, and the testing demonstrates that the component can perform its required function. This is acceptable. In regard to Item 3.1.2, you stated that due to vendor and engineering recommendations, two new procedures and a surveillance test have been implemented. In addition, maintenance procedures have been developed to include the manufacturer's recommendations for preventative maintenance on components in the reactor protection system. This is also acceptable.

Based on the above, we conclude that your responses to the GL 83-28 Items 3.1.1 and 3.1.2 are acceptable, and we consider our review for these two items complete.

Sincerely,

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

cc: See next page

Distribution:

Docket File	JHopkins
NRC & L PDRs	ETourigny
Branch Files	EButcher
OELD	AThadani
HThompson	
ACRS 10	
EJordan	
PKreutzer	
JBess	

ORB#3:DL
PKreutzer
11/18/85

ORB#3:DL
ETourigny;ef
11/18/85

ORB#3:DL
EButcher
11/19/85

8512050397 851119
PDR ADOCK 05000285
P PDR

Mr. R. L. Andrews
Omaha Public Power District

Fort Calhoun Station
Unit No. 1

cc:
Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, D.C. 20036

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68023

Metropolitan Planning Agency
ATTN: Dagnia Frieditis
7000 West Center Road
Omaha, Nebraska 68107

Mr. Phillip Harrell, Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Bethesda, Maryland 20814

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011