

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION AND NUMBER	MAXIMUM ISOLATION TIME (Seconds)
B. <u>Remote-Manual Isolation Valves</u> ^(e) (Continued)	
19. <u>Primary Containment Monitoring System Torus Suction Isolation Valves</u>	NA
Division I: T50-F407A	
Division II: T50-F407B	
20. <u>Drywell Atmosphere Sample Isolation Valves</u>	NA
Division I: T50-F401A	
T50-F402A	
T50-F403A	
T50-F404A	
T50-F405A	
T50-F406A	
Division II: T50-F401B	
T50-F402B	
T50-F403B	
T50-F404B	
T50-F405B	
T50-F406B	
21. <u>Drywell to Suppression Chamber Vacuum Breakers N₂ Supply Isolation Valves</u>	NA
T48-F416	
T48-F417	
T48-F418	
T48-F419	
T48-F420	
T48-F421	
T48-F422	
T48-F423	
T48-F424	
T48-F425	
T48-F426	
T48-F427	