

REFUELING OPERATIONS

SURVEILLANCE REQUIREMENTS (Continued)

- b. Performance of a CHANNEL FUNCTIONAL TEST:
 - 1. Within 24 hours prior to the start of CORE ALTERATIONS, and
 - 2. At least once per 7 days.
- c. Verifying that the channel count rate is at least 0.7* cps:
 - 1. Prior to control rod withdrawal,
 - 2. Prior to and at least once per 12 hours during CORE ALTERATIONS, and
 - 3. At least once per 24 hours.
- d. Verifying, within 8 hours prior to and at least once per 12 hours during, that the RPS circuitry "shorting links" have been removed during the time any control rod is withdrawn** unless adequate shutdown margin has demonstrated per Specification 3.1.1.

* For only the fuel movements required to replace neutron sources, the count rate may be reduced to 0.3 counts per second prior to achieving a burnup of 2000 MWD/T on the first core provided the signal-to-noise ratio ≥ 2 . After a burnup of 2000 MWD/T, the count rate must be at least 0.7 cps provided the signal-to-noise ratio is ≥ 2 . Otherwise, 3 cps.

~~*Provided signal-to-noise ratio is ≥ 2 . Otherwise, 3 cps.~~

**Not required for control rods removed per Specification 3.9.10.1 or 3.9.10.2.

FERMI - UNIT 2

3/4 9-4