



**Commonwealth Edison**  
One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

DMB

January 29, 1986

Mr. James G. Keppler  
Regional Administrator  
Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

SUBJECT: Braidwood Station Units 1 and 2  
10 CFR 50.55(e) No. 84-16 Final Report  
ASME Material Procurement Documentation  
NRC Docket Nos. 50-456/50-457

- REFERENCE: (a) D.H. Smith letter to J.G. Keppler  
dated October 2, 1984
- (b) D.H. Smith letter to J.G. Keppler  
dated November 28, 1984
- (c) D.H. Smith letter to J.G. Keppler  
dated February 8, 1985
- (d) D.H. Smith letter to J.G. Keppler  
dated April 12, 1985
- (e) A.D. Miosi letter to J.G. Keppler  
dated August 2, 1985
- (f) A.D. Miosi letter to J.G. Keppler  
dated November 4, 1985

Dear Mr. Keppler:

The above references provided information concerning a potential deficiency reportable pursuant to 10 CFR 50.55(e) regarding the adequacy of ASME Material Procurement Documentation at our Braidwood Station. The purpose of this letter is to inform you that the corrective actions identified by Commonwealth Edison to address this issue are now complete. This is considered to be a final report.

8602130406 860129  
PDR ADDCK 05000456  
S PDR

1E27  
1/0

FEB 4 1986

In summary, the review of the documentation for approximately 4,300 heat/lot numbers pertaining to site procured ASME materials is complete. Approximately 2,200 items required additional documentation from the manufacturer/supplier or corrective action to associated records. Of the total heat/lot numbers, 397 required additional corrective action to bring the documentation into conformance with ASME Section III requirements. Two heat/lot numbers require replacement in limited applications which will be completed prior to completing the N-5 Data Reports.

Based on the review of the documentation and revisions to applicable procedures pertaining to procurement and receipt inspections, Commonwealth Edison Company considers corrective actions for this issue complete.

Please address any questions that you or your staff may have concerning this matter to this office.

Very truly yours,

*A.D. Miosi*

A.D. Miosi  
Nuclear Licensing Administrator

ADM/pav

cc: NRC Resident Inspector - Braidwood  
1219K