

NOTICE OF VIOLATION

Public Service Electric & Gas Co.
Hudson Generating Station
Jersey City, NJ 07306

Docket No. 030-22088

License No. 29-20659-02

During an NRC inspection conducted on March 27, 1997, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," (Enforcement Policy), NUREG 1600, the violation is listed below:

- A. License Condition No. 14 of NRC License No. 29-20659-02 requires that each gauge be tested for the proper operation of the on-off mechanism and indicator at no longer than six-month intervals.

Contrary to the above, as of March 27, 1997 each gauge has not been tested for the proper operation of the on-off mechanism and indicator at no longer than six-month intervals. Specifically, the licensee possesses 18 fixed gauges, each containing a sealed cesium-137 source, and none have been routinely tested for proper shutter operation at the required interval. Licensee representatives were unaware of the requirement.

This is a Severity Level IV violation (Supplement VI).

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric & Gas Co., Hudson Generating Station is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region I, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Your response may reference or include previous docketed correspondence, if the correspondence adequately addresses the required response. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Because your response will be placed in the NRC Public Document Room (PDR), to the extent possible, it should not include any personal privacy, proprietary, or safeguards information so that it can be placed in the PDR without redaction. However, if you find it necessary to include such information, you should clearly indicate the specific information that you desire not to be placed in the PDR, and provide the legal basis to support your request for withholding the information from the public.

RETURN ORIGINAL TO
REGION I

OFFICIAL RECORD COPY

9704150059 970408
PDR ADOCK 03022088
C PDR