

Detroit
Edison

Douglas R. Gipson
Senior Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 596-5249

10CFR50.73

April 7, 1997
NRC-97-0029

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Reference: Fermi 2
Docket No. 50-341
NRC License No. NPF-43

Subject: Licensee Event Report (LER) No. 97-005

Pursuant to Fermi 2 License Condition 2.C.9 and 10CFR50.73(a)(2)(i)(B), Detroit Edison is submitting the enclosed LER No. 97-005 regarding the Emergency Equipment Cooling Water (EECW) makeup tank isolation valve interlocks potentially preventing operation of EECW from Dedicated Shutdown Panel.

The following commitments are being made in this LER:

1. A modification to the plant will be made to ensure that the operation of the EECW makeup tank isolation valve meets the operability requirements of Technical Specifications. Appropriate changes to the dedicated shutdown procedures will also be made.
2. A review of the Dedicated Shutdown Panel circuits will be performed to assure that there are no other similar concerns.

These actions will be completed prior to startup from the current outage.


9704150071 970407
PDR ADOCK 05000341
S PDR



1/1
Lezz

If you have any questions, please contact Mari Jaworsky, Compliance Engineer,
at (313) 586-1427.

Sincerely,

A handwritten signature in cursive script, appearing to read "Mari Jaworsky".

cc: A. B. Beach
G. A. Harris
M. J. Jordan
A. J. Kugler
M. V. Yudas, Jr.
Region III
Wayne County Emergency Management Division