



Northeast
Utilities System



Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791

March 24, 1997

Docket No. 50-245
B16310

Re: 10CFR50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-017-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on February 22, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(i).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16310-1 NNECO commits that OP 344A will be revised by March 31, 1997, to delete the installation of the jumper and require that Technical Specification Limiting Condition for Operation 3.1.C.1 be entered if a battery is removed from service.
- B16310-2 NNECO commits that a review of this event will be included in the annual Plant Operations Review Committee training.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp
Director, Unit Operations

Attachment: LER 97-017-00

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

9704150076 970324
PDR ADOCK 05000245
S PDR

IE 22/1

