



TEXAS UTILITIES GENERATING COMPANY
SEYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

WILLIAM G. COUNSIL
EXECUTIVE VICE PRESIDENT

September 24, 1985
TXX-4567

Mr. D.R. Hunter, Chief
Reactor Project Branch 2
U.S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

Docket Nos.: 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
AUXILIARY FEEDWATER SYSTEM
QA FILE: CP-85-32, SDAR-193
FILE NO.: 10110

Dear Mr. Hunter:

On August 27, 1985 we verbally notified your Mr. T. Westerman of a deficiency regarding the potential elimination of control capability of the feedwater regulating valve due to its power supply being located in the cable spread room.

We are continuing our evaluation and anticipate completion by October 18, 1985.

Very truly yours,

W.G. Council
W.G. Council

WGC:mlm

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8509300481 850924
PDR ADOCK 05000445
S PDR

85-861

IE-27
1/0