



LOUISIANA
POWER & LIGHT

142 DELARONDE STREET
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

December 2, 1985

ROTH S. LEDDICK
Senior Vice President
Nuclear Operations

W3P85-3174
3-A1.01.04
A4.05
QA

Director of Nuclear Reactor Regulation
Attention: Mr. G.W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: Waterford SES Unit 3
Docket No. 50-382
Technical Specification Change Requests
NPF-38-08, NPF-38-09, NPF-38-10, NPF-38-11,
NPF-38-12

Dear Sir:

Louisiana Power & Light hereby files an application for five amendments to the Waterford 3 Technical Specifications. The amendments involve:

1. Deletion of the Core Protection Calculator Addressable Constants,
2. Revisions to incorporate the results of a revised Core Operating Limit Supervisory System "out of service" analysis,
3. Correction of a typographical error in referencing ANSI Standard 3.1-1978,
4. A revision to allow a lower RCS temperature during inservice leak and hydrostatic testing while in Mode 4, and
5. A revision to allow credit for startup testing measurement of the moderator temperature coefficient.

The enclosed proposed changes do not involve an unreviewed safety question nor a significant hazards consideration.

8512060305 851202
PDR ADOCK 05000382
P PDR


Rec'd w/check #150-00

A001
1/1

Mr. G.W. Knighton
W3P85-3174
Page 2

Should you have any questions or require additional information concerning these requested changes, please contact Mike Meisner at (504) 595-2832.

Yours very truly,



R.S. Leddick
Senior Vice President
Nuclear Operations

RSL/MJM/pcl

Enclosures: NPF-38-08
NPF-38-09
NPF-38-10
NPF-38-11
NPF-38-12

cc: B.W. Churchill, W.M. Stevenson, R.D. Martin, J. Wilson,
NRC Resident Inspector's Office (W-3), Administrator Nuclear Energy
Division (State of Louisiana)

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION


In the matter of

Louisiana Power & Light Company
Waterford 3 Steam Electric Station

)
)
) Docket No. 50-382
)

AFFIDAVIT


R.S. Leddick, being duly sworn, hereby deposes and says that he is Senior Vice President - Nuclear Operations of Louisiana Power & Light Company; that he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached Technical Specification Change requests; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.



R.S. Leddick
Senior Vice President
Nuclear Operations

STATE OF LOUISIANA)
) ss
PARISH OF ORLEANS)

Subscribed and sworn to before me, a Notary Public in and for the Parish
and State above named this 2nd day of December 1985


Notary Public

My Commission expires 12 month.