



**Northeast
Utilities System**

Millstone Offices • Rope Ferry Rd., Waterford, CT

P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791

April 7, 1997

Docket No. 50-245
B16336

Re: 10CFR50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-003-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on March 6, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(i).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16336-1 NNECO commits to revise procedures to ensure that Service Water effluent from the Reactor Building is operated within design basis and Technical Specifications prior to operating Cycle 16.
- B16336-2 NNECO commits to perform a review, prior to operating Cycle 16, if system configuration enhancements will be made.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp
Director, Unit Operations

Attachment: LER 97-003-00

cc: Dr. W. D. Travers, Director, Special Projects
H. J. Miller, Region I Administrator
S. Dembek, NRC Project Manager, Millstone Unit No. 1
T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

IE221

9704150251 970407
PDR ADOCK 05000245
S PDR

